Permit to Operate

FACILITY: S-1372 EXPIRATION DATE 05/31/200

LEGAL OWNER OR OPERATOR: NUEVO ENERGY COMPANY **MAILING ADDRESS:** 1200 DISCOVERY DR, STE 500

BAKERSFIELD, CA 93309

FACILITY LOCATION: HEAVY OIL WESTERN

, CA

FACILITY DESCRIPTION: OIL AND NATURAL GAS PRODUCTION

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

The Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

DAVID L. CROW

Executive Director / APCO

Seyed Sadredin

Director of Permit Services

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-0-1 EXPIRATION DATE: 05/31/2007

EQUIPMENT DECRIPTION:

- The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary.
 [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)],
 [Federally Enforceable Through Title V]
- 2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)], [Federally Enforceable Through Title V]
- 3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0], [Federally Enforceable Through Title V]
- 4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020. [District Rule 2010, 3.0 and 4.0; and 2020], [Federally Enforceable Through Title V]
- 5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.9.1 and 9.13.1], [Federally Enforceable Through Title V]
- 6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031], [Federally Enforceable Through Title V]
- 7. Every application for a permit required under Rule 2010 (12/17/92) (Permits Required) shall be filed in a manner and form prescribed by the District. [District Rule 2040], [Federally Enforceable Through Title V]
- 8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.5.1], [Federally Enforceable Through Title V]
- 9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.6.1], [Federally Enforceable Through Title V]
- 11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520(6/15/95) [District Rules 2520, 9.6.2 and 1100, 7.0], [Federally Enforceable Through Title V]

- 12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.8], [Federally Enforceable Through Title V]
- 13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.9.2], [Federally Enforceable Through Title V]
- 14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.9.3], [Federally Enforceable Through Title V]
- 15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.9.4], [Federally Enforceable Through Title V]
- 16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.9.5], [Federally Enforceable Through Title V]
- 17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.10], [Federally Enforceable Through Title V]
- 18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.14.2.1], [Federally Enforceable Through Title V]
- 19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.14.2.2], [Federally Enforceable Through Title V]
- 20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.14.2.3], [Federally Enforceable Through Title V]
- 21. Upon the request of an authorized representative of the District, a permittee shall collect, have collected, or allow the APCO to monitor or sample, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.14.2.4], [Federally Enforceable Through Title V]
- 22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (12/17/92), by using EPA method 9. If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)], [Federally Enforceable Through Title V]
- 23. No person shall supply, sell, solicit or apply any architectural coating, except specialty coatings, that contains more than 250 grams of VOC per liter of coating (less water and exempt compounds, and excluding any colorant added to tint bases), or manufacture, blend, or repackage such coating with more than 250 grams of VOC per liter (less water and exempt compounds, and excluding any colorant added to tint bases) for use within the District. [District Rule 4601, 5.1], [Federally Enforceable Through Title V]
- 24. Specialty Coating Limitations: No person shall apply, sell, solicit, or offer for sale any architectural coating listed in the Tables of Standards (District Rule 4601, Table 1 and Table 2), nor manufacture, blend, or repackage such coating for use within the District, which contains VOCs in excess of the specified limits after the corresponding date listed in Table 1(grams of VOC per liter of coating as applied less water and exempt compounds, excluding any colorant added to tint bases) and in Table 2 (grams of VOC per liter of material), except as provided in Section 5.3 of Rule 4601. [District Rule 4601, 5.2], [Federally Enforceable Through Title V]
- 25. All VOC-containing materials shall be stored in closed containers when not in use. In use includes, but is not limited to: being accessed, filled, emptied, maintained or repaired. [District Rule 4601, 5.4], [Federally Enforceable Through Title V]
- 26. A person shall not use VOCs for the cleanup of spray equipment unless equipment for collection of the cleaning compounds and minimizing its evaporation to the atmosphere is used. [District Rule 4601, 5.5], [Federally Enforceable Through Title V]
- 27. The permittee shall comply with all the Labeling and Test Method requirements outlined in Rule 4601 sections 6.1 and 6.2 (9/17/97). [District Rule 4601, 6.1 and 6.2], [Federally Enforceable Through Title V]
- 28. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.14.1 and 10.0], [Federally Enforceable Through Title V]

- 29. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F], [Federally Enforceable Through Title V]
- 30. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart F. [40 CFR Part 82, Subpart F], [Federally Enforceable Through Title V]
- 31. Disturbances of soil related to any construction, demolition, excavation, extraction, and other earthmoving activities shall comply with the requirements for fugitive dust control in Rule 8021 (11/15/01) unless specifically exempted under section 4.0 of Rule 8021. [District Rule 8021], [Federally Enforceable Through Title V]
- 32. Outdoor handling, storage, and transport of any bulk material shall comply with the requirements of Rule 8031 (11/15/01), unless specifically exempted under section 4.0 of Rule 8031. [District Rule 8031], [Federally Enforceable Through Title V]
- 33. Any open area having 3.0 acres or more of disturbed surface area, that has remained undeveloped, unoccupied, unused or vacant for more than seven days shall comply with the requirements of Rule 8051 (11/15/01), unless specifically exempted under section 4.0 of Rule 8051. [District Rule 8051], [Federally Enforceable Through Title V]
- 34. Any new or existing public or private paved or unpaved road, road construction project, or road modification project shall implement the control measures and design criteria of, and comply with the requirements of Rule 8061 (11/15/01) unless specifically exempted under section 4.0 of Rule 8061. [District Rule 8061], [Federally Enforceable Through Title V]
- 35. Any unpaved vehicle/equipment traffic area of 1.0 acre or larger shall comply with the requirements of Rule 8071 (11/15/01), unless specifically exempted under section 4.0 of Rule 8071. [District Rule 8071], [Federally Enforceable Through Title V]
- 36. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M], [Federally Enforceable Through Title V]
- 37. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.17], [Federally Enforceable Through Title V]
- 38. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2], [Federally Enforceable Through Title V]
- 39. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permit shall apply. [District Rule 2520, 9.1.1], [Federally Enforceable Through Title V]
- 40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 41. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (12/17/92); 4601, sections 5.1, 5.2, 5.4, 5.5, 6.1, and 6.2 (9/17/97); 8020 (4/25/96); 8030 (4/25/96); 8060 (4/25/96); A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 42. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 43. When applicable to 40 CFR Part 68, a subject facility shall submit to the proper authority a Risk Management Plan when mandated by the regulation. [40 CFR Part 68], [Federally Enforceable Through Title V]
- 44. On June 30, 2002, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days of the end of the reporting period. [District Rule 2520], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-1-18 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

25.2 MMBTU/HR NATURAL GAS/TEOR GAS FIRED STEAM GENERATOR #3 (DIS #44770-65) WITH FGR AND O2 CONTROLLER

- 1. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. This equipment is approved to be operated at the following locations: SW/4 Sec. 22, T32S/R23E; Sec. 10 and 23, T31S/R22E; Sec. 10, T29S/R21E; and Sec. 06, T30S, R22E. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Vapors from TEOR operation, permit # S-1372-100 may be incinerated in this steam generator. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Emission rates shall not exceed any of the following; PM10: 0.054 lb/MMBtu, SOx (as SO2): 0.68 lb/MMBtu, NOx (as NO2): 30 ppmv @ 3% O2 or 0.036 lb/MMBtu, VOC: 0.017 lb/MMBtu, or CO: 111 ppmv @ 3% O2 or 0.082 lb/MMBtu. [District NSR Rule, District Rule 4305], [Federally Enforceable Through Title V]
- 5. Standby flare S-1372-100 shall only be used to incinerate TEOR vapors when one or more of steam generators, S-1372-1, '2 or '4 are not in operation. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Total sulfur oxide (SOx as SO2) emissions shall not exceed 1185.63 lb/day from steam generators S-1372-1, '2 and '4 and flare '100. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Sulfur content of TEOR gas and fuel gas shall be demonstrated quarterly by detection tube sampling or other District approved methods. [District Rule 1081], [Federally Enforceable Through Title V]
- 8. The following units are included in permittee's Rule 4405 alternate emission limit plan: S-1372-1, -2, -3, -4, -5, -7, -8, -11, -21, -23, -26, and -29. [District NSR Rule], [Federally Enforceable Through Title V]
- 9. No emission reduction credit shall be granted for this steam generator while it is part of the approved 4405 alternate emission limit plan. [District Rule 4405], [Federally Enforceable Through Title V]
- 10. The permittee shall use flue gas recirculation (FGR) when the steam generator is in operation. [District Rule 4305], [Federally Enforceable Through Title V]
- 11. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. In-stack O2 monitors are acceptable for O2 measurement. [District Rule 4305], [Federally Enforceable Through Title V]
- 12. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall notify the District and return the NOx and CO concentrations to the allowable emissions rate as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate after one hour, the permittee shall conduct an emissions test within 60 days, utilizing District approved test methods, to determine compliance with the applicable emissions limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 13. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within an acceptable range. These records shall be retained at the facility for a period of no less than 2 years and shall be made available for District inspection upon request. [District Rules 4305], [Federally Enforceable Through Title V]
- 14. Exhaust stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 1081], [Federally Enforceable Through Title V]
- NOx and CO emissions shall be measured with source testing conducted not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 16. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]

- 17. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, NOx and CO emission limits shall be measured not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 18. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 19. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 20. Compliance source testing shall be conducted under conditions representative of normal operation. [District Rule 1081], [Federally Enforceable Through Title V]
- 21. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, and stack gas oxygen EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4305], [Federally Enforceable Through Title V]
- 22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 23. Permittee shall maintain records of volume of fuel gas burned and TEOR gas incinerated, fuel gas and TEOR gas sulfur content, and such records shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 1070], [Federally Enforceable Through Title V]
- 24. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 25. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 27. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 28. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 29. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 30. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 33. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 34. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and 407 (Kern)], [Federally Enforceable Through Title V]

- 35. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. Units allowed to utilize the averaging option are: S-1372-1, -2, -4, -5, -13, -16, -17, -18, -19, -20, -24, and -26. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 36. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 37. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 38. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108.1 (Kern), 424 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 39. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 40. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-2-13 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

32.0 MMBTU/HR TEOR/NATURAL GAS-FIRED STEAM GENERATOR #5 (DIS #44826-70) WITH FGR AND O2 CONTROLLER (RULE 4305, GROUP II).

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. This equipment is approved to be operated at the following locations: Sec. 06, T30S/R22E, Sec.'s 23 & 24, T31S/R22E; and Sec. 10, T31S/R22E. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Vapors from TEOR operation, permit # S-1372-100 may be incinerated in this steam generator. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Sulfur content of TEOR gas and fuel gas shall be demonstrated quarterly by detection tube sampling or other District approved methods. [District Rule 1081], [Federally Enforceable Through Title V]
- 6. Emission rates shall not exceed any of the following; PM10: 0.070 lb/MMBtu, SOx (as SO2): 0.939 lb/MMBtu, NOx (as NO2): 30 ppmv @ 3% O2 or 0.036 lb/MMBtu, VOC: 0.006 lb/MMBtu, or CO: 111 ppmv @ 3% O2 or 0.082 lb/MMBtu. [District NSR Rule, District Rule 4305], [Federally Enforceable Through Title V]
- 7. Flare S-1372-100 shall only be used to incinerate TEOR vapors when one or more of steam generators S-1372-1, '2 or '4 are not in operation. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Total sulfur oxide (SOx as SO2) emissions shall not exceed 1185.63 lb/day from steam generators S-1372-1, '2 and '4 and flare '100. [District NSR Rule], [Federally Enforceable Through Title V]
- The permittee shall use flue gas recirculation (FGR) when the steam generator is in operation. [District Rule 4305], [Federally Enforceable Through Title V]
- 10. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. In-stack O2 monitors are acceptable for O2 measurement. [District Rule 4305], [Federally Enforceable Through Title V]
- 11. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall notify the District and return the NOx and CO concentrations to the allowable emissions rate as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate after one hour, the permittee shall conduct an emissions test within 60 days, utilizing District approved test methods, to determine compliance with the applicable emissions limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 12. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within an acceptable range. These records shall be retained at the facility for a period of no less than 2 years and shall be made available for District inspection upon request. [District Rules 4305], [Federally Enforceable Through Title V]
- 13. Exhaust stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 1081], [Federally Enforceable Through Title V]
- 14. Source testing to measure NOx and CO emissions shall be conducted within 60 days of initial startup, or by date compliance must be demonstrated, which ever is sooner, and not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 15. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]

- 16. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 17. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 18. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 19. Compliance source testing shall be conducted under conditions representative of normal operation. [District Rule 1081], [Federally Enforceable Through Title V]
- 20. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, and stack gas oxygen EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4305], [Federally Enforceable Through Title V]
- 21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 22. Permittee shall maintain records of volume of fuel gas burned and TEOR gas incinerated, fuel gas and TEOR gas sulfur content, and such records shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 1070], [Federally Enforceable Through Title V]
- 23. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 24. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 25. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 27. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 28. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 29. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]

- 33. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and 407 (Kern)], [Federally Enforceable Through Title V]
- 34. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. Units allowed to utilize the averaging option are listed in PTO S-1372-1. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 35. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 36. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 37. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108.1 (Kern), 424 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 38. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 39. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-3-7 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

32 MMBTU/HR NATIONAL NATURAL GAS FIRED STEAM GENERATOR (#6 DIS# 2245-72). (RULE 4305, GROUP II UNIT) (CANCELED PER ATC S 1372-318-1, CMD 5/17/99)

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081]
- 3. All wells producing from strata steamed by this unit shall be connected to a District-approved emissions control system, have District-approved closed casing vents or be District-approved uncontrolled cyclic wells. [District Rule 4401]
- 4. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. []
- 5. Only PUC-regulated quality natural gas shall be burned. []
- 6. Emission rate of particulate matter (PM-10) shall not exceed 0.10 lbm/hr. []
- 7. Emission rate of Sulfur Oxide (as SO2) shall not exceed 0.02 lbm/hr. []
- 8. Emission rate of Nitrogen Oxide (as NO2) shall not exceed 0.10 lb/MMBtu. []
- 9. Emission rate of Volatile Organic Componds (VOC) shall not exceed 0.09 lbm/hr. []
- 10. Emission rate of Carbon Monoxide (CO) shall not exceed 1.12 lbm/hr. []
- 11. Compliance with sulfur compound (SO2) emission limit shall be determined by fuel gas sulfur analysis performed 60 days prior to permit anniversary date. []
- 12. Records required by this permit shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District NSR Rule]
- 13. No emission reduction credit shall be granted for this steam generator until it is removed from the approved 4405 alternate emission limit plan.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-4-10 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

25.2 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR #44 (DIS #44784-67) WITH FGR AND O2 CONTROLLER (RULE 4305, GROUP II).

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Burner shall be equipped with operational fuel gas volume flowrate indicator. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Generator shall not be operated if oxygen controller is not operating properly. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Vapors from TEOR operation, permit # S-1372-100 may be incinerated in this steam generator. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Sulfur content of TEOR gas and fuel gas shall be demonstrated quarterly by detection tube sampling or other District approved methods. [District Rule 1081], [Federally Enforceable Through Title V]
- 6. No emission reduction credit shall be granted for this steam generator while it is part of the approved 4405 alternate emission limit plan. [District Rule 4405], [Federally Enforceable Through Title V]
- 7. Emission rates shall not exceed any of the following; PM10: 0.001 lb/MMBtu, SOx (as SO2): 0.088 lb/MMBtu, NOx (as NO2): 30 ppmv @ 3% O2 or 0.036 lb/MMBtu, or CO: 111 ppmv @ 3% O2 or 0.082 lb/MMBtu. [District NSR Rule, District Rule 4305], [Federally Enforceable Through Title V]
- 8. Flare S-1372-100 shall only be used to incinerate TEOR vapors when one or more of steam generators S-1372-1, '2 or '4 are not in operation. [District NSR Rule], [Federally Enforceable Through Title V]
- 9. Total sulfur oxide (SOx as SO2) emissions shall not exceed 1185.63 lb/day from steam generators S-1372-1, '2 and '4 and flare '100. [District NSR Rule], [Federally Enforceable Through Title V]
- 10. The permittee shall use flue gas recirculation (FGR) when the steam generator is in operation. [District Rule 4305], [Federally Enforceable Through Title V]
- 11. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. In-stack O2 monitors are acceptable for O2 measurement. [District Rule 4305], [Federally Enforceable Through Title V]
- 12. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall notify the District and return the NOx and CO concentrations to the allowable emissions rate as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate after one hour, the permittee shall conduct an emissions test within 60 days, utilizing District approved test methods, to determine compliance with the applicable emissions limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 13. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within an acceptable range. These records shall be retained at the facility for a period of no less than 2 years and shall be made available for District inspection upon request. [District Rules 4305], [Federally Enforceable Through Title V]
- 14. Exhaust stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 1081], [Federally Enforceable Through Title V]
- 15. Source testing to measure NOx and CO emissions shall be conducted within 60 days of initial startup, or by date compliance must be demonstrated, which ever is sooner, and not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 16. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]

- 17. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 18. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 19. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 20. Compliance source testing shall be conducted under conditions representative of normal operation. [District Rule 1081], [Federally Enforceable Through Title V]
- 21. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, and stack gas oxygen EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4305], [Federally Enforceable Through Title V]
- 22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 23. Permittee shall maintain records of volume of fuel gas burned and TEOR gas incinerated, fuel gas and TEOR gas sulfur content, and such records shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 1070], [Federally Enforceable Through Title V]
- 24. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 25. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 27. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 28. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 29. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 30. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 33. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]

- 34. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and 407 (Kern)], [Federally Enforceable Through Title V]
- 35. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. Units allowed to utilize the averaging option are listed in PTO S-1372-1. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 36. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 37. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 38. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108.1 (Kern), 424 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 39. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 40. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-5-15 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

32 MMBTU/HR OIL/TEOR GAS/NATURAL GAS FIRED STEAM GENERATOR (#2 DIS# 4510-75) WITH WESTINGHOUSE HAGAN O2 ANALYZER/CONTROLLER. (RULE 4305, GROUP II UNIT) (CANCELED PER ATC S-1372-318-1, CMD 5/17/99)

- 1. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
- 2. Total sulfur content of natural gas combusted shall not exceed 0.2 grain/100 scf. [District NSR Rule]
- 3. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule]
- 4. Fuel oil sulfur content shall not exceed 1.75% by weight. [District NSR Rule]
- Emission rates shall not exceed the following: PM10: 0.088 lb/MMBtu, NOx (as NO2): 0.260 lb/MMBtu, VOC: 0.0044 lb/MMBtu, CO: 0.021 lb/MMBtu. [District Rule 2201]
- 6. SOx (as SO2) emissions shall not exceed 1.23 lb/MMBtu except as provided below in condition #7. [District Rule 2201]
- 7. This steam generator shall be exclusively fired on utility grade natural gas when steam generators S-1372-8, '-13, '-16, and '-24 are incinerating TEOR vapors. [District NSR Rule]
- 8. Particulate matter emissions shall not exceed 0.1 grains/dscf @ 12% CO2. [District Rule 4201]
- 9. When oil firing, compliance source testing for NOx, PM10, SO2 and fuel oil sulfur content shall be conducted annually (or as approved by the District) within 60 days prior to the permit anniversary. [District NSR Rule]
- 10. Compliance with natural gas fired sulfur compound (SO2) emission limit shall be determined by fuel gas sulfur analysis performed 60 days prior to permit anniversary date. [District NSR Rule]
- 11. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081]
- 12. No emission reduction credit shall be granted for this steam generator until it is removed from the approved 4405 alternate emission limit plan. [District NSR Rule]
- 13. The permittee shall maintain records of fuel type, quantity, permitted emission factors and emissions for each unit for each day of operation, in the format approved by the District. [District NSR Rule]
- 14. Records required by this permit shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District NSR Rule]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-7-16 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

30 MMBTU/HR OIL/TEOR GAS/NATURAL GAS-FIRED STEAM GENERATOR #9, DIS# 44508-76 (MCKITTRICK FRONT/GAMBLE LEASE). (RULE 4305, GROUP II UNIT) (CANCELED PER ATC S-1372-318-1, CMD 5/17/99)

- 1. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
- 2. Total sulfur content of natural gas combusted shall not exceed 0.2 grain/100 scf. []
- 3. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. []
- 4. Fuel oil sulfur content shall not exceed 0.5% by weight. []
- Emission rates shall not exceed the following: PM10: 0.035 lb/MMBtu, NOx (as NO2): 0.260 lb/MMBtu, VOC: 0.0044 lb/MMBtu, CO: 0.022 lb/MMBtu. [District Rule 2201]
- 6. SOx (as SO2) emissions shall not exceed 0.340 lb/MMBtu except as provided below in condition #7. [District Rule 2201]
- 7. Steam generators S-1372-7, -10, -14, -23, -30, -31, -32, -33, and -34 shall be fired exclusively on utility grade natural gas when steam generators S-1372-17, 18, 19, 20 are incinerating TEOR vapors. [District NSR Rule]
- 8. Particulate matter emissions shall not exceed 0.1 grains/dscf @ 12% CO2. []
- 9. When oil firing, compliance source testing for NOx, PM10, SO2 and fuel sulfur content shall be conducted annually (or as approved by the District) within 60 days prior to the permit anniversary. []
- 10. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081]
- 11. Compliance with natural gas fired sulfur compound (SO2) emission limit shall be determined by fuel gas sulfur analysis performed 60 days prior to permit anniversary date. []
- 12. The permittee shall maintain records of fuel type, quantity, permitted emission factors and emissions for each unit for each day of operation, in the format approved by the District. [District NSR Rule]
- 13. Records required by this permit shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District NSR Rule]
- 14. No emission reduction credit shall be granted for this steam generator until it is removed from the approved 4405 alternate emission limit plan.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-8-16 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

32 MMBTU/HR J.F. NATURAL GAS/TEOR GAS FIRED STEAM GENERATOR (#10 DOME, DIS# 44510-76) WITH FLUE GAS RECIRCULATION AND O2 CONTROLLER.

- 1. Approved locations for this equipment: Sec. 16, T31S/R22E (Bremer Lease) and SW/4 of Sec. 10, T31S/R22E (E&M Lease). [District NSR Rule], [Federally Enforceable Through Title V]
- 2. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. When burning TEOR gas, steam generators S-1372-10, -14, -30, -31, -32, -33, -34, and -318 shall be fired exclusively on utility grade natural gas. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Emissions shall not exceed any of the following: PM10: 0.014 lb/MMBtu; NOx (as NO2): 30 ppmv @ 3% O2; VOC: 0.003 lb/MMBtu; or CO: 29 ppmv @ 3% O2. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. SOx (as SO2) emissions shall not exceed 1193.52 lb/day for this steam generator. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Total SOx (as SO2) emissions shall not exceed 1578.08 lb/day for the following steam generators: S-1372-8 (#10), S-1372-17 (#19); S-1372-18 (#28), S-1372-19 (#29), and S-1372-20 (#30). [District NSR Rule], [Federally Enforceable Through Title V]
- 7. When burning TEOR gas, sulfur compound (SO2) emission limit compliance shall be demonstrated by fuel gas sulfur analysis performed 60 days prior to permit anniversary date. [District Rule 1081], [Federally Enforceable Through Title V]
- 8. When burning TEOR gas, compliance with casing gas sulfur compound emission limits shall be demonstrated by record keeping of TEOR gas flowrate and H2S concentration. [District Rule 1070], [Federally Enforceable Through Title V]
- 9. This unit shall be tested for compliance with the NOx and CO emissions limits at least once every 12 months. After demonstrating compliance on two consecutive annual source tests, the unit shall be tested not less than once every thirty-six months. [District Rule 4305], [Federally Enforceable Through Title V]
- 10. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 11. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rule 4305], [Federally Enforceable Through Title V]
- 12. NOx emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rule 4305], [Federally Enforceable Through Title V]
- 13. Stack gas oxygen shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rule 4305], [Federally Enforceable Through Title V]
- 14. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 15. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers/Compu-Nox emissions analyzer. [District Rule 4305], [Federally Enforceable Through Title V]
- 16. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. These records shall be retained at the facility for a period of no less than 2 years and shall be made available for District inspection upon request. [District Rule 4305], [Federally Enforceable Through Title V]

- 17. If the NOx or CO concentrations, as measured by the portable analyzer/Compu-NOx emissions analyzer, exceed the allowable emissions rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emissions limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 18. The portable analyzer shall be calibrated as recommended by the manufacturer. All instrument calibration data shall be kept on file including the date of calibration. The calibration date shall not exceed 6 months prior to the date the stack concentrations are measured and recorded. [District Rule 4305], [Federally Enforceable Through Title V]
- 19. Concentration measurements shall not be taken until the sample acquisition probe has been exposed to the stack gas for at least 150% of the response time. Measurements shall be taken in triplicate. [District Rule 4305], [Federally Enforceable Through Title V]
- 20. If water vapor is not removed prior to measurement, the absolute humidity in the gas stream must be determined so that the gas concentrations may be reported on a dry basis. [District Rule 4305], [Federally Enforceable Through Title V]
- 21. If water vapor creates an interference with the measurement of any component, then the water vapor must be removed from the gas stream prior to concentration measurements. [District Rule 4305], [Federally Enforceable Through Title V]
- 22. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 23. During source testing, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 24. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 25. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 27. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 28. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 29. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 33. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rule 407 (Kern)], [Federally Enforceable Through Title V]

- 34. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 35. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 36. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 37. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108.1 (Kern), 404 (Kern), 408 (Kern) and 407.2 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 38. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 39. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-10-17 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR NATURAL GAS/TEOR GAS FIRED STEAM GENERATOR (#11 BREMER, DIS# 44511-76) LOW-NOX BURNER AND O2 CONTROLLER

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Emissions shall not exceed any of the following: PM10: 0.014 lb/MMBtu; NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2; VOC: 0.0003 lb/MMBtu; or CO: 400 ppmv @ 3 % O2. [District NSR Rule & Rule 4305], [Federally Enforceable Through Title V]
- 3. SOx (as SO2) emissions shall not exceed 46.4 lb/day except as provided below in condition #4. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Steam generators S-1372-10, -14, -30, -31, -32, -33, -34, and -318 shall be fired exclusively on utility grade natural gas when steam generators S-1372-8, 17, 18, 19, 20 are incinerating TEOR vapors. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Compliance with gas fired sulfur compound (SO2) emission limit shall be determined by fuel gas sulfur analysis performed 60 days prior to permit anniversary date. [District Rule 1070], [Federally Enforceable Through Title V]
- 6. Source testing to measure NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rules 4305], [Federally Enforceable Through Title V]
- 7. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305], [Federally Enforceable Through Title V]
- 8. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control
 method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305], [Federally Enforceable
 Through Title V]
- 10. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 11. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 12. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 13. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, and 4305], [Federally Enforceable Through Title V]
- 14. Compliance with casing gas sulfur compound emission limits shall be demonstrated by record keeping of casing gas flowrate and H2S concentration. [District NSR Rule], [Federally Enforceable Through Title V]
- 15. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 16. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]

- 17. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 18. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 19. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 20. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 21. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 22. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 23. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 24. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 25. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 27. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 28. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 29. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)], [Federally Enforceable Through Title V]
- 30. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

- 33. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 34. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 35. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 36. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2 and 4351, 6.3], [Federally Enforceable Through Title V]
- 37. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 38. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 39. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 40. The number of representative units source tested to demonstrate compliance for NOx limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-11-7 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

27.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (#7 DIS# 44852-14) WITH O2 CONTROLLER AND SO2 SCRUBBER (HOPKINS LEASE). (RULE 4305, GROUP II UNIT) (CANCELED PER ATC S-1372-318-1, CMD 5/17/99)

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
- 3. All wells producing from strata steamed by this unit shall be connected to a District-approved emissions control system, have District-approved closed casing vents or be District-approved uncontrolled cyclic wells. [District Rule 4401]
- 4. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. []
- 5. Burner shall be equipped with operational fuel gas volume flowrate indicator. []
- 6. Natural gas fuel shall be of PUC quality with a maximum sulfur content of 0.1 gr/100 dscf. []
- 7. Noncondensible vapors from TEOR operation S-1372-100 shall be incinerated in this steam generator. []
- 8. Emissions shall not exceed PM10: 0.03 lbm/hr, SOx (as SO2): 6.63 lbm/hr, VOC: 0.20 lbm/hr, CO: 1.02 lbm/hr. []
- 9. Emission rate for Nitrogen Oxides shall not exceed 0.10 lb/MMBtu. []
- 10. No emission reduction credit shall be granted for this steam generator until it is removed from the approved 4405 alternate emission limit plan.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-13-18 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR NATURAL GAS/TEOR GAS FIRED STEAM GENERATOR (#16, DIS# 12667-79) EQUIPPED WITH FLUE GAS RECIRCULATION (FGR) AND O2 CONTROLLER.

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Emissions shall not exceed any of the following: PM10: 0.014 lb/MMbtu; NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2; VOC: 0.003 lb/MMBtu; or CO: 400 ppmv @ 3% O2. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. SOx (as SO2) emissions shall not exceed 123.2 lb/day except as provided below in conditions 4 and 5. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Steam generator S-1372-317 shall be exclusively fired on PUC quality natural gas when this steam generator is incinerating TEOR vapors. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Total casing gas sulfur oxide (SOx as SO2) emissions shall not exceed 1193.52 lb/day for the following steam generators and standby flare: S-1372-13 (#16), S-1372-16 (#12), S-1372-24 (#20), and S-1372-76. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Compliance with gas fired sulfur compound (SO2) emission limit shall be determined by record keeping of TEOR gas flowrate and fuel gas sulfur analysis performed 60 days prior to permit anniversary date. [District Rule 1070], [Federally Enforceable Through Title V]
- 7. Source testing to measure NOx and CO emissions shall be conducted within 60 days of startup, and not less than once every 12 months, except as provided below. [District Rules 4305], [Federally Enforceable Through Title V]
- 8. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305], [Federally Enforceable Through Title V]
- 9. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305], [Federally Enforceable Through Title V]
- 10. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 4305], [Federally Enforceable Through Title V]
- 11. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 12. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 14. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081 and 4305], [Federally Enforceable Through Title V]
- 15. Compliance with casing gas sulfur compound emission limits shall be demonstrated by record keeping of casing gas flowrate and H2S concentration. [District NSR Rule], [Federally Enforceable Through Title V]
- 16. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 17. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]

- 18. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 19. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 20. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 21. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 22. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 23. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 24. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 25. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 26. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 27. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 28. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 30. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)], [Federally Enforceable Through Title V]
- 31. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. Units allowed to utilize the averaging option are listed in PTO S-1372-1. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]

- 33. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 34. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 35. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 36. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 37. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2 and 4351, 6.3], [Federally Enforceable Through Title V]
- 38. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 39. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 40. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 41. The number of representative units source tested to demonstrate compliance for NOx limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-14-17 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR NATURAL GAS/TEOR GAS FIRED STEAM GENERATOR (#13 BREMER, DIS# 44521-76) EQUIPPED WITH O2 CONTROLLER AND FGR

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. No less than 0.5 miles of roadway shall be paved and maintained in good repair. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Emissions shall not exceed any of the following: PM10: 0.014 lb/MMbtu; NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2; VOC: 0.003 lb/MMBtu; or CO: 400 ppmv @ 3% O2. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. SOx (as SO2) emissions shall not exceed 46.4 lb/day except as provided below in condition #5. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Steam generators S-1372-10, -14, -23, -30, -31, -32, -33, -34, and -318 shall be fired exclusively on PUC quality natural gas when steam generators S-1372-8, 17, 18, 19, 20 are incinerating TEOR vapors. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Compliance with gas fired sulfur compound (SO2) emission limit shall be determined by fuel gas sulfur analysis performed 60 days prior to permit anniversary date. [District Rule 1070], [Federally Enforceable Through Title V]
- 7. Source testing to measure NOx and CO emissions shall be conducted within 60 days of startup, and not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 8. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 9. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 10. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305], [Federally Enforceable Through Title V]
- 11. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 12. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 14. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081 and District Rule 4305], [Federally Enforceable Through Title V]
- 15. Compliance with casing gas sulfur compound emission limits shall be demonstrated by record keeping of casing gas flowrate and H2S concentration. [District NSR Rule], [Federally Enforceable Through Title V]
- 16. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 17. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]

- 18. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 19. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 20. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 21. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 22. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 23. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 24. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 25. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 26. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 27. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 28. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 30. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)], [Federally Enforceable Through Title V]
- 31. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 33. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

- 34. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 35. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 36. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 37. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2 and 4351, 6.3], [Federally Enforceable Through Title V]
- 38. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 39. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 40. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 41. The number of representative units source tested to demonstrate compliance for NOx limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-16-19 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR NATURAL GAS/TEOR GAS FIRED STEAM GENERATOR (#12 MCKITTRICK FRONT, DIS# 44519-76) EQUIPPED WITH O2 CONTROLLER, LOW-NOX BURNER AND FGR.

- 1. This steam generator is approved to operate at the following locations: Sec. 23, T31S, R22E, NW 1/4 Sec. 6, T30S, R22E, and NW 1/4 Sec. 10, T29S, R21E [District NSR Rule], [Federally Enforceable Through Title V]
- 2. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. No less than 0.5 miles of roadway shall be paved and maintained in good repair. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. The steam generator shall be equipped with piping from TEOR operation S-1372-76 to fuel gas inlet on burner when operating at Sec. 23, T31S, R22E. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Emissions shall not exceed any of the following: PM10: 0.014 lb/MMbtu; NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2; VOC: 0.0012 lb/MMBtu; or CO: 400 ppmv @ 3% O2. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. SOx (as SO2) emissions shall not exceed 92.5 lb/day except as provided below in conditions 8 and 9. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Steam generator S-1372-317 shall be exclusively fired on PUC quality natural gas when this steam generator is incinerating TEOR vapors. [District NSR Rule], [Federally Enforceable Through Title V]
- 9. Total casing gas sulfur oxide (SOx as SO2) emissions shall not exceed 1193.52 lb/day for the following steam generators and standby flare: S-1372-13 (#16), S-1372-16 (#12), S-1372-24 (#20), and S-1372-76. [District NSR Rule], [Federally Enforceable Through Title V]
- 10. Compliance with gas fired sulfur compound (SO2) emission limit shall be determined by record keeping of TEOR gas flowrate and fuel gas sulfur analysis performed 60 days prior to permit anniversary date. [District Rule 1070], [Federally Enforceable Through Title V]
- 11. Source testing to measure NOx and CO emissions shall be conducted within 60 days of startup, and not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 12. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 13. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 14. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305], [Federally Enforceable Through Title V]
- 15. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 16. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

- 18. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081 and 4305], [Federally Enforceable Through Title V]
- 19. Compliance with casing gas sulfur compound emission limits shall be demonstrated by record keeping of casing gas flowrate and H2S concentration. [District NSR Rule], [Federally Enforceable Through Title V]
- 20. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 21. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 22. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 23. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 24. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 25. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 26. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 27. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 28. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 29. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 30. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 33. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 34. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)], [Federally Enforceable Through Title V]

- 35. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. Units allowed to utilize the averaging option are listed in PTO S-1372-1. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 36. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 37. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 38. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 39. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 40. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 41. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2 and 4351, 6.3], [Federally Enforceable Through Title V]
- 42. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 43. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 44. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 45. The number of representative units source tested to demonstrate compliance for NOx limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-17-20 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR OIL/NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (#19 DIS# 45002-80) EQUIPPED WITH LOW-NOX BURNER.

- 1. Steam generators S-1372-1 and '-17 shall not be located simultaneously at any of the following locations: Sec. 22, T32S, R23E; NE/4 & SE/4 Sec. 21, T32S, R23E; NW/4 & NE/4 Sec. 27, T32S, R23E; and NE/4 Sec. 28, T32S, R23E. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Steam generator firebox convection section, scrubber bypass valve, and all flue gas ductwork shall be maintained with no detectable leaks. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. This steam generator is authorized for incineration of non-condensible vapors from TEOR operation #S-1372-312. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. No less than 0.35 miles of roadway shall be paved and maintained in good repair. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. The permittee shall maintain records of fuel type, quantity, permitted emission factors and emissions for each unit for each day of operation, in the format approved by the District. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Gas-fired emissions shall not exceed PM10: 0.048 lb/MMbtu; and VOC: 0.0006 lb/MMBtu. [District NSR Rule], [Federally Enforceable Through Title V]
- 9. Gas fired emission rates shall not exceed the following: NOx 30 ppmv and CO 400 ppmv calculated to 3.00% O2 by volume stack gas oxygen and averaged over 60 minutes. [District Rule 4305], [Federally Enforceable Through Title V]
- 10. SOx (as SO2) emissions shall not exceed 95.54 lb/day except as provided below in conditions 14 and 15. [District NSR Rule], [Federally Enforceable Through Title V]
- 11. Total casing gas sulfur oxide (SOx as SO2) emissions shall not exceed 1578.08 lb/day for the following steam generators: S-1372-8 (#10), S-1372-17 (#19); S-1372-18 (#28), S-1372-19 (#29), and S-1372-20 (#30). [District NSR Rule], [Federally Enforceable Through Title V]
- 12. Steam generators S-1372-10, -14, -30, -31, -32, -33, -34, and -318 shall be fired exclusively on utility grade natural gas when this steam generator is gas-fired and incinerating TEOR vapors. [District NSR Rule], [Federally Enforceable Through Title V]
- 13. Sulfur compound (SO2) emission limit compliance shall be demonstrated by fuel gas sulfur analysis performed 60 days prior to permit anniversary date. [District Rule 1081], [Federally Enforceable Through Title V]
- 14. Compliance with casing gas sulfur compound emission limits shall be demonstrated by record keeping of TEOR gas flowrate and H2S concentration. [District NSR Rule], [Federally Enforceable Through Title V]
- 15. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305], [Federally Enforceable Through Title V]
- 16. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 17. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305], [Federally Enforceable Through Title V]

- 18. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 19. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 21. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, and 4305], [Federally Enforceable Through Title V]
- 22. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 23. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 24. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 25. During natural gas curtailment, total cumulative hours of operation for burning liquid fuel shall not exceed 336 hours per calendar year, excluding equipment testing which shall not exceed 48 hours per year. [District Rule 4305], [Federally Enforceable Through Title V]
- 26. The owner of any unit operated under the exemption of natural gas curtailment shall monitor and record for each unit the cumulative annual hours of operation on each liquid fuel during curtailment and testing. [District Rule 4305], [Federally Enforceable Through Title V]
- 27. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 28. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 30. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 31. Source testing shall be performed using EPA Method 5 while firing on residual oil (including crude or topped crude) to demonstrate compliance with PM emission limits. Source testing shall be performed within 60 days of firing on residual oil unless such testing has been performed within the 12 month period prior to firing on said oil and the test results showed compliance with PM emission limits of this permit. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or on diesel fuel not exceeding 0.5% sulfur by weight; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 33. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 34. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

- 35. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 36. If the unit is fired on noncertified liquid fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the liquid fuel being fired in the unit shall be determined using ASTM D 2880. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 37. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 240 or D 238288 for liquid hydrocarbon fuels; ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 38. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas or diesel fuel not exceeding 0.5% sulfur by weight; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels or 3.0% by weight for residual oil (including crude or topped crude); or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)], [Federally Enforceable Through Title V]
- 39. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. Units allowed to utilize the averaging option are listed in PTO S-1372-1. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 40. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. For residual oil (including crude and topped crude) fired units, compliance may be demonstrated through supplier certification of nitrogen content and heating value or by weekly fuel testing for nitrogen content and heating value. Hourly emissions shall be calculated using the heating value, maximum rated unit capacity, and the following formula: lb NO2/1000 gal = 20.54 + 104.39 (N), where N is the weight % nitrogen in the fuel. If compliance with the NOx emission limit is demonstrated through the fuel nitrogen content testing and compliance has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be bi-annually. If a bi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 41. If the unit is fired on noncertified residual oil (including crude and topped crude) and compliance with NOx emission limits is achieved through fuel nitrogen content testing, then the nitrogen content of the fuel being fired in the unit shall be determined using ASTM D3431. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 42. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 43. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 44. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 45. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 46. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 47. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 48. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2 and 4351, 6.3], [Federally Enforceable Through Title V]

- 49. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 50. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 51. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 52. The number of representative units source tested to demonstrate compliance for NOx limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-18-20 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR OIL/NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (#28 DIS# 45003-80) EQUIPPED WITH FLUE GAS RECIRCULATION (FGR).

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. No less than 0.35 miles of roadway shall be paved and maintained in good repair. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Noncondensible vapors from TEOR operation, permit # S-1372-77, may be incinerated in this steam generator. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Gas-fired emission rates shall not exceed the following: NOx 30 ppmv and CO 400 ppmv calculated to 3.00% O2 by volume stack gas oxygen and averaged over 60 minutes. [District Rule 4305], [Federally Enforceable Through Title V]
- 5. Gas-fired emissions shall not exceed any of the following: PM10: 0.064 lb/MMbtu; or VOC: 0.006 lb/MMbtu. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. SOx (as SO2) emissions shall not exceed 95.54 lb/day except as provided below in conditions 7 and 8. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Total casing gas sulfur oxide (SOx as SO2) emissions shall not exceed 1578.08 lb/day for the following steam generators: S-1372-8 (#10), S-1372-17 (#19); S-1372-18 (#28), S-1372-19 (#29), and S-1372-20 (#30). [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Steam generators S-1372-10, -14, -30, -31, -32, -33, -34, and -318 shall be fired exclusively on utility grade natural gas when this steam generator is gas-fired and incinerating TEOR vapors. [District NSR Rule], [Federally Enforceable Through Title V]
- 9. Sulfur compound (SO2) emission limit compliance shall be demonstrated by fuel gas sulfur analysis performed 60 days prior to permit anniversary date. [District Rule 1081], [Federally Enforceable Through Title V]
- 10. Compliance with casing gas sulfur compound emission limits shall be demonstrated by record keeping of TEOR gas flowrate and H2S concentration. [District Rule 1070], [Federally Enforceable Through Title V]
- 11. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305], [Federally Enforceable Through Title V]
- 12. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 13. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305], [Federally Enforceable Through Title V]
- 14. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 17. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, and 4305], [Federally Enforceable Through Title V]

- 18. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 19. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 20. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 21. During natural gas curtailment, total cumulative hours of operation for burning liquid fuel shall not exceed 336 hours per calendar year, excluding equipment testing which shall not exceed 48 hours per year. [District Rule 4305], [Federally Enforceable Through Title V]
- 22. The owner of any unit operated under the exemption of natural gas curtailment shall monitor and record for each unit the cumulative annual hours of operation on each liquid fuel during curtailment and testing. [District Rule 4305], [Federally Enforceable Through Title V]
- 23. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 24. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 25. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 26. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 27. Source testing shall be performed using EPA Method 5 while firing on residual oil (including crude or topped crude) to demonstrate compliance with PM emission limits. Source testing shall be performed within 60 days of firing on residual oil unless such testing has been performed within the 12 month period prior to firing on said oil and the test results showed compliance with PM emission limits of this permit. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 28. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or on diesel fuel not exceeding 0.5% sulfur by weight; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 29. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. If the unit is fired on noncertified liquid fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the liquid fuel being fired in the unit shall be determined using ASTM D 2880. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 33. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 240 or D 2382 for liquid hydrocarbon fuels; ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]

- 34. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas or diesel fuel not exceeding 0.5% sulfur by weight; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels or 3.0% by weight for residual oil (including crude or topped crude); or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)], [Federally Enforceable Through Title V]
- 35. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. Units allowed to utilize the averaging option are listed in PTO S-1372-1. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 36. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. For residual oil (including crude and topped crude) fired units, compliance may be demonstrated through supplier certification of nitrogen content and heating value or by weekly fuel testing for nitrogen content and heating value. Hourly emissions shall be calculated using the heating value, maximum rated unit capacity, and the following formula: lb NO2/1000 gal = 20.54 + 104.39 (N), where N is the weight % nitrogen in the fuel. If compliance with the NOx emission limit is demonstrated through the fuel nitrogen content testing and compliance has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be bi-annually. If a bi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 37. If the unit is fired on noncertified residual oil (including crude and topped crude) and compliance with NOx emission limits is achieved through fuel nitrogen content testing, then the nitrogen content of the fuel being fired in the unit shall be determined using ASTM D3431. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 38. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 40. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 41. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 42. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 43. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 44. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2 and 4351, 6.3], [Federally Enforceable Through Title V]
- 45. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 46. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]

47.	All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall be fired on
	the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil)
	then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year
	of the switch. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]

48.	The number of representative units source tested to demonstrate compliance for NOx limits shall be at least 30% of the total number of units
	in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once
	[District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-19-19 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR OIL/NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (#29 DIS# 45004-80) WITH O2 CONTROLLER AND FLUE GAS RECIRCULATION (FGR).

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. No less than 0.35 miles of roadway shall be paved and maintained in good repair. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Noncondensible vapors from TEOR operation, permit # S-1372-77, may be incinerated in this steam generator. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Gas-fired emission rates shall not exceed the following: NOx 30 ppmv and CO 400 ppmv calculated to 3.00% O2 by volume stack gas oxygen and averaged over 60 minutes. [District Rule 4305], [Federally Enforceable Through Title V]
- 5. Gas-fired emissions shall not exceed any of the following: PM10: 0.064 lb/MMbtu; or VOC: 0.006 lb/MMbtu. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. SOx (as SO2) emissions shall not exceed 95.54 lb/day except as provided below in conditions 7 and 8. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Total casing gas sulfur oxide (SOx as SO2) emissions shall not exceed 1578.08 lb/day for the following steam generators: S-1372-8 (#10), S-1372-17 (#19); S-1372-18 (#28), S-1372-19 (#29), and S-1372-20 (#30). [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Steam generators S-1372-10, -14, -30, -31, -32, -33, -34, and -318 shall be fired exclusively on utility grade natural gas when this steam generator is gas-fired and incinerating TEOR vapors. [District NSR Rule], [Federally Enforceable Through Title V]
- 9. Sulfur compound (SO2) emission limit compliance shall be demonstrated by fuel gas sulfur analysis performed 60 days prior to permit anniversary date. [District Rule 1081], [Federally Enforceable Through Title V]
- 10. Compliance with casing gas sulfur compound emission limits shall be demonstrated by record keeping of TEOR gas flowrate and H2S concentration. [District Rule 1070], [Federally Enforceable Through Title V]
- 11. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305], [Federally Enforceable Through Title V]
- 12. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 13. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305], [Federally Enforceable Through Title V]
- 14. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 17. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, and 4305], [Federally Enforceable Through Title V]

- 18. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 19. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 20. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 21. During natural gas curtailment, total cumulative hours of operation for burning liquid fuel shall not exceed 336 hours per calendar year, excluding equipment testing which shall not exceed 48 hours per year. [District Rule 4305], [Federally Enforceable Through Title V]
- 22. The owner of any unit operated under the exemption of natural gas curtailment shall monitor and record for each unit the cumulative annual hours of operation on each liquid fuel during curtailment and testing. [District Rule 4305], [Federally Enforceable Through Title V]
- 23. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 24. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 25. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 26. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 27. Source testing shall be performed using EPA Method 5 while firing on residual oil (including crude or topped crude) to demonstrate compliance with PM emission limits. Source testing shall be performed within 60 days of firing on residual oil unless such testing has been performed within the 12 month period prior to firing on said oil and the test results showed compliance with PM emission limits of this permit. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 28. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or on diesel fuel not exceeding 0.5% sulfur by weight; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 29. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. If the unit is fired on noncertified liquid fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the liquid fuel being fired in the unit shall be determined using ASTM D 2880. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 33. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 240 or D 2382 for liquid hydrocarbon fuels; ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]

- 34. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas or diesel fuel not exceeding 0.5% sulfur by weight; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels or 3.0% by weight for residual oil (including crude or topped crude); or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)], [Federally Enforceable Through Title V]
- 35. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. Units allowed to utilize the averaging option are listed in PTO S-1372-1. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 36. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. For residual oil (including crude and topped crude) fired units, compliance may be demonstrated through supplier certification of nitrogen content and heating value or by weekly fuel testing for nitrogen content and heating value. Hourly emissions shall be calculated using the heating value, maximum rated unit capacity, and the following formula: lb NO2/1000 gal = 20.54 + 104.39 (N), where N is the weight % nitrogen in the fuel. If compliance with the NOx emission limit is demonstrated through the fuel nitrogen content testing and compliance has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be bi-annually. If a bi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 37. If the unit is fired on noncertified residual oil (including crude and topped crude) and compliance with NOx emission limits is achieved through fuel nitrogen content testing, then the nitrogen content of the fuel being fired in the unit shall be determined using ASTM D3431. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 38. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 40. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 41. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 42. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 43. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 44. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2 and 4351, 6.3], [Federally Enforceable Through Title V]
- 45. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 46. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]

47.	All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall be fired on
	the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil)
	then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year
	of the switch. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]

48.	The number of representative units source tested to demonstrate compliance for NOx limits shall be at least 30% of the total number of units
	in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once
	[District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-20-19 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR OIL/NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (#30 DIS# 45005-80) WITH O2 CONTROLLER AND FGR.

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. No less than 0.35 miles of roadway shall be paved and maintained in good repair. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Noncondensible vapors from TEOR operation, permit # S-1372-77, may be incinerated in this steam generator. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Gas-fired emission rates shall not exceed the following: NOx 30 ppmv and CO 400 ppmv calculated to 3.00% O2 by volume stack gas oxygen and averaged over 60 minutes. [District Rule 4305], [Federally Enforceable Through Title V]
- 5. Gas-fired emissions shall not exceed any of the following: PM10: 0.064 lb/MMbtu; or VOC: 0.006 lb/MMbtu. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. SOx (as SO2) emissions shall not exceed 95.54 lb/day except as provided below in conditions 7 and 8. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Total casing gas sulfur oxide (SOx as SO2) emissions shall not exceed 1578.08 lb/day for the following steam generators: S-1372-8 (#10), S-1372-17 (#19); S-1372-18 (#28), S-1372-19 (#29), and S-1372-20 (#30). [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Steam generators S-1372-10, -14, -30, -31, -32, -33, -34, and -318 shall be fired exclusively on utility grade natural gas when this steam generator is gas-fired and incinerating TEOR vapors. [District NSR Rule], [Federally Enforceable Through Title V]
- 9. Sulfur compound (SO2) emission limit compliance shall be demonstrated by fuel gas sulfur analysis performed 60 days prior to permit anniversary date. [District Rule 1081], [Federally Enforceable Through Title V]
- 10. Compliance with casing gas sulfur compound emission limits shall be demonstrated by record keeping of TEOR gas flowrate and H2S concentration. [District Rule 1070], [Federally Enforceable Through Title V]
- 11. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305], [Federally Enforceable Through Title V]
- 12. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 13. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305], [Federally Enforceable Through Title V]
- 14. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 17. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, and 4305], [Federally Enforceable Through Title V]

- 18. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 19. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 20. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 21. During natural gas curtailment, total cumulative hours of operation for burning liquid fuel shall not exceed 336 hours per calendar year, excluding equipment testing which shall not exceed 48 hours per year. [District Rule 4305], [Federally Enforceable Through Title V]
- 22. The owner of any unit operated under the exemption of natural gas curtailment shall monitor and record for each unit the cumulative annual hours of operation on each liquid fuel during curtailment and testing. [District Rule 4305], [Federally Enforceable Through Title V]
- 23. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 24. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 25. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 26. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 27. Source testing shall be performed using EPA Method 5 while firing on residual oil (including crude or topped crude) to demonstrate compliance with PM emission limits. Source testing shall be performed within 60 days of firing on residual oil unless such testing has been performed within the 12 month period prior to firing on said oil and the test results showed compliance with PM emission limits of this permit. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 28. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or on diesel fuel not exceeding 0.5% sulfur by weight; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 29. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. If the unit is fired on noncertified liquid fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the liquid fuel being fired in the unit shall be determined using ASTM D 2880. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 33. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 240 or D 2382 for liquid hydrocarbon fuels; ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]

- 34. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas or diesel fuel not exceeding 0.5% sulfur by weight; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels or 3.0% by weight for residual oil (including crude or topped crude); or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)], [Federally Enforceable Through Title V]
- 35. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. Units allowed to utilize the averaging option are listed in PTO S-1372-1. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 36. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. For residual oil (including crude and topped crude) fired units, compliance may be demonstrated through supplier certification of nitrogen content and heating value or by weekly fuel testing for nitrogen content and heating value. Hourly emissions shall be calculated using the heating value, maximum rated unit capacity, and the following formula: lb NO2/1000 gal = 20.54 + 104.39 (N), where N is the weight % nitrogen in the fuel. If compliance with the NOx emission limit is demonstrated through the fuel nitrogen content testing and compliance has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be bi-annually. If a bi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 37. If the unit is fired on noncertified residual oil (including crude and topped crude) and compliance with NOx emission limits is achieved through fuel nitrogen content testing, then the nitrogen content of the fuel being fired in the unit shall be determined using ASTM D3431. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 38. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 40. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 41. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 42. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 43. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 44. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2 and 4351, 6.3], [Federally Enforceable Through Title V]
- 45. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 46. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]

- 47. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 48. The number of representative units source tested to demonstrate compliance for NOx limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-21-5 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

32 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR #31 ALSO APPROVED AT LOCATIONS SEC 36, T29S, R21E; SEC 06, T30S, R22E; SEC 10, T31S, R22E. (RULE 4305, GROUP II UNIT)

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
- 3. All wells producing from strata steamed by this unit shall be connected to a District-approved emissions control system, have District-approved closed casing vents or be District-approved uncontrolled cyclic wells. [District Rule 4401]
- 4. Only PUC regulated quality natural gas shall be burned. [District Rule 2201]
- 5. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District Rule 2201]
- 6. Emissions shall not exceed PM10: 0.10 lbm/hr, SOx (as SO2): 0.02 lbm/hr, VOC: 0.09 lbm/hr, CO: 1.12 lbm/hr. [District Rule 2201]
- 7. Emission rate for Nitrogen Oxides shall not exceed 0.16 lb/MMBtu. [District Rule 2201]
- 8. The steam generator shall not exceed 80% throttle and 80% use. [District Rule 2201]
- District shall be notified in writing at least 7 days prior to each transfer between District approved location, giving the exact location of the move. [District Rule 2201]
- 10. No emission reduction credit shall be granted for this steam generator until it is removed from the approved 4405 alternate emission limit plan. [District Rule 2201 and 4401]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-23-15 EXPIRATION DATE: 05/31/2007

EQUIPMENT DECRIPTION:

30 MMBTU/HR TEOR GAS/NATURAL GAS FIRED STEAM GENERATOR (#32 DIS# 44510-76) WITH O2 CONTROLLER. (RULE 4305, GROUP II UNIT)

- 1. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
- 2. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District Rule 2201]
- Compliance with casing gas sulfur compound emission limits shall be demonstrated by record keeping of casing gas flowrate and H2S
 concentration. [District Rule 1070]
- 4. Emissions shall not exceed any of the following: PM10: 0.014 lb/MMBtu; NOx (as NO2): 0.10 lb/MMBtu; VOC: 0.00125 lb/MMBtu; or CO: 31 ppmv @ 3% O2. [District Rule 2201]
- 5. SOx (as SO2) emissions shall not exceed 274.56 lb/day except as provided below in condition #6. [District Rule 2201]
- 6. Steam generators S-1372-10, -14, -23, -30, -31, -32, -33, -34, and -318 shall be fired exclusively on utility grade natural gas when steam generators S-1372-8, 17, 18, 19, 20 are incinerating TEOR vapors. [District Rule 2201]
- 7. No emission reduction credit shall be granted for this steam generator until it is removed from the approved 4405 alternate emission limit plan. [District Rule 4405]
- 8. Records required by this permit shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District NSR Rule]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-24-18 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (#20 DIS# 45220-81) WITH O2 CONTROLLER AND FGR.

- 1. When located at NW section 10, T29S, R21E, this unit shall be fired on natural gas. The SO2 scrubber is not required at this location. [District Rule 2080], [Federally Enforceable Through Title V]
- 2. All wells producing from strata steamed by this unit shall be connected to a District-approved emissions control system, have District-approved closed casing vents or be District-approved uncontrolled cyclic wells. [District Rule 4401], [Federally Enforceable Through Title V]
- 3. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. No less than 0.4 miles of roadway shall be paved and maintained in good repair. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Emissions shall not exceed PM10: 0.014 lb/MMbtu; SOx (as SO2): 123.4 lb/day; NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2; VOC: 0.0004 lb/MMBtu; or CO: 400 ppmv @ 3% O2. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Compliance with gas fired sulfur compound (SO2) emission limit shall be determined by fuel gas sulfur analysis performed 60 days prior to permit anniversary date. [District Rule 1070], [Federally Enforceable Through Title V]
- 7. Source testing to measure NOx and CO emissions shall be conducted within 60 days of startup, and not less than once every 12 months thereafter, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 8. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 9. If permittee fails any compliance demonstration for NOx and CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 10. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305], [Federally Enforceable Through Title V]
- 11. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 12. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 13. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081 and 4305], [Federally Enforceable Through Title V]
- 14. Compliance with casing gas sulfur compound emission limits shall be demonstrated by record keeping of casing gas flowrate and H2S concentration. [District NSR Rule], [Federally Enforceable Through Title V]
- 15. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 16. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]

- 17. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 18. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 19. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 forty-minute test runs for NOx and CO. This mean shall be multiplied by the appropriate factor. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 20. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 21. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 22. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 23. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 24. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 25. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 27. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 28. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 29. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)], [Federally Enforceable Through Title V]
- 30. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. Units allowed to utilize the averaging option are listed in PTO S-1372-1. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]

- 32. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 33. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 34. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 35. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 36. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2 and 4351, 6.3], [Federally Enforceable Through Title V]
- 37. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 38. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 39. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 40. The number of representative units source tested to demonstrate compliance for NOx limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-26-8 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

32 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (#22 DIS# 45222-80) WITH FGR

- 1. All wells producing from strata steamed by this unit shall be connected to a District-approved emissions control system, have District-approved closed casing vents or be District-approved uncontrolled cyclic wells. [District Rule 4401], [Federally Enforceable Through Title V]
- 2. Steam generator firebox convection section, scrubber bypass valve, and all flue gas ductwork shall be maintained with no detectable leaks. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Natural gas fuel shall be of PUC regulated quality. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Noncondensible vapors from TEOR operation S-1372-99 shall be incinerated in this steam generator. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Burner shall be equipped with operational TEOR gas volume flowmeter. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Emission rates shall not exceed any of the following: PM10: 0.7 lb/day, SOx: 61.4 lb/day, NOx: 122.9 lb/day, VOC: 2.1 lb/day, or CO: 26.9 lb/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Gas fired emission rates shall not exceed the following: NOx 0.036 lb/MMBtu or 30 ppmv and CO 400 ppmv calculated to 3.00% O2 by volume stack gas oxygen and averaged over 60 minutes. [District Rule 4305], [Federally Enforceable Through Title V]
- 8. Source testing to measure Rule 4305 NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 9. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 10. If permittee fails any compliance demonstration for NOx and CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 11. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 12. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 14. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, and stack gas oxygen EPA Method 3 or 3A or ARB Method 100. [District Rule 1081 & Rule 4305], [Federally Enforceable Through Title V]
- 15. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 16. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 17. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]

- 18. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 19. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 20. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 21. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 22. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 23. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 24. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 25. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 27. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 28. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 29. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and 407 (Kern)], [Federally Enforceable Through Title V]
- 30. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. Units allowed to utilize the averaging option are listed in PTO S-1372-1. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 33. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rule 108.1 (Kern) and 404 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

34.	This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity
	for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this
	source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

35. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-29-17 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

30.0 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR #23 (DIS #45223-80) WITH FGR AND O2 CONTROLLER (RULE 4305, GROUP II).

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. This equipment is approved to be operated at the following locations: Section 8, T30S/R22E; and SE/4 Section 10, T31S/R22E. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. No less than 0.179 miles of roadway shall be paved and maintained in good repair. [District NSR Rule]
- 5. Sulfur content of natural gas shall not exceed 0.35 gr S/ 100 dscf. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Sulfur content of natural gas shall be demonstrated at least quarterly by detection tube sampling or other District approved methods. [District Rule 1081], [Federally Enforceable Through Title V]
- 7. Emission rates shall not exceed any of the following; PM10: 0.007 lb/MMBtu; SOx (as SO2): 0.001 lb/MMBtu; NOx (as NO2): 30 ppmv @ 3% O2 or 0.036 lb/MMBtu; VOC: 0.003 lb/MMBtu; or CO: 111 ppmv @ 3% O2 or 0.082 lb/MMBtu. [District NSR Rule, District Rule 4305], [Federally Enforceable Through Title V]
- 8. No emission reduction credit shall be granted for this steam generator until it is removed from the approved 4405 alternate emission limit plan. [District Rule 4405], [Federally Enforceable Through Title V]
- 9. The permittee shall use flue gas recirculation (FGR) when the steam generator is in operation. [District Rule 4305], [Federally Enforceable Through Title V]
- 10. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. In-stack O2 monitors are acceptable for O2 measurement. [District Rule 4305], [Federally Enforceable Through Title V]
- 11. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall notify the District and return the NOx and CO concentrations to the allowable emissions rate as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate after one hour, the permittee shall conduct an emissions test within 60 days, utilizing District approved test methods, to determine compliance with the applicable emissions limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 12. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within an acceptable range. These records shall be retained at the facility for a period of no less than five years and shall be made available for District inspection upon request. [District Rules 4305], [Federally Enforceable Through Title V]
- 13. Exhaust stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 1081], [Federally Enforceable Through Title V]
- 14. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 15. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 16. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]

- 17. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 18. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 19. Compliance source testing shall be conducted under conditions representative of normal operation. [District Rule 1081], [Federally Enforceable Through Title V]
- 20. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, and stack gas oxygen EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4305], [Federally Enforceable Through Title V]
- 21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 22. Permittee shall maintain records of volume of fuel gas burned and fuel gas sulfur content. Such records shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 1070], [Federally Enforceable Through Title V]
- 23. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 24. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 25. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 26. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 27. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 28. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 29. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 30. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 33. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]

- 34. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)], [Federally Enforceable Through Title V]
- 35. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 36. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 37. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 38. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 39. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 40. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-30-18 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR NATURAL GAS/CASING GAS FIRED STEAM GENERATOR (#33; DIS# 45233-82) WITH O2 CONTROLLER, LOW-NOX BURNER, AND FLUE GAS RECIRCULATION (FGR).

- 1. This equipment is approved to be operated at the following locations: Section 16, T31S/R22E; and NW/4 Section 06, T30S/R22E. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. No less than 0.5 miles of roadway shall be paved and maintained in good repair. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Emissions shall not exceed any of the following: PM10: 0.014 lb/MMbtu; NOx (as NO2): 0.036 lb/MMBtu or 30 ppmvd @ 3.00% O2; VOC: 0.003 lb/MMBtu; or CO: 400 ppmvd @ 3.00% O2. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. SOx (as SO2) emissions shall not exceed 97.9 lb/day except as provided below in condition #7. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Steam generators S-1372-10, -14, -30, -31, -32, -33, -34, and -318 shall be fired exclusively on utility grade natural gas when steam generators S-1372-8, 17, 18, 19, 20 are incinerating TEOR vapors. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Compliance with gas fired sulfur compound (SO2) emission limit shall be determined by fuel gas sulfur analysis performed 60 days prior to permit anniversary date. [District Rule 1070], [Federally Enforceable Through Title V]
- 9. Source testing to measure NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 10. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 11. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 12. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305], [Federally Enforceable Through Title V]
- 13. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 14. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 15. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 16. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081 and 4305], [Federally Enforceable Through Title V]
- 17. Compliance with casing gas sulfur compound emission limits shall be demonstrated by record keeping of casing gas flowrate and H2S concentration. [District NSR Rule], [Federally Enforceable Through Title V]

- 18. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 19. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 20. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 21. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 22. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 23. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 24. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 25. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 26. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 27. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 28. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 32. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)], [Federally Enforceable Through Title V]
- 33. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

- 34. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 35. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 36. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 37. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 38. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 39. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2 and 4351, 6.3], [Federally Enforceable Through Title V]
- 40. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 41. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 42. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 43. The number of representative units source tested to demonstrate compliance for NOx limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-31-16 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR NATURAL GAS/CASING GAS FIRED STEAM GENERATOR (#34 DIS# 45234-82) WITH O2 CONTROLLER AND LOW-NOX BURNER.

- 1. This equipment is approved to be operated at the following locations: Section 16, T31S/R22E; and NW/4 Section 06, T30S/R22E. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. No less than 0.5 miles of roadway shall be paved and maintained in good repair. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Emissions shall not exceed any of the following: PM10: 0.014 lb/MMbtu; NOx (as NO2): 0.036 lb/MMBtu or 30 ppmvd @ 3.00% O2; VOC: 0.003 lb/MMBtu; or CO: 400 ppmvd @ 3.00% O2. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. SOx (as SO2) emissions shall not exceed 97.9 lb/day except as provided below in condition #7. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Steam generators S-1372-10, -14, -30, -31, -32, -33, -34, and -318 shall be fired exclusively on utility grade natural gas when steam generators S-1372-8, 17, 18, 19, 20 are incinerating TEOR vapors. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Compliance with gas fired sulfur compound (SO2) emission limit shall be determined by fuel gas sulfur analysis performed 60 days prior to permit anniversary date. [District Rule 1070], [Federally Enforceable Through Title V]
- 9. Source testing to measure NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 10. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 11. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 12. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305], [Federally Enforceable Through Title V]
- 13. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 14. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 15. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 16. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081 and 4305], [Federally Enforceable Through Title V]
- 17. Compliance with casing gas sulfur compound emission limits shall be demonstrated by record keeping of casing gas flowrate and H2S concentration. [District NSR Rule], [Federally Enforceable Through Title V]

- 18. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 19. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 20. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 21. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 22. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 23. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 24. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 25. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 26. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 27. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 28. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 32. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)], [Federally Enforceable Through Title V]
- 33. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

- 34. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 35. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 36. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 37. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 38. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 39. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2 and 4351, 6.3], [Federally Enforceable Through Title V]
- 40. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 41. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 42. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 43. The number of representative units source tested to demonstrate compliance for NOx limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-32-16 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR NATURAL GAS/CASING GAS FIRED STEAM GENERATOR (#35; DIS# 45235-82) WITH O2 CONTROLLER, FGR, AND LOW-NOX BURNER.

- 1. This permit unit is authorized to operate at the following locations: Section 16, T31S, R22E (Bremer Fee Lease) and NW/4 Section 6, T30S, R22E (McKittrick Front Lease). [District NSR Rule], [Federally Enforceable Through Title V]
- 2. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. No less than 0.5 miles of roadway shall be paved and maintained in good repair. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Emissions shall not exceed any of the following: PM10: 0.014 lb/MMbtu; NOx (as NO2): 0.036 lb/MMBtu or 30 ppmvd @ 3.00% O2; VOC: 0.003 lb/MMBtu; or CO: 400 ppmvd @ 3.00% O2. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. SOx (as SO2) emissions shall not exceed 97.9 lb/day except as provided below in condition #7. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Steam generators S-1372-10, -14, -30, -31, -32, -33, -34, and -318 shall be fired exclusively on utility grade natural gas when steam generators S-1372-8, 17, 18, 19, 20 are incinerating TEOR vapors. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Compliance with gas fired sulfur compound (SO2) emission limit shall be determined by fuel gas sulfur analysis performed 60 days prior to permit anniversary date. [District Rule 1070], [Federally Enforceable Through Title V]
- 9. Source testing to measure NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 10. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 11. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 12. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305], [Federally Enforceable Through Title V]
- 13. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 14. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 15. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 16. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081 and 4305], [Federally Enforceable Through Title V]
- 17. Compliance with casing gas sulfur compound emission limits shall be demonstrated by record keeping of casing gas flowrate and H2S concentration. [District NSR Rule], [Federally Enforceable Through Title V]

- 18. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 19. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 20. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 21. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 22. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 23. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 24. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 25. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 26. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 27. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 28. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 32. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)], [Federally Enforceable Through Title V]
- 33. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

- 34. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 35. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 36. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 37. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 38. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 39. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2 and 4351, 6.3], [Federally Enforceable Through Title V]
- 40. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 41. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 42. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 43. The number of representative units source tested to demonstrate compliance for NOx limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-33-15 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR NATURAL GAS/CASING GAS FIRED STEAM GENERATOR (#36; DIS# 45236-82) WITH O2 CONTROLLER AND LOW-NOX BURNER APPROVED TO OPERATE AT VARIOUS SPECIFIED LOCATIONS

- 1. This permit unit is authorized to operate at the following locations: NW/4 Section 16, T31S, R22E (Bremer Fee Lease) and SW/4 Section 06, T30S, R22E (McFront Lease). [District NSR Rule], [Federally Enforceable Through Title V]
- 2. When located at SW/4 Section 06, T30S, R22E (McFront Lease), this unit shall be fired on PUC quality natural gas only. [District Rule 2080], [Federally Enforceable Through Title V]
- 3. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. No less than 0.5 miles of roadway shall be paved and maintained in good repair. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Emissions shall not exceed any of the following: PM10: 0.014 lb/MMBtu; NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3 % O2; VOC: 0.003 lb/MMBtu; or CO: 400 ppmv @ 3% O2. [District NSR Rule & Rule 4305], [Federally Enforceable Through Title V]
- 7. When located at NW/4 Section 16, T31S, R22E, SOx (as SO2) emissions shall not exceed 97.9 lb/day except as provided below in condition #8. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Steam generators S-1372-10, -14, -30, -31, -32, -33, -34, and -318 shall be fired exclusively on utility grade natural gas when steam generators S-1372-8, 17, 18, 19, 20 are incinerating TEOR vapors. [District NSR Rule], [Federally Enforceable Through Title V]
- 9. When located at NW/4 Section 16, T31S, R22E, compliance with gas fired sulfur compound (SO2) emission limit shall be determined by fuel gas sulfur analysis performed 60 days prior to permit anniversary date. [District Rule 1070], [Federally Enforceable Through Title V]
- 10. Source testing to measure NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 11. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 12. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 13. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305], [Federally Enforceable Through Title V]
- 14. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 17. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305], [Federally Enforceable Through Title V]

- 18. When located at NW/4 Section 16, T31S, R22E, compliance with casing gas sulfur compound emission limits shall be demonstrated by record keeping of casing gas flowrate and H2S concentration. [District NSR Rule], [Federally Enforceable Through Title V]
- 19. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 20. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 21. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 22. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 23. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 24. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 25. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 27. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 28. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 29. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 33. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)], [Federally Enforceable Through Title V]

- 34. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 35. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 36. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 37. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 38. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 39. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 40. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2 and 4351, 6.3], [Federally Enforceable Through Title V]
- 41. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 42. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 43. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 44. The number of representative units source tested to demonstrate compliance for NOx limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-34-15 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR NATURAL GAS/CASING GAS FIRED STEAM GENERATOR (#37; DIS# 45237-82) WITH O2 CONTROLLER AND LOW-NOX BURNER.

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. No less than 0.5 miles of roadway shall be paved and maintained in good repair. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Emissions shall not exceed any of the following: PM10: 0.014 lb/MMBtu; NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2; VOC: 0.003 lb/MMBtu; or CO: 400 ppmv @ 3% O2. [District NSR Rule & Rule 4305], [Federally Enforceable Through Title V]
- 4. SOx (as SO2) emissions shall not exceed 97.9 lb/day except as provided below in condition #5. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Steam generators S-1372-10, -14, -30, -31, -32, -33, -34, and -318 shall be fired exclusively on utility grade natural gas when steam generators S-1372-8, 17, 18, 19, 20 are incinerating TEOR vapors. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Compliance with gas fired sulfur compound (SO2) emission limit shall be determined by fuel gas sulfur analysis performed 60 days prior to permit anniversary date. [District Rule 1070], [Federally Enforceable Through Title V]
- 7. Source testing to measure NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 8. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 9. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 10. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305], [Federally Enforceable Through Title V]
- 11. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 12. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 14. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081 and 4305], [Federally Enforceable Through Title V]
- 15. Compliance with casing gas sulfur compound emission limits shall be demonstrated by record keeping of casing gas flowrate and H2S concentration. [District NSR Rule], [Federally Enforceable Through Title V]
- 16. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 17. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]

- 18. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 19. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 20. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 21. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 22. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 23. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 24. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 25. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 26. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 27. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 28. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 30. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)], [Federally Enforceable Through Title V]
- 31. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 33. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

- 34. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 35. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 36. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 37. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2 and 4351, 6.3], [Federally Enforceable Through Title V]
- 38. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 39. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 40. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 41. The number of representative units source tested to demonstrate compliance for NOx limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-74-4 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

TEOR OPERATION INCLUDING 78 STEAM ENHANCED WELLS, WELL VENT VAPOR COLLECTION & CONTROL SYSTEM, 12.8 MMBTU/HR KALDAIR FLARE, SEPARATORS, HEAT EXCHANGER, & KNOCKOUT DRUM.

- 1. Final vapor condenser shall utilize exhaust gas temperature indicator. [District Rule 1070 and District NSR Rule], [Federally Enforceable Through Title V]
- 2. Mist eliminator shall be maintained in optimum operating condition. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Well vent vapors shall be combusted in Kaldair flare. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Pilots shall be exclusively fired with PUC quality natural gas. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. TEOR noncondensible gas sulfur content incinerated in flare shall not exceed 10,000 ppm (as SO2) by weight. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Pilot fuel gas flowrate shall not exceed 350 scf/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Emissions from the flare shall not exceed PM10: 0.01 lbm/hr, SOx (as SO2): 0.74 lbm/hr, NOx (as NO2): 0.24 lbm/hr, VOC: 0.00 lbm/hr. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Total fugitive volatile organic compounds (VOC) emission rate shall not exceed 5.1 lb/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 9. Permittee shall maintain with the permit a current listing of all steam enhanced wells connected to the casing vent control system and shall make such listing readily available for District inspection upon request. [District NSR Rule], [Federally Enforceable Through Title V]
- 10. Permittee shall keep accurate daily records of amount of pilot fuel gas and TEOR noncondensible gas introduced to flare for incineration and shall make such records readily available for District inspection upon request. [District Rule 1070 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 11. Permittee shall determine sulfur content of gases introduced into flare on weekly basis and shall make records of such determination readily available for District inspection upon request. [District Rule 1070 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 12. The following test method shall be used for fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. The flare shall be operated according to the manufacturer's specifications, a copy of which shall be maintained on site. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 14. The flare in this permit shall be inspected every two weeks while in operation for visible emissions. If visible emissions are observed, corrective action shall be taken. If visible emissions continue, an EPA method 9 test shall be conducted within 72 hours. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 15. The crude oil production from wells associated with this permit unit shall not lie within 1000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5], [Federally Enforceable Through Title V]
- 16. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1], [Federally Enforceable Through Title V]
- 17. All required source testing shall conform to the compliance testing procedures described in District Rule 1081(as amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 18. The operator shall maintain monitoring records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1], [Federally Enforceable Through Title V]

- 19. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 20. The uncontrolled VOC emissions from any well vent shall be reduced by at least 99 percent by weight or, if several steam-enhanced crude oil production well vents are connected to a vapor collection and control system, total uncontrolled VOC emissions shall be reduced by at least 99 percent. This requirement does not apply to cyclic wells located on contiguous and adjacent oil production properties with less than 10 cyclic wells owned by or under the control of a company. [District Rule 4401, 5.1 and 5.2], [Federally Enforceable Through Title V]
- 21. For cyclic wells located on properties with less than 10 cyclic wells and owned by a company, the uncontrolled VOC emissions from any well vent or system of well vents connected to a single vapor collection and control device shall be reduced by at least 50 percent.

 Properties shall include contiguous and adjacent oil production properties owned by or under control of the company. [District Rule 4401, 5.4], [Federally Enforceable Through Title V]
- 22. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3], [Federally Enforceable Through Title V]
- 23. Units consisting of more than 500 wells shall not exceed one leak detected for each 20 wells tested with a minimum of 50 wells tested. [District Rule 4401, 5.3], [Federally Enforceable Through Title V]
- 24. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1], [Federally Enforceable Through Title V]
- 25. Operator shall repair each leak within 15 calendar days of detection. The APCO may grant a 10 calendar day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1], [Federally Enforceable Through Title V]
- 26. Operator shall maintain all components of a well vent vapor collection and control system in good repair. Components of the well vent vapor collection and control system shall include all piping, valves, fittings, pumps, compressors, tanks, etc. used to collect, control, store, or dispose of VOC condensate or non-condensable VOCs and which is prior to any blending of VOC condensate with crude oil or blending of non-condensable VOCs with gases to be used as a fuel. [District Rule 4401, 5.3 and 5.3.2], [Federally Enforceable Through Title V]
- 27. Annual control efficiency compliance tests shall be performed on all vapor collection and control systems used to control emissions from steam-enhanced crude oil production wells. Testing shall be performed by source testers certified by the California Air Resources Board (CARB) during June, July, August or September of each year if the system's control efficiency is dependent upon ambient air temperature. The APCO may waive the annual testing requirements of this condition if the vapor control system does not exhaust to atmosphere or if all uncondensed VOC emissions collected by a vapor collection and control system are incinerated in fuel burning equipment, an internal combustion engine or in a smokeless open flare, and the source's Operating Permit contains adequate periodic monitoring to ensure the source meets 99% control efficiency. [District Rule 4401, 5.1, 5.2 and 6.2.1], [Federally Enforceable Through Title V]
- 28. The control efficiency of the vapor collection and control system used to control VOC emissions from steam enhanced crude oil production well shall be determined by mass balance based on most stringent of a source test, USEPA approved emission factors, or Air Pollution (AP)-42 emission factors for components and number of components; and the efficiency of destruction devices determined by USEPA Method 25, 25a, or 25b as applicable. [District Rule 4401, 6.3.1], [Federally Enforceable Through Title V]
- 29. VOC content shall be determined using the latest revision of ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by CARB Method 432. [District Rule 4401, 6.3.2], [Federally Enforceable Through Title V]
- 30. The source shall perform leak inspections at least annually, using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.4.2 and 4401, 6.3.3], [Federally Enforceable Through Title V]
- 31. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following requirements: County Rule 108.1 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 32. Compliance with permit conditions in the Title V permit shall be deemed in compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 33. The requirements of SJVUAPCD Rule 4407 (Adopted 5/19/94) and SJVUAPCD Rule 4801 (Adopted 12/17/92) do not apply to the well vents. For Rule 4801 applicability, well vent emissions are fugitive emissions not considered to come from a point source. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-75-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WELL VENT VAPOR COLLECTION SYSTEM SERVING 30 STEAM DRIVE WELLS AND 10 CYCLIC WELLS

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. Sulfur compound emissions shall not exceed 2000 ppmv as SO2. [District Rule 4801]
- 3. Total uncontrolled VOC emissions from all well vents shall be reduced by at least 99%. [District Rule 4401]
- 4. The operation shall include one air cooled heat exchanger, one gas liquid separator, one condensate holding tank, and vapor collection piping network. []
- 5. Final vapor condenser shall utilize exhaust gas temperature indicator. []
- 6. Condensate shall be disposed of in a manner preventing VOC emissions to the atmosphere. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-76-12 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

TEOR OPERATION INCL. 262 STEAM ENHANCED WELLS, WELL VENT VAPOR COLLECTION SYSTEM, STANDBY FLARE, HEAT EXCHANGERS, SEPARATORS, COMPRESSORS, TANKS, & VAPOR PIPING TO UNITS S-1372-13, '-16, & '-24 (DOME/TUMBADOS LEASE)

- 1. Leaks shall be inspected and repaired as specified in Rule 4401. [District Rule 4401], [Federally Enforceable Through Title V]
- 2. Operation shall include 20' tall standby flare, vapor piping to standby flare, vapor piping to 3 DOGGR (Division of Oil and Gas and Geothermal Resources) approved disposal wells, and vapor piping to District approved TEOR steam generators S-1372-13, -16, & -24 for incineration. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Operation shall include sulfa check system, to be used when necessary to meet sulfur compounds limits of standby flare and steam generators S-1372-13, -16, & -24. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. TEOR vapors shall be disposed of in DOGGR approved disposal wells and/or shall be incinerated as allowed by conditions 5 and 6. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Standby flare shall be used to incinerate TEOR vapors only when at least one of three steam generators S-1372-13, -16 & -24 is inoperative and remaining steam generators are fired on PUC quality natural gas, or as allowed by condition #4. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. TEOR vapors shall be equally distributed to standby flare and steam generators S-1372-13, -16, & -24 when one or more of the steam generators is inoperative. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Total casing gas sulfur oxide (SOx as SO2) emissions shall not exceed 1193.52 lb/day for the following steam generators and standby flare: S-1372-13 (#16), S-1372-16 (#12), S-1372-24 (#20), and S-1372-76. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Total fugitive volatile organic compounds (VOC) emission rate shall not exceed 117.8 lb/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 9. Final vapor condenser shall be equipped with operational exhaust gas temperature indicator. [District Rule 1070 and District NSR Rule], [Federally Enforceable Through Title V]
- 10. Mist eliminator shall be maintained and operated according to manufacturer's recommendation. [District NSR Rule], [Federally Enforceable Through Title V]
- 11. Standby flare shall be designed for smokeless operation, with no visible emissions in excess of 5% opacity. [District NSR Rule], [Federally Enforceable Through Title V]
- 12. Permittee shall maintain accurate records of well casing vapor H2S concentration (periodic sampling of no less than once per quarter), daily volume of casing vapor incinerated, and calculated daily SO2 emissions. [District Rule 1070 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. Permittee shall maintain with the permit a copy of DOGGR approval, and a current listing of all steam enhanced wells connected to the casing vent control system and shall make such listing readily available for District inspection upon request. [District Rule 1070 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 14. The following test method shall be used for fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- The flare shall be operated according to the manufacturer's specifications, a copy of which shall be maintained on site. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 16. The flare in this permit shall be inspected every two weeks while in operation for visible emissions. If visible emissions are observed, corrective action shall be taken. If visible emissions continue, an EPA method 9 test shall be conducted within 72 hours. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 17. The crude oil production from wells associated with this permit unit shall not lie within 1000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5], [Federally Enforceable Through Title V]

- 18. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1], [Federally Enforceable Through Title V]
- 19. All required source testing shall conform to the compliance testing procedures described in District Rule 1081(as amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 20. The operator shall maintain monitoring records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1], [Federally Enforceable Through Title V]
- 21. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 22. The uncontrolled VOC emissions from any well vent shall be reduced by at least 99 percent by weight or, if several steam-enhanced crude oil production well vents are connected to a vapor collection and control system, total uncontrolled VOC emissions shall be reduced by at least 99 percent. This requirement does not apply to cyclic wells located on contiguous and adjacent oil production properties with less than 10 cyclic wells owned by or under the control of a company. [District Rule 4401, 5.1 and 5.2], [Federally Enforceable Through Title V]
- 23. For cyclic wells located on properties with less than 10 cyclic wells and owned by a company, the uncontrolled VOC emissions from any well vent or system of well vents connected to a single vapor collection and control device shall be reduced by at least 50 percent.

 Properties shall include contiguous and adjacent oil production properties owned by or under control of the company. [District Rule 4401, 5.4], [Federally Enforceable Through Title V]
- 24. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3], [Federally Enforceable Through Title V]
- 25. Units consisting of more than 500 wells shall not exceed one leak detected for each 20 wells tested with a minimum of 50 wells tested. [District Rule 4401, 5.3], [Federally Enforceable Through Title V]
- 26. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1], [Federally Enforceable Through Title V]
- 27. Operator shall repair each leak within 15 calendar days of detection. The APCO may grant a 10 calendar day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1], [Federally Enforceable Through Title V]
- 28. Operator shall maintain all components of a well vent vapor collection and control system in good repair. Components of the well vent vapor collection and control system shall include all piping, valves, fittings, pumps, compressors, tanks, etc. used to collect, control, store, or dispose of VOC condensate or non-condensable VOCs and which is prior to any blending of VOC condensate with crude oil or blending of non-condensable VOCs with gases to be used as a fuel. [District Rule 4401, 5.3 and 5.3.2], [Federally Enforceable Through Title V]
- 29. Annual control efficiency compliance tests shall be performed on all vapor collection and control systems used to control emissions from steam-enhanced crude oil production wells. Testing shall be performed by source testers certified by the California Air Resources Board (CARB) during June, July, August or September of each year if the system's control efficiency is dependent upon ambient air temperature. The APCO may waive the annual testing requirements of this condition if the vapor control system does not exhaust to atmosphere or if all uncondensed VOC emissions collected by a vapor collection and control system are incinerated in fuel burning equipment, an internal combustion engine or in a smokeless open flare, and the source's Operating Permit contains adequate periodic monitoring to ensure the source meets 99% control efficiency. [District Rule 4401, 5.1, 5.2 and 6.2.1], [Federally Enforceable Through Title V]
- 30. The control efficiency of the vapor collection and control system used to control VOC emissions from steam enhanced crude oil production well shall be determined by mass balance based on most stringent of a source test, USEPA approved emission factors, or Air Pollution (AP)-42 emission factors for components and number of components; and the efficiency of destruction devices determined by USEPA Method 25, 25a, or 25b as applicable. [District Rule 4401, 6.3.1], [Federally Enforceable Through Title V]
- 31. VOC content shall be determined using the latest revision of ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by CARB Method 432. [District Rule 4401, 6.3.2], [Federally Enforceable Through Title V]
- 32. The source shall perform leak inspections at least annually, using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.4.2 and 4401, 6.3.3], [Federally Enforceable Through Title V]
- 33. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following requirements: County Rule 108.1 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 34. Compliance with permit conditions in the Title V permit shall be deemed in compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

35.	The requirements of SJVUAPCD Rule 4407 (Adopted 5/19/94) and SJVUAPCD Rule 4801 (Adopted 12/17/92) do not apply to the well vents. For Rule 4801 applicability, well vent emissions are fugitive emissions not considered to come from a point source. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
	NUEVO ENEDOV COMPANY S 1272 76 12

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-77-12 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

THERMALLY ENHANCED OIL RECOVERY OPERATION WELL VENT VAPOR COLLECTION SYSTEM WITH 314 STEAM DRIVE WELLS, HEAT EXCHANGERS, GAS/LIQUID SEPARATORS, STORAGE VESSELS, COMPRESSORS, VAPOR PIPING TO STEAM GENERATORS, AND STANDBY FLARE (BREMER LEASE)

- 1. Leaks shall be inspected and repaired as specified in Rule 4401. [District Rule 4401], [Federally Enforceable Through Title V]
- 2. Operation shall include sulfa check system, to be used when necessary to meet sulfur compounds limits of TEOR steam generators S-1372-17, S-1372-18, S-1372-19, S-1372-20, and flare (S-1372-77). [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Exhaust duct to atmosphere or incineration device shall be equipped with temperature indicator. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Condensate storage vessels shall be equipped with mist eliminator positioned an adequate distance downstream of nearest flow obstruction. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Final vapor condenser shall be equipped with exhaust gas temperature indicator. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. When purchasing steam from Midway Sunset Cogeneration, an equivalent number of permittee's Bremer Lease generators shall be shutdown unless otherwise approved by the District. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Fugitive VOC emissions from vapor collection and control system shall not exceed 170.2 lb/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Noncondensible vapors from this well vent vapor control system shall be incinerated in steam generators S-1372-17, S-1372-18, S-1372-19, S-1372-20, or in flare (S-1372-77). [District NSR Rule], [Federally Enforceable Through Title V]
- 9. Standby flare shall be equipped with automatically lit pilot and waste gas shutoff upon flame failure. [District NSR Rule], [Federally Enforceable Through Title V]
- 10. Standby flare shall only be used to incinerate TEOR vapors when steam generator S-1372-17, S-1372-18, S-1372-19, or S-1372-20 are inoperable. [District NSR Rule], [Federally Enforceable Through Title V]
- 11. Sulfur oxide (SOx as SO2) emissions shall not exceed 80,950 lb/yr from the flare. [District NSR Rule], [Federally Enforceable Through Title V]
- 12. If vapor combustion sources are inoperative, well vent vapors shall not be vented to the atmosphere. [District NSR Rule], [Federally Enforceable Through Title V]
- 13. Permittee shall maintain accurate records of well casing vapor H2S concentration (periodic sampling of no less than once per quarter) and daily volume of casing vapor incinerated. [District Rule 1070], [Federally Enforceable Through Title V]
- 14. Permittee shall maintain with the permit a current listing of all steam enhanced wells connected to the casing vent control system and shall make such listing readily available for District inspection upon request. [District Rule 1070], [Federally Enforceable Through Title V]
- 15. The following test method shall be used for fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 16. The flare shall be operated according to the manufacturer's specifications, a copy of which shall be maintained on site. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 17. The flare in this permit shall be inspected every two weeks while in operation for visible emissions. If visible emissions are observed, corrective action shall be taken. If visible emissions continue, an EPA method 9 test shall be conducted within 72 hours. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 18. The crude oil production from wells associated with this permit unit shall not lie within 1000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5], [Federally Enforceable Through Title V]

- 19. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1], [Federally Enforceable Through Title V]
- 20. All required source testing shall conform to the compliance testing procedures described in District Rule 1081(as amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 21. The operator shall maintain monitoring records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1], [Federally Enforceable Through Title V]
- 22. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 23. The uncontrolled VOC emissions from any well vent shall be reduced by at least 99 percent by weight or, if several steam-enhanced crude oil production well vents are connected to a vapor collection and control system, total uncontrolled VOC emissions shall be reduced by at least 99 percent. This requirement does not apply to cyclic wells located on contiguous and adjacent oil production properties with less than 10 cyclic wells owned by or under the control of a company. [District Rule 4401, 5.1 and 5.2], [Federally Enforceable Through Title V]
- 24. For cyclic wells located on properties with less than 10 cyclic wells and owned by a company, the uncontrolled VOC emissions from any well vent or system of well vents connected to a single vapor collection and control device shall be reduced by at least 50 percent.

 Properties shall include contiguous and adjacent oil production properties owned by or under control of the company. [District Rule 4401, 5.4], [Federally Enforceable Through Title V]
- 25. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3], [Federally Enforceable Through Title V]
- 26. Units consisting of more than 500 wells shall not exceed one leak detected for each 20 wells tested with a minimum of 50 wells tested. [District Rule 4401, 5.3], [Federally Enforceable Through Title V]
- 27. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1], [Federally Enforceable Through Title V]
- 28. Operator shall repair each leak within 15 calendar days of detection. The APCO may grant a 10 calendar day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1], [Federally Enforceable Through Title V]
- 29. Operator shall maintain all components of a well vent vapor collection and control system in good repair. Components of the well vent vapor collection and control system shall include all piping, valves, fittings, pumps, compressors, tanks, etc. used to collect, control, store, or dispose of VOC condensate or non-condensable VOCs and which is prior to any blending of VOC condensate with crude oil or blending of non-condensable VOCs with gases to be used as a fuel. [District Rule 4401, 5.3 and 5.3.2], [Federally Enforceable Through Title V]
- 30. Annual control efficiency compliance tests shall be performed on all vapor collection and control systems used to control emissions from steam-enhanced crude oil production wells. Testing shall be performed by source testers certified by the California Air Resources Board (CARB) during June, July, August or September of each year if the system's control efficiency is dependent upon ambient air temperature. The APCO may waive the annual testing requirements of this condition if the vapor control system does not exhaust to atmosphere or if all uncondensed VOC emissions collected by a vapor collection and control system are incinerated in fuel burning equipment, an internal combustion engine or in a smokeless open flare, and the source's Operating Permit contains adequate periodic monitoring to ensure the source meets 99% control efficiency. [District Rule 4401, 5.1, 5.2 and 6.2.1], [Federally Enforceable Through Title V]
- 31. The control efficiency of the vapor collection and control system used to control VOC emissions from steam enhanced crude oil production well shall be determined by mass balance based on most stringent of a source test, USEPA approved emission factors, or Air Pollution (AP)-42 emission factors for components and number of components; and the efficiency of destruction devices determined by USEPA Method 25, 25a, or 25b as applicable. [District Rule 4401, 6.3.1], [Federally Enforceable Through Title V]
- 32. VOC content shall be determined using the latest revision of ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by CARB Method 432. [District Rule 4401, 6.3.2], [Federally Enforceable Through Title V]
- 33. The source shall perform leak inspections at least annually, using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.4.2 and 4401, 6.3.3], [Federally Enforceable Through Title V]
- 34. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following requirements: County Rule 108.1 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 35. Compliance with permit conditions in the Title V permit shall be deemed in compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

36.	The requirements of SJVUAPCD Rule 4407 (Adopted 5/19/94) and SJVUAPCD Rule 4801 (Adopted 12/17/92) do not apply to the well vents. For Rule 4801 applicability, well vent emissions are fugitive emissions not considered to come from a point source. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
	NUEVO ENERGY COMPANY S-1372-77-12

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-87-6 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

TEOR SYSTEM INCLUDING 208 STEAM ENHANCED WELLS, WELL COLLECTION PIPING, FLARE, NONCONDENSIBLE VAPOR PIPING TO FLARE, SULFA CHECK UNIT, HEAT EXCHANGERS, GAS/LIQUID SEPARATORS, STORAGE VESSELS, COMPRESSORS, LUBE OIL TANKS, AND PUMPS

- 1. Leaks shall be inspected and repaired as specified in Rule 4401. [District Rule 4401]
- Condensate shall be disposed of in a manner preventing VOC emissions to the atmosphere. [District NSR Rule, 4102], [Federally Enforceable Through Title V]
- 3. Well vent casing gases shall vent only to flare. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Flare shall operate with no visible emissions. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Flare pilot shall fire continuously. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Flare shall be equipped with automatic pilot. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Flare emissions shall not exceed any of the following: particulate matter (PM-10): 0.90 lb/day, nitrogen oxide (NOx): 36.10 lb/day, volatile organic compound (VOC): 1.01 lb/day, or carbon monoxide (CO): 12.64 lb/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Sulfur oxide (SOx) emission rate from the incineration of non-condensible vapor recovery gases in flare shall not exceed 274.56 lb/day as SO2. [District NSR Rule], [Federally Enforceable Through Title V]
- 9. Total fugitive volatile organic compound (VOC) emission rate shall not exceed 40.61 lb/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 10. Compliance with sulfur emission limit shall be verified by daily fuel consumption and quarterly fuel sulfur content, and such records shall be available for District inspection for two years. [District Rule 1070], [Federally Enforceable Through Title V]
- 11. Compliance with all other emission limits shall be verified by daily fuel consumption and operational data, and such records shall be available for District inspection for five years. [District Rule 1070], [Federally Enforceable Through Title V]
- 12. Permittee shall maintain with the permit a current listing of all steam enhanced wells connected to the casing vent control system and shall make such listing readily available for District inspection upon request. [District Rule 1070], [Federally Enforceable Through Title V]
- 13. The following test method shall be used for fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 14. The flare shall be operated according to the manufacturer's specifications, a copy of which shall be maintained on site. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 15. The flare in this permit shall be inspected every two weeks while in operation for visible emissions. If visible emissions are observed, corrective action shall be taken. If visible emissions continue, an EPA method 9 test shall be conducted within 72 hours. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 16. The crude oil production from wells associated with this permit unit shall not lie within 1000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5], [Federally Enforceable Through Title V]
- 17. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1], [Federally Enforceable Through Title V]
- All required source testing shall conform to the compliance testing procedures described in District Rule 1081(as amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 19. The operator shall maintain monitoring records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1], [Federally Enforceable Through Title V]

- 20. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 21. The uncontrolled VOC emissions from any well vent shall be reduced by at least 99 percent by weight or, if several steam-enhanced crude oil production well vents are connected to a vapor collection and control system, total uncontrolled VOC emissions shall be reduced by at least 99 percent. This requirement does not apply to cyclic wells located on contiguous and adjacent oil production properties with less than 10 cyclic wells owned by or under the control of a company. [District Rule 4401, 5.1 and 5.2], [Federally Enforceable Through Title V]
- 22. For cyclic wells located on properties with less than 10 cyclic wells and owned by a company, the uncontrolled VOC emissions from any well vent or system of well vents connected to a single vapor collection and control device shall be reduced by at least 50 percent.

 Properties shall include contiguous and adjacent oil production properties owned by or under control of the company. [District Rule 4401, 5.4], [Federally Enforceable Through Title V]
- 23. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3], [Federally Enforceable Through Title V]
- 24. Units consisting of more than 500 wells shall not exceed one leak detected for each 20 wells tested with a minimum of 50 wells tested. [District Rule 4401, 5.3], [Federally Enforceable Through Title V]
- 25. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1], [Federally Enforceable Through Title V]
- 26. Operator shall repair each leak within 15 calendar days of detection. The APCO may grant a 10 calendar day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1], [Federally Enforceable Through Title V]
- 27. Operator shall maintain all components of a well vent vapor collection and control system in good repair. Components of the well vent vapor collection and control system shall include all piping, valves, fittings, pumps, compressors, tanks, etc. used to collect, control, store, or dispose of VOC condensate or non-condensable VOCs and which is prior to any blending of VOC condensate with crude oil or blending of non-condensable VOCs with gases to be used as a fuel. [District Rule 4401, 5.3 and 5.3.2], [Federally Enforceable Through Title V]
- 28. Annual control efficiency compliance tests shall be performed on all vapor collection and control systems used to control emissions from steam-enhanced crude oil production wells. Testing shall be performed by source testers certified by the California Air Resources Board (CARB) during June, July, August or September of each year if the system's control efficiency is dependent upon ambient air temperature. The APCO may waive the annual testing requirements of this condition if the vapor control system does not exhaust to atmosphere or if all uncondensed VOC emissions collected by a vapor collection and control system are incinerated in fuel burning equipment, an internal combustion engine or in a smokeless open flare, and the source's Operating Permit contains adequate periodic monitoring to ensure the source meets 99% control efficiency. [District Rule 4401, 5.1, 5.2 and 6.2.1], [Federally Enforceable Through Title V]
- 29. The control efficiency of the vapor collection and control system used to control VOC emissions from steam enhanced crude oil production well shall be determined by mass balance based on most stringent of a source test, USEPA approved emission factors, or Air Pollution (AP)-42 emission factors for components and number of components; and the efficiency of destruction devices determined by USEPA Method 25, 25a, or 25b as applicable. [District Rule 4401, 6.3.1], [Federally Enforceable Through Title V]
- 30. VOC content shall be determined using the latest revision of ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by CARB Method 432. [District Rule 4401, 6.3.2], [Federally Enforceable Through Title V]
- 31. The source shall perform leak inspections at least annually, using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.4.2 and 4401, 6.3.3], [Federally Enforceable Through Title V]
- 32. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following requirements: County Rule 108.1 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 33. Compliance with permit conditions in the Title V permit shall be deemed in compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 34. The requirements of SJVUAPCD Rule 4407 (Adopted 5/19/94) and SJVUAPCD Rule 4801 (Adopted 12/17/92) do not apply to the well vents. For Rule 4801 applicability, well vent emissions are fugitive emissions not considered to come from a point source. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-93-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

12,600 GALLON 12' DIA. X 15' HIGH FIXED ROOF TEST TANK #D-1

- 1. True vapor pressure of liquid introduced into tank shall not exceed 1.3 psia. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Temperature of liquid in tank shall not exceed 250 degrees F. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Tank throughput shall not exceed 250 bbl/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Liquid stored shall be discharged to production pipeline only. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Tank shall be equipped with temperature indicator. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. VOC emission rate shall not exceed 0.17 lbm/hr. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 8. Operator shall keep accurate records of liquids stored in each container, storage temperature, daily throughput, and true vapor pressure of such liquids. [District Rules 4623, 6.1 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 9. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 10. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-94-4 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

8,820 GALLON 10' DIA. X 15' HIGH FIXED ROOF TEST TANK #D-2 KEENE-WILLIAMS LEASE)

- 1. True vapor pressure of liquid introduced into tank shall not exceed 1.3 psia. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Temperature of liquid in tank shall not exceed 250 degrees F. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Tank throughput shall not exceed 250 bbl/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Liquid stored shall be discharged to production pipeline only. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Tank shall be equipped with temperature indicator. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. VOC emission rate shall not exceed 4.1 lb/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 8. Operator shall keep accurate records of liquids stored in each container, storage temperature, daily throughput, and true vapor pressure of such liquids. [District Rules 4623, 6.1 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 9. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 10. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-95-3 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

12,600 GALLON, 12' DIA. X 15' HIGH FIXED-ROOF TEST TANK #T-2 (KEENE LEASE)

- 1. True vapor pressure of liquid introduced into tank shall not exceed 1.3 psia. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Temperature of liquid in tank shall not exceed 250 degrees F. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Tank throughput shall not exceed 250 bbl/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Tank shall be equipped with temperature indicator. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. VOC emission rate shall not exceed 4.1 lb/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 7. Operator shall keep accurate records of liquids stored in each container, storage temperature, daily throughput, and true vapor pressure of such liquids. [District Rules 4623, 6.1 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 8. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 9. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-96-3 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

8,820 GALLON 10' DIA. X 15' HIGH FIXED ROOF TEST TANK #T-1 (KEENE LEASE)

- 1. True vapor pressure of liquid introduced into tank shall not exceed 1.3 psia. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Temperature of liquid in tank shall not exceed 250 degrees F. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Tank throughput shall not exceed 250 bbl/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Liquid stored shall be discharged to production pipeline only. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Tank shall be equipped with temperature indicator. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. VOC emission rate shall not exceed 4.1 lb/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 8. Operator shall keep accurate records of liquids stored in each container, storage temperature, daily throughput, and true vapor pressure of such liquids. [District Rules 4623, 6.1 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 9. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 10. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-99-4 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

TEOR OPERATION INCLUDING 112 STEAM ENHANCED WELLS, WELL VENT VAPOR RECOVERY SYSTEM, SLUG CATCHER, SCRUBBERS, HEAT EXCHANGER, COMPRESSORS, PUMPS, STANDBY FLARE, SULFA CHECK SYSTEM, & VAPOR PIPING TO UNIT S-1372-26 (MCKITTRICK FEE/HOYT LEASE).

- 1. Leaks shall be inspected and repaired as specified in Rule 4401. [District Rule 4401], [Federally Enforceable Through Title V]
- 2. Collected condensate shall be discharged into production pipeline. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Liquids collected in drip pot on noncondensible piping going to steam generator S-1372-26 shall be returned to condensate collection vessel. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Standby flare shall only be used to incinerate TEOR vapors when steam generator S-1372-26 is inoperative. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Noncondensible vapors from this well vent vapor control system shall be incinerated in steam generator S-1372-26 or standby flare. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Fugitive VOC emissions from vapor collection and control system shall not exceed 2.2 lb/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Sulfur compounds (as SO2) emissions from incineration of TEOR vapors shall not exceed 2.56 lb/hr. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Permittee shall maintain accurate records of well casing vapor H2S concentration (periodic sampling of no less than once per quarter), daily volume of casing vapor incinerated, and calculated daily SO2 emissions. [District Rule 1070], [Federally Enforceable Through Title V]
- 9. Permittee shall maintain with the permit a current listing of all steam enhanced wells connected to the casing vent control system and shall make such listing readily available for District inspection upon request. [District Rule 1070], [Federally Enforceable Through Title V]
- 10. The following test method shall be used for fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 11. The flare shall be operated according to the manufacturer's specifications, a copy of which shall be maintained on site. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 12. The flare in this permit shall be inspected every two weeks while in operation for visible emissions. If visible emissions are observed, corrective action shall be taken. If visible emissions continue, an EPA method 9 test shall be conducted within 72 hours. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. The crude oil production from wells associated with this permit unit shall not lie within 1000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5], [Federally Enforceable Through Title V]
- 14. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1], [Federally Enforceable Through Title V]
- 15. All required source testing shall conform to the compliance testing procedures described in District Rule 1081(as amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 16. The operator shall maintain monitoring records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1], [Federally Enforceable Through Title V]
- 17. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]

- 18. The uncontrolled VOC emissions from any well vent shall be reduced by at least 99 percent by weight or, if several steam-enhanced crude oil production well vents are connected to a vapor collection and control system, total uncontrolled VOC emissions shall be reduced by at least 99 percent. This requirement does not apply to cyclic wells located on contiguous and adjacent oil production properties with less than 10 cyclic wells owned by or under the control of a company. [District Rule 4401, 5.1 and 5.2], [Federally Enforceable Through Title V]
- 19. For cyclic wells located on properties with less than 10 cyclic wells and owned by a company, the uncontrolled VOC emissions from any well vent or system of well vents connected to a single vapor collection and control device shall be reduced by at least 50 percent.

 Properties shall include contiguous and adjacent oil production properties owned by or under control of the company. [District Rule 4401, 5.4], [Federally Enforceable Through Title V]
- 20. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3], [Federally Enforceable Through Title V]
- 21. Units consisting of more than 500 wells shall not exceed one leak detected for each 20 wells tested with a minimum of 50 wells tested. [District Rule 4401, 5.3], [Federally Enforceable Through Title V]
- 22. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1], [Federally Enforceable Through Title V]
- 23. Operator shall repair each leak within 15 calendar days of detection. The APCO may grant a 10 calendar day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1], [Federally Enforceable Through Title V]
- 24. Operator shall maintain all components of a well vent vapor collection and control system in good repair. Components of the well vent vapor collection and control system shall include all piping, valves, fittings, pumps, compressors, tanks, etc. used to collect, control, store, or dispose of VOC condensate or non-condensable VOCs and which is prior to any blending of VOC condensate with crude oil or blending of non-condensable VOCs with gases to be used as a fuel. [District Rule 4401, 5.3 and 5.3.2], [Federally Enforceable Through Title V]
- 25. Annual control efficiency compliance tests shall be performed on all vapor collection and control systems used to control emissions from steam-enhanced crude oil production wells. Testing shall be performed by source testers certified by the California Air Resources Board (CARB) during June, July, August or September of each year if the system's control efficiency is dependent upon ambient air temperature. The APCO may waive the annual testing requirements of this condition if the vapor control system does not exhaust to atmosphere or if all uncondensed VOC emissions collected by a vapor collection and control system are incinerated in fuel burning equipment, an internal combustion engine or in a smokeless open flare, and the source's Operating Permit contains adequate periodic monitoring to ensure the source meets 99% control efficiency. [District Rule 4401, 5.1, 5.2 and 6.2.1], [Federally Enforceable Through Title V]
- 26. The control efficiency of the vapor collection and control system used to control VOC emissions from steam enhanced crude oil production well shall be determined by mass balance based on most stringent of a source test, USEPA approved emission factors, or Air Pollution (AP)-42 emission factors for components and number of components; and the efficiency of destruction devices determined by USEPA Method 25, 25a, or 25b as applicable. [District Rule 4401, 6.3.1], [Federally Enforceable Through Title V]
- 27. VOC content shall be determined using the latest revision of ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by CARB Method 432. [District Rule 4401, 6.3.2], [Federally Enforceable Through Title V]
- 28. The source shall perform leak inspections at least annually, using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.4.2 and 4401, 6.3.3], [Federally Enforceable Through Title V]
- 29. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following requirements: County Rule 108.1 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 30. Compliance with permit conditions in the Title V permit shall be deemed in compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 31. The requirements of SJVUAPCD Rule 4407 (Adopted 5/19/94) and SJVUAPCD Rule 4801 (Adopted 12/17/92) do not apply to the well vents. For Rule 4801 applicability, well vent emissions are fugitive emissions not considered to come from a point source. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-100-6 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

TEOR OPERATION WITH WELL CASING COLLECTION SYSTEM SERVING 439 STEAM ENHANCED WELLS WITH 3-PHASE SEPARATORS, STANDBY FLARE, SLUG CATCHER, SCRUBBERS, HEAT EXCHANGERS, COMPRESSORS, PUMPS, & SULFA CHECK SYSTEM (GAMBLE/MCKITTRICK FRONT)

- 1. Operation shall include the following equipment: 439 steam enhanced wells, well vent vapor collection system, standby flare, slug catchers, heat exchangers, compressors, pumps, vapor piping, Sulfa Check system, tanks and 3-phase separators. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Operation shall include vapor piping from tanks S-1641-34, -35, -36, -37, -133 and -134 to vapor control system. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Leaks shall be inspected and repaired as specified in Rule 4401. [District Rule 4401], [Federally Enforceable Through Title V]
- 4. Operation shall include Sulfa Check system, to be used when necessary to meet sulfur compounds limits of standby flare and steam generators, permit #'s S-1372-1, '2 & '4. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Collected condensate shall be discharged into production pipeline. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Flare shall only use PUC quality natural gas as auxiliary fuel. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Flare S-1372-100 shall only be used to incinerate TEOR vapors when one or more of steam generators S-1372-1, '2 or '4 are not in operation. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Vapors from this well vent vapor control system shall be incinerated in steam generators S-1372-1, '2 and '4, or standby flare. [District NSR Rule], [Federally Enforceable Through Title V]
- 9. Total sulfur oxide (SOx as SO2) emissions shall not exceed 1185.63 lb/day for the following steam generators: S-1372-1, -2 and -4 and standby flare. [District NSR Rule], [Federally Enforceable Through Title V]
- 10. VOC emissions from vapor collection and control system shall not exceed 541.2 lb/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 11. Flare shall be designed for smokeless operation, with no visible emissions in excess of 5% opacity. [District NSR Rule], [Federally Enforceable Through Title V]
- 12. Permittee shall maintain accurate records of well casing vapor H2S concentration (periodic sampling of no less than once per quarter), daily volume of casing vapor incinerated, and calculated daily SO2 emissions. [District Rule 1070], [Federally Enforceable Through Title V]
- 13. Sulfur compound emission sampling limit compliance shall be demonstrated annually by District witnessed fuel gas sulfur analysis, and results submitted within 60 days. [District Rule 1081], [Federally Enforceable Through Title V]
- 14. Permittee shall maintain with the permit a current listing of all steam enhanced wells connected to the casing vent control system and shall make such listing readily available for District inspection upon request. [District NSR Rule], [Federally Enforceable Through Title V]
- The following test method shall be used for fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 16. The flare shall be operated according to the manufacturer's specifications, a copy of which shall be maintained on site. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 17. The flare in this permit shall be inspected every two weeks while in operation for visible emissions. If visible emissions are observed, corrective action shall be taken. If visible emissions continue, an EPA method 9 test shall be conducted within 72 hours. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 18. The crude oil production from wells associated with this permit unit shall not lie within 1000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5], [Federally Enforceable Through Title V]

- 19. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1], [Federally Enforceable Through Title V]
- 20. All required source testing shall conform to the compliance testing procedures described in District Rule 1081(as amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 21. The operator shall maintain monitoring records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1], [Federally Enforceable Through Title V]
- 22. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 23. The uncontrolled VOC emissions from any well vent shall be reduced by at least 99 percent by weight or, if several steam-enhanced crude oil production well vents are connected to a vapor collection and control system, total uncontrolled VOC emissions shall be reduced by at least 99 percent. This requirement does not apply to cyclic wells located on contiguous and adjacent oil production properties with less than 10 cyclic wells owned by or under the control of a company. [District Rule 4401, 5.1 and 5.2], [Federally Enforceable Through Title V]
- 24. For cyclic wells located on properties with less than 10 cyclic wells and owned by a company, the uncontrolled VOC emissions from any well vent or system of well vents connected to a single vapor collection and control device shall be reduced by at least 50 percent.

 Properties shall include contiguous and adjacent oil production properties owned by or under control of the company. [District Rule 4401, 5.4], [Federally Enforceable Through Title V]
- 25. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3], [Federally Enforceable Through Title V]
- 26. Units consisting of more than 500 wells shall not exceed one leak detected for each 20 wells tested with a minimum of 50 wells tested. [District Rule 4401, 5.3], [Federally Enforceable Through Title V]
- 27. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1], [Federally Enforceable Through Title V]
- 28. Operator shall repair each leak within 15 calendar days of detection. The APCO may grant a 10 calendar day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1], [Federally Enforceable Through Title V]
- 29. Operator shall maintain all components of a well vent vapor collection and control system in good repair. Components of the well vent vapor collection and control system shall include all piping, valves, fittings, pumps, compressors, tanks, etc. used to collect, control, store, or dispose of VOC condensate or non-condensable VOCs and which is prior to any blending of VOC condensate with crude oil or blending of non-condensable VOCs with gases to be used as a fuel. [District Rule 4401, 5.3 and 5.3.2], [Federally Enforceable Through Title V]
- 30. Annual control efficiency compliance tests shall be performed on all vapor collection and control systems used to control emissions from steam-enhanced crude oil production wells. Testing shall be performed by source testers certified by the California Air Resources Board (CARB) during June, July, August or September of each year if the system's control efficiency is dependent upon ambient air temperature. The APCO may waive the annual testing requirements of this condition if the vapor control system does not exhaust to atmosphere or if all uncondensed VOC emissions collected by a vapor collection and control system are incinerated in fuel burning equipment, an internal combustion engine or in a smokeless open flare, and the source's Operating Permit contains adequate periodic monitoring to ensure the source meets 99% control efficiency. [District Rule 4401, 5.1, 5.2 and 6.2.1], [Federally Enforceable Through Title V]
- 31. The control efficiency of the vapor collection and control system used to control VOC emissions from steam enhanced crude oil production well shall be determined by mass balance based on most stringent of a source test, USEPA approved emission factors, or Air Pollution (AP)-42 emission factors for components and number of components; and the efficiency of destruction devices determined by USEPA Method 25, 25a, or 25b as applicable. [District Rule 4401, 6.3.1], [Federally Enforceable Through Title V]
- 32. VOC content shall be determined using the latest revision of ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by CARB Method 432. [District Rule 4401, 6.3.2], [Federally Enforceable Through Title V]
- 33. The source shall perform leak inspections at least annually, using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.4.2 and 4401, 6.3.3], [Federally Enforceable Through Title V]
- 34. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following requirements: County Rules 108.1 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 35. Compliance with permit conditions in the Title V permit shall be deemed in compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

36.	The requirements of SJVUAPCD Rule 4407 (Adopted 5/19/94) and SJVUAPCD Rule 4801 (Adopted 12/17/92) do not apply to the well vents. For Rule 4801 applicability, well vent emissions are fugitive emissions not considered to come from a point source. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
	NUIEVO ENEDOV COMDANV S 1272 100 S

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-106-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

32 MMBTU/HR STRUTHERS STEAM GENERATOR (#41). (RULE 4305, GROUP II UNIT) (CANCELED PER ATC S-1372-318-1 - CMD 5/17/99)

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
- 3. Sulfur compound emissions shall not exceed 2000 ppmv as SO2. [District Rule 4801]
- 4. Particulate matter emissions shall not exceed 0.1 gr/scf @ 12% CO2. []
- 5. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. []
- 6. Steam generator shall be fired exclusively on natural gas or LPG and shall have no provisions for firing on fuel oil. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-107-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

25.2 MMBTU/HR NATIONAL STEAM GENERATOR #40. (RULE 4305, GROUP II UNIT) (CANCELED PER ATC S-1372-318-1, CMD 5/17/99)

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
- 3. Sulfur compound emissions shall not exceed 2000 ppmv as SO2. [District Rule 4801]
- 4. Particulate matter emissions shall not exceed 0.1 gr/scf @ 12% CO2. []
- 5. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. []
- 6. Steam generator shall be fired exclusively on natural gas or LPG and shall have no provisions for firing on fuel oil. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-108-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

25.2 MMBTU/HR NATIONAL STEAM GENERATOR #17. (RULE 4305, GROUP II UNIT) (CANCELED PER ATC S-1372-318-1, CMD 5/17/99)

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101]
- 3. Sulfur compound emissions shall not exceed 2000 ppmv as SO2. [District Rule 4801]
- 4. Particulate matter emissions shall not exceed 0.1 gr/scf @ 12% CO2. []
- 5. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. []
- 6. Steam generator shall be fired exclusively on natural gas or LPG and shall have no provisions for firing on fuel oil. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-111-5 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH O2 CONTROLLER AND FLUE GAS RECIRCULATION (FGR).

- Steam generators S-1372-1 and '-111 shall not be located simultaneously at any of the following locations: Sec. 22, T32S, R23E; NE/4 & SE/4 Sec. 21, T32S, R23E; NW/4 & NE/4 Sec. 27, T32S, R23E; and NE/4 Sec. 28, T32S, R23E. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Gas fired emission rates shall not exceed the following: NOx 30 ppmv and CO 400 ppmv calculated to 3.00% O2 by volume stack gas oxygen and averaged over 60 minutes. [District Rule 4305], [Federally Enforceable Through Title V]
- 4. Emission rates shall not exceed the following: PM10: 0.005 lb/MMBtu; VOC: 0.003 lb/MMBtu; or SOx (as SO2): 0.001 lb/MMBtu. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Unit shall be fired only with natural gas with a maximum sulfur content of 0.37 gr/100 scf. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Source testing to measure NOx and CO emissions shall be conducted within 60 days of startup, and not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 7. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 8. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 9. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 10. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 11. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 12. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081 and 4305], [Federally Enforceable Through Title V]
- 13. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 14. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 15. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]

- 16. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 17. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 18. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081, and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 19. Copies of all fuel invoices, gas purchase contract, supplier certifications, and test results used to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel. [District Rule 2520, 9.4.2 and 40 CFR 60.48c(g)], [Federally Enforceable Through Title V]
- 20. Operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 21. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 22. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 23. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 24. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072-80, D 3031-81, D 4084-82, D 3246-81 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 27. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826-88 or D 1945-81 in conjunction with ASTM D 3588-89 for gaseous fuels.

 [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera) 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 30. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 31. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-112-6 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR (#45 GAMBLE) WITH BURNER, O2 CONTROLLER, AND FGR

- 1. Steam generator shall be equipped with operational fuel gas flowmeter. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Exhaust stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA test methods. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Unit shall be fired only with natural gas with a maximum sulfur content of 0.37 gr/100 scf. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Gas combusted in steam generator shall not exceed 62,500 scf/hr, based on 1000 Btu/scf gas, without prior District approval. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Emission rates shall not exceed any of the following: PM10: 0.005 lb/MMBtu, SOx (as SO2): 0.001 lb/MMBtu, NOx (as NO2): 30 ppmvd @ 3% O2 or 0.036 lb/MMBtu, VOC: 0.003 lb/MMBtu, or CO: 400 ppmvd @ 3% O2. [District NSR Rule and 4305], [Federally Enforceable Through Title V]
- 6. Source testing to measure NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 7. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 8. Visible emissions shall be inspected annually during operation. If visible emissions are observed, corrective action shall be taken to eliminate visible emissions. [District Rule 2520 9.4.2], [Federally Enforceable Through Title V]
- 9. Compliance with PM10 emission sampling limit shall be demonstrated, if visible emissions greater than 5% opacity or 1/4 Ringelmann are present. [District Rule 1081and District NSR Rule], [Federally Enforceable Through Title V]
- 10. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 11. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 12. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 13. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 14. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100, PM10 EPA Method 5, and gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305], [Federally Enforceable Through Title V]
- 16. Records required by this permit, including daily records of fuel consumption, shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District NSR Rule], [Federally Enforceable Through Title V]
- 17. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

- 18. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 19. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081, and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 20. Copies of all fuel invoices, gas purchase contract, supplier certifications, and test results used to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel. [District Rule 2520, 9.4.2 and 40 CFR 60.48c(g)], [Federally Enforceable Through Title V]
- 21. Operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 22. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 23. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 24. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 25. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 27. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072-80, D 3031-81, D 4084-82, D 3246-81 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 28. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826-88 or D 1945-81 in conjunction with ASTM D 3588-89 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 30. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rule 108.1 (Kern) and 404 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 31. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 32. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-113-7 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR (#44 GAMBLE) WITH BURNER, O2 CONTROLLER, AND FGR

- 1. Steam generator shall be equipped with operational fuel gas flowmeter. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Exhaust stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA test methods. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Unit shall be fired only with natural gas with a maximum sulfur content of 0.37 gr/100 scf. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Gas combusted in steam generator shall not exceed 62,500 scf/hr, based on 1000 Btu/scf gas, without prior District approval. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Emission rates shall not exceed any of the following: PM10: 0.005 lb/MMBtu, SOx (as SO2): 0.001 lb/MMBtu, NOx (as NO2): 30 ppmvd @ 3% O2 or 0.036 lb/MMBtu, VOC: 0.003 lb/MMBtu, or CO: 400 ppmvd @ 3% O2. [District NSR Rule and 4305], [Federally Enforceable Through Title V]
- 6. Source testing to measure NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 7. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 8. Visible emissions shall be inspected annually during operation. If visible emissions are observed, corrective action shall be taken to eliminate visible emissions. [District Rule 2520 9.4.2], [Federally Enforceable Through Title V]
- 9. Compliance with PM10 emission sampling limit shall be demonstrated, if visible emissions greater than 5% opacity or 1/4 Ringelmann are present. [District Rule 1081and District NSR Rule], [Federally Enforceable Through Title V]
- 10. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 11. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 12. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 13. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 14. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100, PM10 EPA Method 5, and gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305], [Federally Enforceable Through Title V]
- 16. Records required by this permit, including daily records of fuel consumption, shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District NSR Rule], [Federally Enforceable Through Title V]
- 17. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

- 18. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 19. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081, and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]
- 20. Copies of all fuel invoices, gas purchase contract, supplier certifications, and test results used to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel. [District Rule 2520, 9.4.2 and 40 CFR 60.48c(g)], [Federally Enforceable Through Title V]
- 21. Operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 22. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 23. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 24. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 25. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 27. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072-80, D 3031-81, D 4084-82, D 3246-81 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 28. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826-88 or D 1945-81 in conjunction with ASTM D 3588-89 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 30. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rule 108.1 (Kern) and 404 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 31. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of 40 CFR 60, Subpart Dc (except 60.44c(g) and (h) and 60.48c). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 32. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-114-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

5000 BBL SUMP REPLACEMENT TANK WITH ASSOCIATED VALVES, FLANGES, PUMPS, AND PIPING

- 1. The tank PV valve shall be set to within 10% of the maximum allowable working pressure of the tank. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Valves and flanges shall be maintained in good repair and shall have no visible leaks. [District NSR Rule], [Federally Enforceable Through Title VI
- 3. Tank shall receive material from facility's Midway-Sunset Oil Treating facility. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. True vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and District Rule 2010], [Federally Enforceable Through Title V]
- 5. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 6. Operator shall keep accurate records of material diverted into sump tank, storage temperature, and the true vapor pressure of such liquids. [District Rules 4623, 6.1 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 7. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 8. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-115-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

5000 BBL SUMP REPLACEMENT TANK WITH ASSOCIATED VALVES, FLANGES, PUMPS, AND PIPING

- 1. The tank PV valve shall be set to within 10% of the maximum allowable working pressure of the tank. [District NSR Rule], [Federally Enforceable Through Title V]
- Valves and flanges shall be maintained in good repair and shall have no visible leaks. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Tank shall receive material from facility's Midway-Sunset Oil Treating facility. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. True vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and District Rule 2010], [Federally Enforceable Through Title V]
- 5. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 6. Operator shall keep accurate records of material diverted into sump tank, storage temperature, and the true vapor pressure of such liquids. [District Rules 4623, 6.1 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 7. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 8. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-116-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

2000 BBL SUMP REPLACEMENT TANK WITH ASSOCIATED VALVES, FLANGES, PUMPS, AND PIPING

- 1. The tank PV valve shall be set to within 10% of the maximum allowable working pressure of the tank. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Valves and flanges shall be maintained in good repair and shall have no visible leaks. [District NSR Rule], [Federally Enforceable Through Title VI
- 3. Tank shall receive material from facility's Midway-Sunset Oil Treating facility. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. True vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and District Rule 2010], [Federally Enforceable Through Title V]
- 5. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 6. Operator shall keep accurate records of material diverted into sump tank, storage temperature, and the true vapor pressure of such liquids. [District Rules 4623, 6.1 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 7. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 8. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-117-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

500 BBL FIXED ROOF SUMP REPLACEMENT TANK WITH ASSOCIATED VALVES, FLANGES, PUMPS, AND PIPING

- 1. The tank PV valve shall be set to within 10% of the maximum allowable working pressure of the tank. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Valves and flanges shall be maintained in good repair and shall have no visible leaks. [District NSR Rule], [Federally Enforceable Through Title VI
- 3. Tank shall receive material from facility's Midway-Sunset Oil Treating facility. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. True vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and District Rule 2010], [Federally Enforceable Through Title V]
- 5. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 6. Operator shall keep accurate records of material diverted into sump tank, storage temperature, and the true vapor pressure of such liquids. [District Rules 4623, 6.1 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 7. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 8. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-126-11 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

TEOR OPERATION WITH 124 STEAM ENHANCED WELLS, WELL VENT VAPOR RECOVERY SYSTEM, VAPOR PIPING FROM TANK VAPOR CONTROL SYSTEM S-1372-128, KALDAIR P-4-E STANDBY FLARE, HEAT EXCHANGER, SEPARATORS, COMPRESSORS, PUMPS, AND SULFUR SCAVENGER SYSTEM (MCKITTRICK LEASE).

- 1. Leaks shall be inspected and repaired as specified in Rule 4401. [District Rule 4401], [Federally Enforceable Through Title V]
- 2. Noncondensible vapor piping shall vent to steam generator permit unit S-1372-137 or standby flare. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Casing gas shall be treated in gas sulfur scavenger vessels prior to incineration. [District NSR Rule], [Federally Enforceable Through Title V]
- Gas line to flare shall be equipped with volumetric flow rate indicator. [District Rule 1070 and District NSR Rule], [Federally Enforceable Through Title V]
- 5. All TEOR gas shall be treated in H2S scrubber prior to incineration. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. H2S control efficiency shall be maintained at no less than 95% by weight. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Flare shall not operate when steam generator is incinerating TEOR gas. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Flare shall operate with visible emissions less than 5% opacity, or Ringelmann 1/4. [District NSR Rule], [Federally Enforceable Through Title V]
- 9. Condensate shall only enter flow line leading to heater treater and treated oil stream shall only be routed to and stored in heavy oil tank permit units S-1372-128 and -129. [District NSR Rule], [Federally Enforceable Through Title V]
- 10. If noncondensible vapor incineration system is inoperable, all well casing vents served by vapor collection system shall be shut in and shall not vent to atmosphere. [District NSR Rule], [Federally Enforceable Through Title V]
- 11. VOC emission rate shall not exceed 71.9 lb/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 12. SO2 emissions from the incineration device shall not exceed 36.0 lb/day. Permittee shall maintain accurate records of well casing vapor H2S concentration (periodic sampling of no less than once per quarter) and daily volume of casing vapor incinerated. [District NSR Rule], [Federally Enforceable Through Title V]
- 13. Permittee shall maintain with the permit a current listing of all steam enhanced wells connected to the casing vent control system and shall make such listing readily available for District inspection upon request. [District Rule 1070], [Federally Enforceable Through Title V]
- 14. The following test method shall be used for fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 15. The flare shall be operated according to the manufacturer's specifications, a copy of which shall be maintained on site. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 16. The flare in this permit shall be inspected every two weeks while in operation for visible emissions. If visible emissions are observed, corrective action shall be taken. If visible emissions continue, an EPA method 9 test shall be conducted within 72 hours. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 17. The crude oil production from wells associated with this permit unit shall not lie within 1000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5], [Federally Enforceable Through Title V]
- 18. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1], [Federally Enforceable Through Title V]
- 19. All required source testing shall conform to the compliance testing procedures described in District Rule 1081(as amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]

- 20. The operator shall maintain monitoring records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1], [Federally Enforceable Through Title V]
- 21. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 22. The uncontrolled VOC emissions from any well vent shall be reduced by at least 99 percent by weight or, if several steam-enhanced crude oil production well vents are connected to a vapor collection and control system, total uncontrolled VOC emissions shall be reduced by at least 99 percent. This requirement does not apply to cyclic wells located on contiguous and adjacent oil production properties with less than 10 cyclic wells owned by or under the control of a company. [District Rule 4401, 5.1 and 5.2], [Federally Enforceable Through Title V]
- 23. For cyclic wells located on properties with less than 10 cyclic wells and owned by a company, the uncontrolled VOC emissions from any well vent or system of well vents connected to a single vapor collection and control device shall be reduced by at least 50 percent.

 Properties shall include contiguous and adjacent oil production properties owned by or under control of the company. [District Rule 4401, 5.4], [Federally Enforceable Through Title V]
- 24. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3], [Federally Enforceable Through Title V]
- 25. Units consisting of more than 500 wells shall not exceed one leak detected for each 20 wells tested with a minimum of 50 wells tested. [District Rule 4401, 5.3], [Federally Enforceable Through Title V]
- 26. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1], [Federally Enforceable Through Title V]
- 27. Operator shall repair each leak within 15 calendar days of detection. The APCO may grant a 10 calendar day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1], [Federally Enforceable Through Title V]
- 28. Operator shall maintain all components of a well vent vapor collection and control system in good repair. Components of the well vent vapor collection and control system shall include all piping, valves, fittings, pumps, compressors, tanks, etc. used to collect, control, store, or dispose of VOC condensate or non-condensable VOCs and which is prior to any blending of VOC condensate with crude oil or blending of non-condensable VOCs with gases to be used as a fuel. [District Rule 4401, 5.3 and 5.3.2], [Federally Enforceable Through Title V]
- 29. Annual control efficiency compliance tests shall be performed on all vapor collection and control systems used to control emissions from steam-enhanced crude oil production wells. Testing shall be performed by source testers certified by the California Air Resources Board (CARB) during June, July, August or September of each year if the system's control efficiency is dependent upon ambient air temperature. The APCO may waive the annual testing requirements of this condition if the vapor control system does not exhaust to atmosphere or if all uncondensed VOC emissions collected by a vapor collection and control system are incinerated in fuel burning equipment, an internal combustion engine or in a smokeless open flare, and the source's Operating Permit contains adequate periodic monitoring to ensure the source meets 99% control efficiency. [District Rule 4401, 5.1, 5.2 and 6.2.1], [Federally Enforceable Through Title V]
- 30. The control efficiency of the vapor collection and control system used to control VOC emissions from steam enhanced crude oil production well shall be determined by mass balance based on most stringent of a source test, USEPA approved emission factors, or Air Pollution (AP)-42 emission factors for components and number of components; and the efficiency of destruction devices determined by USEPA Method 25, 25a, or 25b as applicable. [District Rule 4401, 6.3.1], [Federally Enforceable Through Title V]
- 31. VOC content shall be determined using the latest revision of ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by CARB Method 432. [District Rule 4401, 6.3.2], [Federally Enforceable Through Title V]
- 32. The source shall perform leak inspections at least annually, using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.4.2 and 4401, 6.3.3], [Federally Enforceable Through Title V]
- 33. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following requirements: County Rule 108.1 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 34. Compliance with permit conditions in the Title V permit shall be deemed in compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 35. The requirements of SJVUAPCD Rule 4407 (Adopted 5/19/94) and SJVUAPCD Rule 4801 (Adopted 12/17/92) do not apply to the well vents. For Rule 4801 applicability, well vent emissions are fugitive emissions not considered to come from a point source. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-127-11 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR NATURAL GAS/TEOR GAS FIRED STEAM GENERATOR #43 WITH O2 CONTROLLER AND FGR.

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- Emissions shall not exceed any of the following: PM10 0.021 lb/MMBtu; SOx (as SO2) 0.0006 lb/MMBtu; NOx (as NO2) 0.036 lb/MMBtu or 30 ppmv @ 3% O2; VOC - 0.0003 lb/MMBtu; or CO - 400 ppmv @ 3% O2 lb/MMBtu. [District NSR Rule and District Rule 4305], [Federally Enforceable Through Title V]
- 3. Compliance with gas fired sulfur compound (SO2) emission limit shall be determined by fuel gas sulfur analysis performed 60 days prior to permit anniversary date. [District Rule 1070], [Federally Enforceable Through Title V]
- 4. Source testing to measure NOx and CO emissions shall be conducted within 60 days of startup, and not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 5. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 6. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305], [Federally Enforceable Through Title V]
- 7. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305], [Federally Enforceable Through Title V]
- 8. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 9. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 10. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 11. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305], [Federally Enforceable Through Title V]
- 12. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 13. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 14. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), and 110 (Madera)], [Federally Enforceable Through Title V]

- 16. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 17. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 18. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 19. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of the fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 20. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 21. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 22. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072-80, D 3031-81, D 4084-82, D 3246-81 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 23. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 240-87 or D 2382-88 for liquid hydrocarbon fuels; ASTM D 1826-88 or D 1945-81 in conjunction with ASTM D 3588-89 for gaseous fuels. [District Rule 2520, 9.4.2 and District Rule 4305, 6.2.1], [Federally Enforceable Through Title V]
- 24. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)], [Federally Enforceable Through Title V]
- 25. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 27. Nitrogen oxide (NOx) emission concentrations in ppmv shall be referenced at dry stack gas conditions, and shall be calculated to 3.00 percent by volume stack gas oxygen and averaged over 60 minutes, and lb/MMBtu rates shall be calculated as lb NO2/MMBtu of heat input (hhv). [District Rule 4305, 5.0, 8.2], [Federally Enforceable Through Title V]
- 28. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 30. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rule 108.1 (Kern) and 404 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 31. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

- 32. The requirements of 40 CFR 60.40c do not apply to this source. The facility has stated this unit has not been reconstructed or modified after June 9, 1989. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 33. The requirements of SJVUAPCD Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 34. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2 and 4351, 6.3], [Federally Enforceable Through Title V]
- 35. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 36. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 37. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 38. The number of representative units source tested to demonstrate compliance for NOx limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-128-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,000 GALLON WASH TANK (#80) AND TWO FREE WATER KNOCKOUT VESSELS WITH VAPOR RECOVERY SYSTEM SHARED WITH PERMIT UNITS S-1372-129, 130, 131, 132, 133, 134, 135, AND 136 (UNIT LEASE)

- 1. The vapor recovery system shall include the following operational equipment: pressure/vacuum relief valves, piping to pressure relief valve at vapor collection manifold, one air cooled heat exchanger, one vapor recovery compressor, one compressor discharge gas/liquid separator, one condensate pump, and vapor piping to TEOR vapor control system S-1372-126. [District NSR Rule], [Federally Enforceable Through Title V]
- Vapor control system efficiency shall be maintained at no less than 99% by weight. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. True vapor pressure of liquids stored shall not exceed 1.60 psia. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Throughput shall not exceed 1,600 bbl/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Pressure/vacuum relief valves shall be set to open at 2 oz./square inch pressure and 0.5 oz./square inch vacuum. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Vapor compressor shall activate whenever tank internal pressure exceeds 2 oz./square inch. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. There shall be no truck loading or unloading at this facility. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Liquids from gas/liquid separators shall be pumped back to tanks. [District NSR Rule], [Federally Enforceable Through Title V]
- 9. VOC emission rate shall not exceed 0.01 lb/hr. [District NSR Rule], [Federally Enforceable Through Title V]
- 10. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. Gas-tight shall be defined as emitting no more than 10,000 ppm of methane measured at a distance of one centimeter from the potential source with an instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this limit shall be considered a leak. [District Rule 4623, 5.3.2], [Federally Enforceable Through Title V]
- 11. All piping, valves and fittings shall be constructed and maintained in a gas-tight condition. Gas-tight shall be defined as emitting no more than 10,000 ppm of methane measured at a distance of one centimeter from the potential source with an instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this limit shall be considered a leak. [District Rule 4623, 5.3.3], [Federally Enforceable Through Title V]
- 12. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. A facility operator, upon detection of a leaking component, shall affix to that component a weatherproof readily visible tag bearing the date on which the leak is detected. The tag shall remain in place until the leaking component is repaired, reinspected and found to be in compliance with the requirements of this rule. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 14. An operator shall reinspect a component for leaks within thirty working days after the date on which the component is repaired. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 15. Emissions from components which have been tagged by the facility operator for repair within 15 calendar days or which have been repaired and are awaiting re-inspection shall not be in violation of this permit. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

- Any component leak shall be repaired to a leak-free condition or vented to a flare satisfying the requirements of 40 CFR 60.18 or to a vapor control device that is at least 95 percent efficient as measured by EPA Method 25 within fifteen (15) calendar days of detection. The APCO may grant a ten (10) calendar day extension provided the operator demonstrates that necessary and sufficient actions are being taken to correct the leak within this time period. Any vapor control device, other than a flare, used to comply with this condition shall demonstrate at least 95% control efficiency as measured by EPA Method 25 at least annually. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 17. If the leaking component is an essential part of a critical process unit which cannot be immediately shut down for repairs, the operator shall 1) Minimize the leak within 15 calendar days; and 2) If the leak which has been minimized still exceeds the concentration allowed by this permit, the essential component shall be repaired to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection. A critical process unit is any process unit which would result in the automatic shutdown of other process units if it were shut down. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 18. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired; 4) Identification and location of essential parts of critical process units found leaking that cannot be repaired until the next process unit turnaround; and 5) Method used to minimize the leak from essential parts of critical process units which cannot be repaired until the next process unit turnaround. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 19. Operator shall keep a record of liquids stored in each container, storage temperature and the Reid vapor pressure of such liquids. [District Rule 4623, 6.1], [Federally Enforceable Through Title V]
- 20. True vapor pressure shall be measured using Reid vapor pressure ASTM Method D323-82 modified by maintaining the hot water bath at storage temperature. Where storage temperature is above 100 degrees F true vapor pressure shall be determined by Reid vapor pressure at 100 degrees F and ARB approved calculations. [District Rule 4623, 6.2.2], [Federally Enforceable Through Title V]
- 21. True vapor pressure of crude oil with an API (American Petroleum Institute) gravity less than 30 deg, as determined by API 2547, may be determined by Headspace Gas Chromatography using the procedures from ARB Evaluation of a Method for Determining Vapor Pressures of Petroleum Mixtures by Headspace Gas Chromatography, October 1990. [District Rule 4623, 6.2.3], [Federally Enforceable Through Title V]
- 22. Control efficiency shall be determined by a comparison of controlled emissions to those emissions which would occur from a fixed or cone roof tank in the same product service without a vapor recovery system. Emissions shall be determined based on tank emission factors in EPA Publication AP-42, component counts for fugitive emissions sources, recognized emission factors for fugitive emission sources and the efficiency of any VOC destruction device. [District Rule 4623, 6.2.4], [Federally Enforceable Through Title V]
- 23. The efficiency of any VOC destruction device shall be measured by EPA Method 25, 25a, or 25b. [District Rule 4623, 6.2.5], [Federally Enforceable Through Title V]
- 24. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 25. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 26. Operator shall monitor vapor recovery compressor activation and shut off manometer pressures on quarterly basis to ensure that compressor activation pressure does not exceed pressure relief valve setting. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 27. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 28. Operator shall keep accurate records of types of liquids stored in each container, storage temperature, daily throughput, and the true vapor pressure of such liquids. [District Rules 4623, 6.1 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 31. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4623 (Amended December 17, 1992). A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-129-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,000 GALLON PRODUCTION TANK (#78) SERVED BY VAPOR RECOVERY SYSTEM LISTED ON PERMIT UNIT S-1372-

- 1. Pressure/vacuum relief valves shall be set to open at 2 oz./square inch pressure and 0.5 oz./square inch vacuum. [District Rule 4623], [Federally Enforceable Through Title V]
- 2. True vapor pressure (TVP) of any liquid placed, stored or held in the tank shall not exceed 1.60 psia. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. There shall be no truck loading or unloading at this facility. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Facility piping system shall be routinely inspected for leaks and all leaks shall be promptly repaired. [District NSR Rule], [Federally Enforceable Through Title V]
- Vapor control system efficiency shall be maintained at no less than 99% by weight. [District NSR Rule], [Federally Enforceable Through Title
 V]
- 6. Average daily throughput shall not exceed 1,600 bbl/day of fluid. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Vapor compressor shall activate whenever tank internal pressure exceeds 2 oz./square inch. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Vapor collection system shall not discharge to atmosphere except during breakdown conditions pursuant to Rule 1100. [District Rule 1100], [Federally Enforceable Through Title V]
- 9. Liquids from gas/liquid separators shall be pumped back to tanks. [District NSR Rule], [Federally Enforceable Through Title V]
- 10. VOC emission rate shall not exceed 0.15 lb/hr. [District NSR Rule], [Federally Enforceable Through Title V]
- 11. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. Gas-tight shall be defined as emitting no more than 10,000 ppm of methane measured at a distance of one centimeter from the potential source with an instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this limit shall be considered a leak. [District Rule 4623, 5.3.2], [Federally Enforceable Through Title V]
- 12. All piping, valves and fittings shall be constructed and maintained in a gas-tight condition. Gas-tight shall be defined as emitting no more than 10,000 ppm of methane measured at a distance of one centimeter from the potential source with an instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this limit shall be considered a leak. [District Rule 4623, 5.3.3], [Federally Enforceable Through Title V]
- 13. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 14. A facility operator, upon detection of a leaking component, shall affix to that component a weatherproof readily visible tag bearing the date on which the leak is detected. The tag shall remain in place until the leaking component is repaired, reinspected and found to be in compliance with the requirements of this rule. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 15. An operator shall reinspect a component for leaks within thirty working days after the date on which the component is repaired. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 16. Emissions from components which have been tagged by the facility operator for repair within 15 calendar days or which have been repaired and are awaiting re-inspection shall not be in violation of this permit. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

- 17. Any component leak shall be repaired to a leak-free condition or vented to a flare satisfying the requirements of 40 CFR 60.18 or to a vapor control device that is at least 95 percent efficient as measured by EPA Method 25 within fifteen (15) calendar days of detection. The APCO may grant a ten (10) calendar day extension provided the operator demonstrates that necessary and sufficient actions are being taken to correct the leak within this time period. Any vapor control device, other than a flare, used to comply with this condition shall demonstrate at least 95% control efficiency as measured by EPA Method 25 at least annually. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 18. If the leaking component is an essential part of a critical process unit which cannot be immediately shut down for repairs, the operator shall 1) Minimize the leak within 15 calendar days; and 2) If the leak which has been minimized still exceeds the concentration allowed by this permit, the essential component shall be repaired to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection. A critical process unit is any process unit which would result in the automatic shutdown of other process units if it were shut down. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 19. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired; 4) Identification and location of essential parts of critical process units found leaking that cannot be repaired until the next process unit turnaround; and 5) Method used to minimize the leak from essential parts of critical process units which cannot be repaired until the next process unit turnaround. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 20. Operator shall keep a record of liquids stored in each container, storage temperature and the Reid vapor pressure of such liquids. [District Rule 4623, 6.1], [Federally Enforceable Through Title V]
- 21. True vapor pressure shall be measured using Reid vapor pressure ASTM Method D323-82 modified by maintaining the hot water bath at storage temperature. Where storage temperature is above 100 degrees F true vapor pressure shall be determined by Reid vapor pressure at 100 degrees F and ARB approved calculations. [District Rule 4623, 6.2.2], [Federally Enforceable Through Title V]
- 22. True vapor pressure of crude oil with an API (American Petroleum Institute) gravity less than 30 deg, as determined by API 2547, may be determined by Headspace Gas Chromatography using the procedures from ARB Evaluation of a Method for Determining Vapor Pressures of Petroleum Mixtures by Headspace Gas Chromatography, October 1990. [District Rule 4623, 6.2.3], [Federally Enforceable Through Title V]
- 23. Control efficiency shall be determined by a comparison of controlled emissions to those emissions which would occur from a fixed or cone roof tank in the same product service without a vapor recovery system. Emissions shall be determined based on tank emission factors in EPA Publication AP-42, component counts for fugitive emissions sources, recognized emission factors for fugitive emission sources and the efficiency of any VOC destruction device. [District Rule 4623, 6.2.4], [Federally Enforceable Through Title V]
- 24. The efficiency of any VOC destruction device shall be measured by EPA Method 25, 25a, or 25b. [District Rule 4623, 6.2.5], [Federally Enforceable Through Title V]
- 25. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 27. Operator shall maintain all records for at least five years and conform to the recordkeeping requirements described in District Rule 2520. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 28. Operator shall monitor vapor recovery compressor activation and shut off manometer pressures on quarterly basis to ensure that compressor activation pressure does not exceed pressure relief valve setting. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. Operator shall keep accurate records of types of liquids stored in each container, storage temperature, daily throughput, and the true vapor pressure of such liquids. [District Rules 4623, 6.1 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 33. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4623 (Amended December 17, 1992). A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-130-2 EXPIRATION DATE: 05/31/2007

EQUIPMENT DECRIPTION:

84,000 GALLON WATER DISPOSAL TANK (#79) WITH VAPOR RECOVERY SYSTEM SHARED WITH S-1372-128

- 1. Pressure/vacuum relief valves shall be set to open at 2 oz./square inch pressure and 0.5 oz./square inch vacuum. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. True vapor pressure of liquids stored shall not exceed 1.60 psia. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Throughput shall not exceed 20,000 bbl/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Vapor compressor shall activate whenever tank internal pressure exceeds 2 oz./square inch. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. There shall be no truck loading or unloading at this facility. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Facility piping system shall be routinely inspected for leaks and all leaks shall be promptly repaired. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Vapor collection system shall not discharge to atmosphere except during breakdown conditions pursuant to Rule 1100. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Liquids from gas/liquid separators shall be pumped back to tanks. [District NSR Rule], [Federally Enforceable Through Title V]
- 9. VOC emission rate shall not exceed 0.01 lb/hr. [District NSR Rule], [Federally Enforceable Through Title V]
- 10. Vapor control system efficiency shall be maintained at no less than 99% by weight. [District NSR Rule], [Federally Enforceable Through Title V]
- 11. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. Gas-tight shall be defined as emitting no more than 10,000 ppm of methane measured at a distance of one centimeter from the potential source with an instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this limit shall be considered a leak. [District Rule 4623, 5.3.2], [Federally Enforceable Through Title V]
- 12. All piping, valves and fittings shall be constructed and maintained in a gas-tight condition. Gas-tight shall be defined as emitting no more than 10,000 ppm of methane measured at a distance of one centimeter from the potential source with an instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this limit shall be considered a leak. [District Rule 4623, 5.3.3], [Federally Enforceable Through Title V]
- 13. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 14. A facility operator, upon detection of a leaking component, shall affix to that component a weatherproof readily visible tag bearing the date on which the leak is detected. The tag shall remain in place until the leaking component is repaired, reinspected and found to be in compliance with the requirements of this rule. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 15. An operator shall reinspect a component for leaks within thirty working days after the date on which the component is repaired. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 16. Emissions from components which have been tagged by the facility operator for repair within 15 calendar days or which have been repaired and are awaiting re-inspection shall not be in violation of this permit. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

- 17. Any component leak shall be repaired to a leak-free condition or vented to a flare satisfying the requirements of 40 CFR 60.18 or to a vapor control device that is at least 95 percent efficient as measured by EPA Method 25 within fifteen (15) calendar days of detection. The APCO may grant a ten (10) calendar day extension provided the operator demonstrates that necessary and sufficient actions are being taken to correct the leak within this time period. Any vapor control device, other than a flare, used to comply with this condition shall demonstrate at least 95% control efficiency as measured by EPA Method 25 at least annually. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 18. If the leaking component is an essential part of a critical process unit which cannot be immediately shut down for repairs, the operator shall 1) Minimize the leak within 15 calendar days; and 2) If the leak which has been minimized still exceeds the concentration allowed by this permit, the essential component shall be repaired to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection. A critical process unit is any process unit which would result in the automatic shutdown of other process units if it were shut down. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 19. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired; 4) Identification and location of essential parts of critical process units found leaking that cannot be repaired until the next process unit turnaround; and 5) Method used to minimize the leak from essential parts of critical process units which cannot be repaired until the next process unit turnaround. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 20. Operator shall keep a record of liquids stored in each container, storage temperature and the Reid vapor pressure of such liquids. [District Rule 4623, 6.1], [Federally Enforceable Through Title V]
- 21. True vapor pressure shall be measured using Reid vapor pressure ASTM Method D323-82 modified by maintaining the hot water bath at storage temperature. Where storage temperature is above 100 degrees F true vapor pressure shall be determined by Reid vapor pressure at 100 degrees F and ARB approved calculations. [District Rule 4623, 6.2.2], [Federally Enforceable Through Title V]
- 22. True vapor pressure of crude oil with an API (American Petroleum Institute) gravity less than 30 deg, as determined by API 2547, may be determined by Headspace Gas Chromatography using the procedures from ARB Evaluation of a Method for Determining Vapor Pressures of Petroleum Mixtures by Headspace Gas Chromatography, October 1990. [District Rule 4623, 6.2.3], [Federally Enforceable Through Title V]
- 23. Control efficiency shall be determined by a comparison of controlled emissions to those emissions which would occur from a fixed or cone roof tank in the same product service without a vapor recovery system. Emissions shall be determined based on tank emission factors in EPA Publication AP-42, component counts for fugitive emissions sources, recognized emission factors for fugitive emission sources and the efficiency of any VOC destruction device. [District Rule 4623, 6.2.4], [Federally Enforceable Through Title V]
- 24. The efficiency of any VOC destruction device shall be measured by EPA Method 25, 25a, or 25b. [District Rule 4623, 6.2.5], [Federally Enforceable Through Title V]
- 25. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 27. Operator shall maintain all records for at least five years and conform to the recordkeeping requirements described in District Rule 2520. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 28. Operator shall monitor vapor recovery compressor activation and shut off manometer pressures on quarterly basis to ensure that compressor activation pressure does not exceed pressure relief valve setting. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. Operator shall keep accurate records of types of liquids stored in each container, storage temperature, daily throughput, and the true vapor pressure of such liquids. [District Rules 4623, 6.1 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 33. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4623 (Amended December 17, 1992). A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-131-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,000 GALLON PRODUCTION TANK (#77) WITH VAPOR RECOVERY SYSTEM SHARED WITH S-1372-128

- 1. Pressure/vacuum relief valves shall be set to open at 2 oz/square inch pressure and 0.5 oz./square inch vacuum. [District Rule 4623], [Federally Enforceable Through Title V]
- 2. True vapor pressure (TVP) of any liquid placed, stored or held in the tank shall not exceed 1.60 psia. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. There shall be no truck loading or unloading at this facility. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Facility piping system shall be routinely inspected for leaks and all leaks shall be promptly repaired. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Vapor control system efficiency shall be maintained at no less than 99% by weight. [District NSR Rule], [Federally Enforceable Through Title VI
- 6. Average daily throughput shall not exceed 1,600 bbl/day of fluid. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Vapor compressor shall activate whenever tank internal pressure exceeds 2 oz./square inch. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Vapor collection system shall not discharge to atmosphere except during breakdown conditions pursuant to Rule 1100. [District Rule 1100], [Federally Enforceable Through Title V]
- 9. Liquids from gas/liquid separators shall be pumped back to tanks. [District NSR Rule], [Federally Enforceable Through Title V]
- 10. VOC emission rate shall not exceed 0.15 lbm/hr. [District NSR Rule], [Federally Enforceable Through Title V]
- 11. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. Gas-tight shall be defined as emitting no more than 10,000 ppm of methane measured at a distance of one centimeter from the potential source with an instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this limit shall be considered a leak. [District Rule 4623, 5.3.2], [Federally Enforceable Through Title V]
- 12. All piping, valves and fittings shall be constructed and maintained in a gas-tight condition. Gas-tight shall be defined as emitting no more than 10,000 ppm of methane measured at a distance of one centimeter from the potential source with an instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this limit shall be considered a leak. [District Rule 4623, 5.3.3], [Federally Enforceable Through Title V]
- 13. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 14. A facility operator, upon detection of a leaking component, shall affix to that component a weatherproof readily visible tag bearing the date on which the leak is detected. The tag shall remain in place until the leaking component is repaired, reinspected and found to be in compliance with the requirements of this rule. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 15. An operator shall reinspect a component for leaks within thirty working days after the date on which the component is repaired. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 16. Emissions from components which have been tagged by the facility operator for repair within 15 calendar days or which have been repaired and are awaiting re-inspection shall not be in violation of this permit. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

- 17. Any component leak shall be repaired to a leak-free condition or vented to a flare satisfying the requirements of 40 CFR 60.18 or to a vapor control device that is at least 95 percent efficient as measured by EPA Method 25 within fifteen (15) calendar days of detection. The APCO may grant a ten (10) calendar day extension provided the operator demonstrates that necessary and sufficient actions are being taken to correct the leak within this time period. Any vapor control device, other than a flare, used to comply with this condition shall demonstrate at least 95% control efficiency as measured by EPA Method 25 at least annually. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 18. If the leaking component is an essential part of a critical process unit which cannot be immediately shut down for repairs, the operator shall 1) Minimize the leak within 15 calendar days; and 2) If the leak which has been minimized still exceeds the concentration allowed by this permit, the essential component shall be repaired to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection. A critical process unit is any process unit which would result in the automatic shutdown of other process units if it were shut down. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 19. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired; 4) Identification and location of essential parts of critical process units found leaking that cannot be repaired until the next process unit turnaround; and 5) Method used to minimize the leak from essential parts of critical process units which cannot be repaired until the next process unit turnaround. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 20. Operator shall keep a record of liquids stored in each container, storage temperature and the Reid vapor pressure of such liquids. [District Rule 4623, 6.1], [Federally Enforceable Through Title V]
- 21. True vapor pressure shall be measured using Reid vapor pressure ASTM Method D323-82 modified by maintaining the hot water bath at storage temperature. Where storage temperature is above 100 degrees F true vapor pressure shall be determined by Reid vapor pressure at 100 degrees F and ARB approved calculations. [District Rule 4623, 6.2.2], [Federally Enforceable Through Title V]
- 22. True vapor pressure of crude oil with an API (American Petroleum Institute) gravity less than 30 deg, as determined by API 2547, may be determined by Headspace Gas Chromatography using the procedures from ARB Evaluation of a Method for Determining Vapor Pressures of Petroleum Mixtures by Headspace Gas Chromatography, October 1990. [District Rule 4623, 6.2.3], [Federally Enforceable Through Title V]
- 23. Control efficiency shall be determined by a comparison of controlled emissions to those emissions which would occur from a fixed or cone roof tank in the same product service without a vapor recovery system. Emissions shall be determined based on tank emission factors in EPA Publication AP-42, component counts for fugitive emissions sources, recognized emission factors for fugitive emission sources and the efficiency of any VOC destruction device. [District Rule 4623, 6.2.4], [Federally Enforceable Through Title V]
- 24. The efficiency of any VOC destruction device shall be measured by EPA Method 25, 25a, or 25b. [District Rule 4623, 6.2.5], [Federally Enforceable Through Title V]
- 25. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 27. Operator shall maintain all records for at least five years and conform to the recordkeeping requirements described in District Rule 2520. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 28. Operator shall monitor vapor recovery compressor activation and shut off manometer pressures on quarterly basis to ensure that compressor activation pressure does not exceed pressure relief valve setting. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. Operator shall keep accurate records of types of liquids stored in each container, storage temperature, daily throughput, and the true vapor pressure of such liquids. [District Rules 4623, 6.1 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 33. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4623 (Amended December 17, 1992). A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-132-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

210,000 GALLON REJECT TANK (#77) SERVED BY VAPOR RECOVERY SYSTEM LISTED ON S-1372-128

- 1. Pressure/vacuum relief valves shall be set to open at 2 oz./square inch pressure and 0.5 oz./square inch vacuum. [District Rule 4623], [Federally Enforceable Through Title V]
- 2. Vapor compressor shall activate whenever tank internal pressure exceeds 2 oz./square inch. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. True vapor pressure (TVP) of any liquid placed, stored or held in the tank shall not exceed 1.60 psia. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. There shall be no truck loading or unloading at this facility. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Facility piping system shall be routinely inspected for leaks and all leaks shall be promptly repaired. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Vapor control system efficiency shall be maintained at no less than 99% by weight. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Vapor collection system shall not discharge to atmosphere except during breakdown conditions pursuant to Rule 1100. [District Rule 1100], [Federally Enforceable Through Title V]
- 8. Liquids from gas/liquid separators shall be pumped back to tanks. [District NSR Rule], [Federally Enforceable Through Title V]
- 9. Throughput shall not exceed 100 bbl/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 10. VOC emission rate shall not exceed 0.01 lb/hr. [District NSR Rule], [Federally Enforceable Through Title V]
- 11. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. Gas-tight shall be defined as emitting no more than 10,000 ppm of methane measured at a distance of one centimeter from the potential source with an instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this limit shall be considered a leak. [District Rule 4623, 5.3.2], [Federally Enforceable Through Title V]
- All piping, valves and fittings shall be constructed and maintained in a gas-tight condition. Gas-tight shall be defined as emitting no more than 10,000 ppm of methane measured at a distance of one centimeter from the potential source with an instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this limit shall be considered a leak. [District Rule 4623, 5.3.3], [Federally Enforceable Through Title V]
- 13. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 14. A facility operator, upon detection of a leaking component, shall affix to that component a weatherproof readily visible tag bearing the date on which the leak is detected. The tag shall remain in place until the leaking component is repaired, reinspected and found to be in compliance with the requirements of this rule. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 15. An operator shall reinspect a component for leaks within thirty working days after the date on which the component is repaired. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 16. Emissions from components which have been tagged by the facility operator for repair within 15 calendar days or which have been repaired and are awaiting re-inspection shall not be in violation of this permit. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

- 17. Any component leak shall be repaired to a leak-free condition or vented to a flare satisfying the requirements of 40 CFR 60.18 or to a vapor control device that is at least 95 percent efficient as measured by EPA Method 25 within fifteen (15) calendar days of detection. The APCO may grant a ten (10) calendar day extension provided the operator demonstrates that necessary and sufficient actions are being taken to correct the leak within this time period. Any vapor control device, other than a flare, used to comply with this condition shall demonstrate at least 95% control efficiency as measured by EPA Method 25 at least annually. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 18. If the leaking component is an essential part of a critical process unit which cannot be immediately shut down for repairs, the operator shall 1) Minimize the leak within 15 calendar days; and 2) If the leak which has been minimized still exceeds the concentration allowed by this permit, the essential component shall be repaired to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection. A critical process unit is any process unit which would result in the automatic shutdown of other process units if it were shut down. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 19. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired; 4) Identification and location of essential parts of critical process units found leaking that cannot be repaired until the next process unit turnaround; and 5) Method used to minimize the leak from essential parts of critical process units which cannot be repaired until the next process unit turnaround. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 20. Operator shall keep a record of liquids stored in each container, storage temperature and the Reid vapor pressure of such liquids. [District Rule 4623, 6.1], [Federally Enforceable Through Title V]
- 21. True vapor pressure shall be measured using Reid vapor pressure ASTM Method D323-82 modified by maintaining the hot water bath at storage temperature. Where storage temperature is above 100 degrees F true vapor pressure shall be determined by Reid vapor pressure at 100 degrees F and ARB approved calculations. [District Rule 4623, 6.2.2], [Federally Enforceable Through Title V]
- 22. True vapor pressure of crude oil with an API (American Petroleum Institute) gravity less than 30 deg, as determined by API 2547, may be determined by Headspace Gas Chromatography using the procedures from ARB Evaluation of a Method for Determining Vapor Pressures of Petroleum Mixtures by Headspace Gas Chromatography, October 1990. [District Rule 4623, 6.2.3], [Federally Enforceable Through Title V]
- 23. Control efficiency shall be determined by a comparison of controlled emissions to those emissions which would occur from a fixed or cone roof tank in the same product service without a vapor recovery system. Emissions shall be determined based on tank emission factors in EPA Publication AP-42, component counts for fugitive emissions sources, recognized emission factors for fugitive emission sources and the efficiency of any VOC destruction device. [District Rule 4623, 6.2.4], [Federally Enforceable Through Title V]
- 24. The efficiency of any VOC destruction device shall be measured by EPA Method 25, 25a, or 25b. [District Rule 4623, 6.2.5], [Federally Enforceable Through Title V]
- 25. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 27. Operator shall maintain all records for at least five years and conform to the recordkeeping requirements described in District Rule 2520. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 28. Operator shall monitor vapor recovery compressor activation and shut off manometer pressures on quarterly basis to ensure that compressor activation pressure does not exceed pressure relief valve setting. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. Operator shall keep accurate records of types of liquids stored in each container, storage temperature, daily throughput, and the true vapor pressure of such liquids. [District Rules 4623, 6.1 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 33. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4623 (Amended December 17, 1992). A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-133-4 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

63,000 GALLON FIXED ROOF CRUDE OIL PRODUCTION TANK #108 WITH GAS/LIQUID SEPARATORS, HEAT EXCHANGERS, AND VAPOR COMPRESSOR SHARED WITH S-1372-134

- 1. Tank shall be equipped with a vapor loss prevention system consisting of vapor and condensate collection systems capable of reducing volatile organic compound (VOC) emissions by at least 99%. [District Rule 2201]
- 2. Tank vapors shall compressed and transported to vapor control system listed on S-1372-100. [District Rule 2201]
- 3. Tank gauging or sampling port shall be equipped with a gas-tight cover (as defined in Rule 4623) which shall be closed at all times except during gauging, sampling or attended maintenance operations. [District Rule 4623]
- 4. All piping, valves and fittings shall be constructed and maintained in a gas-tight condition (as defined in Rule 4623). [District Rule 4623]
- 5. True vapor pressure of liquids stored shall not exceed 1.6 psia. [District Rule 2201]
- 6. Average daily throughput on an annual basis shall not exceed 9000 bbl/day of oil. [District Rule 2201]
- 7. Volatile organic compound (VOC) emissions shall not exceed 0.7 lb/day. [District Rule 2201]
- 8. Permittee shall maintain accurate records of daily throughput, true vapor pressure, and temperature of liquids stored and shall make such records available for District inspection for two years. [District Rule 2201 & 4623]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-134-4 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,000 GALLON GALLON FIXED ROOF CRUDE OIL PRODUCTION TANK WITH GAS/LIQUID SEPARATORS, HEAT EXCHANGERS, AND VAPOR COMPRESSOR SHARED WITH S-1372-133

- 1. Tank shall be equipped with a vapor loss prevention system consisting of vapor and condensate collection systems capable of reducing volatile organic compound (VOC) emissions by at least 99%. [District Rule 2201]
- 2. Tank vapors shall compressed and transported to vapor control system listed on S-1372-100. [District Rule 2201]
- 3. Tank gauging or sampling port shall be equipped with a gas-tight cover (as defined in Rule 4623) which shall be closed at all times except during gauging, sampling or attended maintenance operations. [District Rule 4623]
- 4. All piping, valves and fittings shall be constructed and maintained in a gas-tight condition (as defined in Rule 4623). [District Rule 4623]
- 5. True vapor pressure of liquids stored shall not exceed 1.6 psia. [District Rule 2201]
- 6. Average daily throughput on an annual basis shall not exceed 9000 bbl/day of oil. [District Rule 2201]
- 7. Volatile organic compound (VOC) emissions shall not exceed 0.7 lb/day. [District Rule 2201]
- 8. Permittee shall maintain accurate records of daily throughput, true vapor pressure, and temperature of liquids stored and shall make such records available for District inspection for two years. [District Rule 2201 & 4623]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-135-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

420,000 GALLON FIXED ROOF SUMP TANK WITH VAPOR RECOVERY SYSTEM SHARED WITH S-1372-128

- Pressure/vacuum relief valves shall be set to open at 2 oz. pressure and 0.5 oz. vacuum. [District Rule 4623], [Federally Enforceable Through Title V]
- 2. True vapor pressure (TVP) of any liquid placed, stored or held in the tank shall not exceed 1.60 psia. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. There shall be no truck loading or unloading at this facility. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Facility piping system shall be routinely inspected for leaks and all leaks shall be promptly repaired. [District NSR Rule], [Federally Enforceable Through Title V]
- Vapor control system efficiency shall be maintained at no less than 99% by weight. [District NSR Rule], [Federally Enforceable Through Title
 V]
- 6. Average daily throughput shall not exceed 30,300 bbl/day of fluid. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Vapor compressor shall activate whenever tank internal pressure exceeds 2 oz./square inch. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Vapor collection system shall not discharge to atmosphere except during breakdown conditions pursuant to Rule 1100. [District Rule 1100], [Federally Enforceable Through Title V]
- 9. Liquids from gas/liquid separators shall be pumped back to tanks. [District NSR Rule], [Federally Enforceable Through Title V]
- 10. VOC emission rate shall not exceed 0.87 lb/hr. [District NSR Rule], [Federally Enforceable Through Title V]
- 11. Any tank gauging or sampling device on a tank vented to the vapor recovery system shall be equipped with a gas-tight cover which shall be closed at all times except during gauging or sampling. Gas-tight shall be defined as emitting no more than 10,000 ppm of methane measured at a distance of one centimeter from the potential source with an instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this limit shall be considered a leak. [District Rule 4623, 5.3.2], [Federally Enforceable Through Title V]
- All piping, valves and fittings shall be constructed and maintained in a gas-tight condition. Gas-tight shall be defined as emitting no more than 10,000 ppm of methane measured at a distance of one centimeter from the potential source with an instrument calibrated with methane in accordance with EPA Method 21. Emissions in excess of this limit shall be considered a leak. [District Rule 4623, 5.3.3], [Federally Enforceable Through Title V]
- 13. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 14. A facility operator, upon detection of a leaking component, shall affix to that component a weatherproof readily visible tag bearing the date on which the leak is detected. The tag shall remain in place until the leaking component is repaired, reinspected and found to be in compliance with the requirements of this rule. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 15. An operator shall reinspect a component for leaks within thirty working days after the date on which the component is repaired. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 16. Emissions from components which have been tagged by the facility operator for repair within 15 calendar days or which have been repaired and are awaiting re-inspection shall not be in violation of this permit. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

- 17. Any component leak shall be repaired to a leak-free condition or vented to a flare satisfying the requirements of 40 CFR 60.18 or to a vapor control device that is at least 95 percent efficient as measured by EPA Method 25 within fifteen (15) calendar days of detection. The APCO may grant a ten (10) calendar day extension provided the operator demonstrates that necessary and sufficient actions are being taken to correct the leak within this time period. Any vapor control device, other than a flare, used to comply with this condition shall demonstrate at least 95% control efficiency as measured by EPA Method 25 at least annually. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 18. If the leaking component is an essential part of a critical process unit which cannot be immediately shut down for repairs, the operator shall 1) Minimize the leak within 15 calendar days; and 2) If the leak which has been minimized still exceeds the concentration allowed by this permit, the essential component shall be repaired to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection. A critical process unit is any process unit which would result in the automatic shutdown of other process units if it were shut down. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 19. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired; 4) Identification and location of essential parts of critical process units found leaking that cannot be repaired until the next process unit turnaround; and 5) Method used to minimize the leak from essential parts of critical process units which cannot be repaired until the next process unit turnaround. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 20. Operator shall keep a record of liquids stored in each container, storage temperature and the Reid vapor pressure of such liquids. [District Rule 4623, 6.1], [Federally Enforceable Through Title V]
- 21. True vapor pressure shall be measured using Reid vapor pressure ASTM Method D323-82 modified by maintaining the hot water bath at storage temperature. Where storage temperature is above 100 degrees F true vapor pressure shall be determined by Reid vapor pressure at 100 degrees F and ARB approved calculations. [District Rule 4623, 6.2.2], [Federally Enforceable Through Title V]
- 22. True vapor pressure of crude oil with an API (American Petroleum Institute) gravity less than 30 deg, as determined by API 2547, may be determined by Headspace Gas Chromatography using the procedures from ARB Evaluation of a Method for Determining Vapor Pressures of Petroleum Mixtures by Headspace Gas Chromatography, October 1990. [District Rule 4623, 6.2.3], [Federally Enforceable Through Title V]
- 23. Control efficiency shall be determined by a comparison of controlled emissions to those emissions which would occur from a fixed or cone roof tank in the same product service without a vapor recovery system. Emissions shall be determined based on tank emission factors in EPA Publication AP-42, component counts for fugitive emissions sources, recognized emission factors for fugitive emission sources and the efficiency of any VOC destruction device. [District Rule 4623, 6.2.4], [Federally Enforceable Through Title V]
- 24. The efficiency of any VOC destruction device shall be measured by EPA Method 25, 25a, or 25b. [District Rule 4623, 6.2.5], [Federally Enforceable Through Title V]
- 25. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. The operator of a fixed roof tank shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 27. Operator shall maintain all records for at least five years and conform to the recordkeeping requirements described in District Rule 2520. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 28. Operator shall monitor vapor recovery compressor activation and shut off manometer pressures on quarterly basis to ensure that compressor activation pressure does not exceed pressure relief valve setting. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. Operator shall keep accurate records of types of liquids stored in each container, storage temperature, daily throughput, and the true vapor pressure of such liquids. [District Rules 4623, 6.1 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. This unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 33. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 4623 (Amended December 17, 1992). A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-136-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

60.5 HP AIR FLOTATION OIL/WATER SEPARATOR SERVED BY VAPOR RECOVERY SYSTEM LISTED ON PERMIT UNIT S-1372-128

- 1. The operator shall keep accurate records of types, storage temperature and Reid vapor pressure of liquids stored. [District Rule 4623]
- 2. Pressure/vacuum relief valves shall be set to open at 2 oz. pressure and 0.5 oz. vacuum. [District Rule 4623]
- 3. True vapor pressure (TVP) of any liquid placed, stored or held in the tank shall not exceed 1.60 psia. [District Rule 2201]
- 4. Noncondensible vapors shall be incinerated in gas fired steam generator permit unit S-1372-127. [District Rule 2201]
- 5. There shall be no truck loading or unloading at this facility. [District Rule 2201]
- 6. Facility piping system shall be routinely inspected for leaks and all leaks shall be promptly repaired. [District Rule 2201]
- 7. Vapor control system efficiency shall be maintained at no less than 99% by weight. [District Rule 2201]
- 8. Vapor collection system shall not discharge to atmosphere except during breakdown conditions pursuant to Rule 1100. [District Rule 1100]
- 9. Liquids from gas/liquid separators shall be pumped back to tanks. [District Rule 2201]
- 10. VOC emission rate shall not exceed 0.05 lbm/hr. [District Rule 2201]
- 11. The air floatation unit shall be enclosed and vapor tight. [District Rule 4623]
- 12. The air floatation unit shall keep all doors, hatches, and access holes closed at all times except during breakdowns or maintenance. [District Rule 4623]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-137-5 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

25.2 MMBTU/HR TEOR GAS/NATURAL GAS FIRED STEAM GENERATOR. (RULE 4305, GROUP II UNIT)

- 1. This equipment shall not be operated for any reason until necessary retrofits are made to comply with the applicable requirements of District Rule 4305. [District Rule 4305]
- 2. No modification to this unit shall be performed without an Authority to Construct for that modification(s), except for changes specified in condition 3 below. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. The fuel supply line shall be physically disconnected from this unit. [District Rule 2080], [Federally Enforceable Through Title V]
- 4. Emissions from this unit shall not exceed any of the following: NOx (as NO2): 30 ppmv @3% O2; or CO: 400 ppmv @3% O2. [District Rule 4305]
- 5. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. This unit shall not be operated unless the owner or operator applies to modify the Title V permit to address the requirements of District Rule 2520 section 9.0 for this permit unit. [District Rule 2520, Section 9.0], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-138-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

21,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#MC-11)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-139-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

10.0 MMBTU/HR NATURAL GAS/LPG FIRED HEATER TREATER #1 (#25118): WITH TWO 5 MMBTU/HR KVAERNER-ZINK LOW NOX FORCED DRAFT BURNERS WITH FGR AND FUEL INDUCED FGR & TWO STACKS & PLC AUTOMATED CONTROLS

- 1. Emissions shall not exceed any of the following: NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2; or CO: 150 ppmv @ 3% O2. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least once a calendar quarter or on an alternate schedule as approved by the APCO using District approved portable analyzers. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of no less than five years and shall be made readily available for District inspection upon request. [District Rules 1070], [Federally Enforceable Through Title V]
- 4. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081, and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 6. Operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 7. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2, 5.3, and 5.5 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 8. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 9. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 10. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 11. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 12. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072-80, D 3031-81, D 4084-82, D 3246-81 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. If the unit is fired on non-certified liquid fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the liquid fuel being fired in the unit shall be determined using ASTM D 2880-71. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 14. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

- 15. Annual source testing shall be performed for NOx (ppmv) according to EPA Method 7E (or ARB Method 100), stack gas oxygen by EPA Method 3 or 3A (or ARB Method 100), and NOx emission rate (heat input basis) by EPA Method 19, and for CO according to EPA Method 10 (or ARB Method 100). Gaseous fired units demonstrating compliance on 2 consecutive annual tests shall be tested not less than once every 36 months. Annual testing shall resume if any such test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 16. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 18. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 19. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rule 108.1 (Kern) and 404 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 20. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-140-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

6 MMBTU/HR NATURAL GAS FIRED HEATER TREATER (#2 #25127)

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 3.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Heater treater shall be fired exclusively on natural gas or LPG and shall have no provisions for firing on fuel oil. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081, and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 4. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 6. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1], [Federally Enforceable Through Title V]
- 8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 11. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]

- 14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rule 108.1 (Kern) and 404 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 16. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-141-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

8.4 MMBTU/HR NATURAL GAS FIRED HEATER TREATER (#3 #10355)

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 3.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Heater treater shall be fired exclusively on natural gas or LPG and shall have no provisions for firing on fuel oil. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081, and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 4. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 6. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1], [Federally Enforceable Through Title V]
- 8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 11. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]

- 14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rule 108.1 (Kern) and 404 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 16. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-142-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

10 MMBTU/HR NATURAL GAS FIRED HEATER TREATER (#4 #10356)

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 3.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Heater treater shall be fired exclusively on natural gas or LPG and shall have no provisions for firing on fuel oil. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081, and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 4. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 6. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1], [Federally Enforceable Through Title V]
- 8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 11. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]

- 14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rule 108.1 (Kern) and 404 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 16. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-143-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

8.4 MMBTU/HR NATURAL GAS FIRED HEATER TREATER (#5 #10357)

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 3.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Heater treater shall be fired exclusively on natural gas or LPG and shall have no provisions for firing on fuel oil. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081, and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 4. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 6. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1], [Federally Enforceable Through Title V]
- 8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 11. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]

- 14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rule 108.1 (Kern) and 404 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 16. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-144-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

8 MMBTU/HR NATURAL GAS FIRED HEATER TREATER (#6 #10278)

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 3.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Heater treater shall be fired exclusively on natural gas or LPG and shall have no provisions for firing on fuel oil. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081, and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 4. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 6. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1], [Federally Enforceable Through Title V]
- 8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 11. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]

- 14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rule 108.1 (Kern) and 404 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 16. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-145-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

6 MMBTU/HR NATURAL GAS FIRED HEATER TREATER (#1 #25038) - KEENE WILLIAMS LEASE

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 3.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Heater treater shall be fired exclusively on natural gas or LPG and shall have no provisions for firing on fuel oil. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081, and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 4. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 6. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1], [Federally Enforceable Through Title V]
- 8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 11. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]

- 14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rule 108.1 (Kern) and 404 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 16. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-146-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

8 MMBTU/HR NATURAL GAS FIRED HEATER TREATER (#2 #10290)

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 3.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Heater treater shall be fired exclusively on natural gas or LPG and shall have no provisions for firing on fuel oil. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081, and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 4. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 6. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1], [Federally Enforceable Through Title V]
- 8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 11. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]

- 14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rule 108.1 (Kern) and 404 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 16. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-147-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

8.4 MMBTU/HR NATURAL GAS FIRED HEATER TREATER (#1 #25058)

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 3.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Heater treater shall be fired exclusively on natural gas or LPG and shall have no provisions for firing on fuel oil. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081, and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 4. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 6. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1], [Federally Enforceable Through Title V]
- 8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 11. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]

- 14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rule 108.1 (Kern) and 404 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 16. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-148-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

8 MMBTU/HR NATURAL GAS FIRED HEATER TREATER (#1 #25035)

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 3.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Heater treater shall be fired exclusively on natural gas or LPG and shall have no provisions for firing on fuel oil. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081, and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 4. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 6. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1], [Federally Enforceable Through Title V]
- 8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 11. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]

- 14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rule 108.1 (Kern) and 404 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 16. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-149-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

6 MMBTU/HR NATURAL GAS FIRED HEATER TREATER (#1 #10310)

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 3.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Heater treater shall be fired exclusively on natural gas or LPG and shall have no provisions for firing on fuel oil. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081, and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 4. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 6. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1], [Federally Enforceable Through Title V]
- 8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 11. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]

- 14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rule 108.1 (Kern) and 404 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 16. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-150-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

7.0 MMBTU/HR NATURAL GAS/LPG FIRED HEATER TREATER #2 (#20119, MCKITTRICK UNIT) INCLUDING: 3-STAGE KVAERNER-HRI LOW NOX FORCED DRAFT BURNER WITH FLUE GAS RECIRCULATION AND PLC AUTOMATED CONTROLS

- 1. Emissions shall not exceed any of the following: NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2; or CO: 150 ppmv @ 3% O2. [District Rule 4305], [Federally Enforceable Through Title V]
- 2. Source testing to measure NOx and CO emissions shall be conducted not less than once every 12 months thereafter, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 3. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 4. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 5. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305], [Federally Enforceable Through Title V]
- 6. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 7. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 8. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 9. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, and stack gas oxygen EPA Method 3 or 3A or ARB Method 100. [District Rules 1081 and 4305], [Federally Enforceable Through Title V]
- 10. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 11. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of no less than five years and shall be made readily available for District inspection upon request. [District Rules 1070 and 4305], [Federally Enforceable Through Title V]
- 12. If the NOx and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed for more than one hour the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 13. All required source testing shall conform to the compliance testing procedures described in District Rule 1081(Last Amended December 19,1993). [District Rule 1081, and County Rule 108.1 (Kern,)], [Federally Enforceable Through Title V]
- 14. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 15. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]

- 16. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 17. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 18. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 19. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072-80, D 3031-81, D 4084-82, D 3246-81 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 20. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826-88 or D 1945-81 in conjunction with ASTM D 3588-89 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1], [Federally Enforceable Through Title V]
- 21. Nitrogen oxide (NOx) emission concentrations in ppmv shall be referenced at dry stack gas conditions, and shall be calculated to 3.00 percent by volume stack gas oxygen and averaged over 60 minutes, and lb/MMBtu rates shall be calculated as lb NO2/MMBtu of heat input (hhv). [District Rule 4305, 5.0, 8.2 and/or 4351, 8.1], [Federally Enforceable Through Title V]
- 22. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 23. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 24. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108.1 (Kern), 424 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 25. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 26. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 27. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2 and 4351, 6.3], [Federally Enforceable Through Title V]
- 28. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 29. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 30. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]

31.	The number of representative units source tested to demonstrate compliance for NOx limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
	NUEVO ENERGY COMPANY S-1372-150-1

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-151-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

8 MMBTU/HR NATURAL GAS FIRED HEATER TREATER (#1 #20120)

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 3.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Heater treater shall be fired exclusively on natural gas or LPG and shall have no provisions for firing on fuel oil. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081, and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 4. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 6. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1], [Federally Enforceable Through Title V]
- 8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 11. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]

- 14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rule 108.1 (Kern) and 404 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 16. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-152-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

6 MMBTU/HR NATURAL GAS FIRED HEATER TREATER (#1 #10293)

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 3.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Heater treater shall be fired exclusively on natural gas or LPG and shall have no provisions for firing on fuel oil. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Amended December 16, 1993). [District Rule 1081, and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 4. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 6. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.4.2 and 4301, 5.2.1], [Federally Enforceable Through Title V]
- 8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 11. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]

- 14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 15. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of County Rule 108.1 (Kern) and 404 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 16. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-153-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

525 GALLON FIXED ROOF SCALE INHIBITOR STORAGE TANK (#T-155)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. At least once per year, the true vapor pressure of the organic liquid stored in the tank shall be certified by a third party supplier or the operator. In accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92), determinations shall be made annually during summer and whenever there is a change in the source or type of organic liquid entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 3. As used in this permit, the term "source or type of organic" shall mean organic liquids with similar characteristics. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 4. Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 10,667 gallons. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-154-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

525 GALLON FIXED ROOF BACKWASH SOAP STORAGE TANK (#SC-14) - CANCELLED PER 1/16/97 LETTER. PLY

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. The true vapor pressure (TVP) of liquids stored in the tank shall not exceed 1.5 psi. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-155-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

300 GALLON FIXED ROOF STORAGE TANK (2-DMO-4128F)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. At least once per year, the true vapor pressure of the organic liquid stored in the tank shall be certified by a third party supplier or the operator. In accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92), determinations shall be made annually during summer and whenever there is a change in the source or type of organic liquid entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 3. As used in this permit, the term "source or type of organic" shall mean organic liquids with similar characteristics. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 4. Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 10,667 gallons. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-156-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

300 GALLON FIXED ROOF STORAGE TANK (1-DMO-4128F)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. At least once per year, the true vapor pressure of the organic liquid stored in the tank shall be certified by a third party supplier or the operator. In accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92), determinations shall be made annually during summer and whenever there is a change in the source or type of organic liquid entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 3. As used in this permit, the term "source or type of organic" shall mean organic liquids with similar characteristics. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 4. Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 10,667 gallons. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-157-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

300 GALLON FIXED ROOF STORAGE TANK (4-DMO-O675K)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. At least once per year, the true vapor pressure of the organic liquid stored in the tank shall be certified by a third party supplier or the operator. In accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92), determinations shall be made annually during summer and whenever there is a change in the source or type of organic liquid entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 3. As used in this permit, the term "source or type of organic" shall mean organic liquids with similar characteristics. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 4. Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 10,667 gallons. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-158-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

300 GALLON FIXED ROOF STORAGE TANK (1-RBW-0239A)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. At least once per year, the true vapor pressure of the organic liquid stored in the tank shall be certified by a third party supplier or the operator. In accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92), determinations shall be made annually during summer and whenever there is a change in the source or type of organic liquid entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 3. As used in this permit, the term "source or type of organic" shall mean organic liquids with similar characteristics. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 4. Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 10,667 gallons. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-159-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

300 GALLON FIXED ROOF STORAGE TANK (2-DMO-0599F)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. At least once per year, the true vapor pressure of the organic liquid stored in the tank shall be certified by a third party supplier or the operator. In accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92), determinations shall be made annually during summer and whenever there is a change in the source or type of organic liquid entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 3. As used in this permit, the term "source or type of organic" shall mean organic liquids with similar characteristics. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 4. Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 10,667 gallons. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-160-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

37,800 GALLON FREE WATER KNOCKOUT VESSEL (#25039) - CANCELLED PER 2/4/97 LETTER. PLY

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. The true vapor pressure (TVP) of liquids stored in the tank shall not exceed 1.5 psi. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-161-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

10,500 GALLON FREE WATER KNOCKOUT VESSEL (#10522) - CANCELLED PER 2/4/97 LETTER. PLY

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. The true vapor pressure (TVP) of liquids stored in the tank shall not exceed 1.5 psi. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-162-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

37,800 GALLON FREE WATER KNOCKOUT VESSEL (#25057) - CANCELLED PER 2/4/97 LETTER. PLY

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. The true vapor pressure (TVP) of liquids stored in the tank shall not exceed 1.5 psi. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-163-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

33,600 GALLON FREE WATER KNOCKOUT VESSEL (#25062) - CANCELLED PER 2/4/97 LETTER. PLY

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. The true vapor pressure (TVP) of liquids stored in the tank shall not exceed 1.5 psi. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-164-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

33,600 GALLON FREE WATER KNOCKOUT VESSEL (#10278) - CANCELLED PER 2/4/97 LETTER. PLY

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. The true vapor pressure (TVP) of liquids stored in the tank shall not exceed 1.5 psi. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-165-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

33,600 GALLON FREE WATER KNOCKOUT VESSEL (#10309) - CANCELLED PER 2/4/97 LETTER. PLY

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. The true vapor pressure (TVP) of liquids stored in the tank shall not exceed 1.5 psi. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-166-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

33,600 GALLON FREE WATER KNOCKOUT VESSEL (#10308) - CANCELLED PER 2/4/97 LETTER. PLY

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. The true vapor pressure (TVP) of liquids stored in the tank shall not exceed 1.5 psi. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-167-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

6,300 GALLON FREE WATER KNOCKOUT VESSEL (#20116) - CANCELLED PER 2/4/97 LETTER. PLY

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. The true vapor pressure (TVP) of liquids stored in the tank shall not exceed 1.5 psi. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-168-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

33,600 GALLON FREE WATER KNOCKOUT VESSEL (#10292) - CANCELLED PER 2/4/97 LETTER. PLY

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. The true vapor pressure (TVP) of liquids stored in the tank shall not exceed 1.5 psi. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-169-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

39,900 GALLON FREE WATER KNOCKOUT VESSEL (#25119) - CANCELLED PER 2/4/97 LETTER. PLY.

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. The true vapor pressure (TVP) of liquids stored in the tank shall not exceed 1.5 psi. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-170-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

6,830 GALLON FREE WATER KNOCKOUT VESSEL (#25128) - CANCELLED PER 2/4/97 LETTER. PLY

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. The true vapor pressure (TVP) of liquids stored in the tank shall not exceed 1.5 psi. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-172-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

37,800 GALLON FREE WATER KNOCKOUT VESSEL (#10354) - CANCELLED PER 2/4/97 LETTER. PLY

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. The true vapor pressure (TVP) of liquids stored in the tank shall not exceed 1.5 psi. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-173-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

37,800 GALLON FREE WATER KNOCKOUT VESSEL (#10353) - CANCELLED PER 2/4/97 LETTER. PLY

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. The true vapor pressure (TVP) of liquids stored in the tank shall not exceed 1.5 psi. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-174-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

37,800 GALLON FREE WATER KNOCKOUT VESSEL (#10352) - CANCELLED PER 2/4/97 LETTER. PLY

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. The true vapor pressure (TVP) of liquids stored in the tank shall not exceed 1.5 psi. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-175-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

37,800 GALLON FREE WATER KNOCKOUT VESSEL (#01279) - CANCELLED PER 2/4/97 LETTER. PLY

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. The true vapor pressure (TVP) of liquids stored in the tank shall not exceed 1.5 psi. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-176-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

37,800 GALLON FREE WATER KNOCKOUT VESSEL (#10351) - CANCELLED PER 2/4/97 LETTER. PLY

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. The true vapor pressure (TVP) of liquids stored in the tank shall not exceed 1.5 psi. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-186-2 EXPIRATION DATE: 05/31/2007

EQUIPMENT DECRIPTION:

GASOLINE DISPENSING FACILITY WITH ONE 10,000 GALLON FIREGUARD ABOVEGROUND STORAGE TANK SERVED BY TWO-POINT PHASE I AND AND BALANCE PHASE II VAPOR RECOVERY SYSTEM (G-70-162-A) AND TWO FUELING POINTS WITH TWO GASOLINE DISPENSING NOZZLES

- 1. Aboveground storage tank(s) shall be equipped with pressure/vacuum valves set to within 10 percent of the maximum working pressure of the tank. [District Rule 4621], [Federally Enforceable Through Title V]
- 2. The permittee shall perform and pass a Static Pressure Decay Test using BAAQMD Method ST-38 at least once every 12 months. [District Rule 4622], [Federally Enforceable Through Title V]
- 3. The District shall be notified by the permittee 15 days prior to each test. The test results shall be submitted to the District no later than 30 days after each test. [District Rule 1081], [Federally Enforceable Through Title V]
- 4. The vapor recovery systems and their components shall be operated and maintained in accordance with the State certification requirements. [District Rules 4621 and 4622], [Federally Enforceable Through Title V]
- 5. This gasoline storage and dispensing equipment shall not be used in retail sales, where gasoline dispensed by the unit is subject to payment of California sales tax on gasoline sales. [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 6. Each gasoline storage tank shall be equipped with a permanent submerged fill pipe. [District Rule 4621, 5.1.1], [Federally Enforceable Through Title V]
- 7. Each storage tank subject to this permit shall be equipped with an ARB certified Phase I vapor recovery system, which shall prevent at least 95% by weight of all gasoline vapors displaced during the filling of storage tanks from entering the atmosphere. The transfer of gasoline from any delivery vessel to any stationary storage container with 250 gallon capacity or more shall not be allowed unless the container is equipped with an ARB certified Phase 1 system and maintained and operated according to manufacturers specifications. [District Rule 4621, 3.1 and 5.1.1], [Federally Enforceable Through Title V]
- 8. No gasoline delivery vessel shall be operated or be allowed to operate unless valid State of California decals are displayed on the cargo tank which attest to the vapor integrity of the tank. [District Rule 4621, 5.2.1], [Federally Enforceable Through Title V]
- 9. Each dispensing system shall be equipped with an ARB certified Phase II vapor recovery system which shall prevent at least 95% by weight of all gasoline vapors displaced during refueling of vehicles from entering the atmosphere. [District Rule 4622, 5.1], [Federally Enforceable Through Title V]
- 10. Compliance with the requirement of the Phase II system to be 95% effective for displaced vapors is considered to be demonstrated by passing performance tests, at least once every year from the date of the most recent test, or at more frequent intervals, as specified by the ARB Executive Order certifying the system. [District Rules 2520, 9.4.2 and 4622, 5.2, 6.2. 6.3], [Federally Enforceable Through Title V]
- 11. Each ARB certified vapor recovery system shall be tested within 60 days of major modification or installation, except as otherwise allowed by this permit. For this condition, a major modification is considered to be replacing, repairing, or upgrading 75% or more of the certified system. [District Rule 4622, 6.2.2], [Federally Enforceable Through Title V]
- 12. The ARB certified vapor recovery system and all of its components shall be maintained in good repair. Any ARB certified gasoline vapor recovery system, which has been installed and has been issued a permit to operate, shall not be removed regardless of the amount of gasoline dispensed or how the gasoline is delivered to the facility. [District Rule 4622, 5.3], [Federally Enforceable Through Title V]
- 13. No gasoline shall be transferred into vehicle fuel tanks if the vapor recovery system contains any defect listed in Section 94006 of Title 17 of the California Code of Regulations or in Section 5.4 of SJVUAPCD Rule 4622 (as amended February 17, 1994) until the defect has been repaired, replaced, or adjusted as necessary to correct the defect, and the District has reinspected the system or has authorized its use pending reinspection. [District Rule 4622, 5.4], [Federally Enforceable Through Title V]
- 14. Any defects identified shall be tagged "Out of Order"; the tagged equipment shall be rendered inoperable and the tag(s) shall not be removed until the defect has been repaired, replaced or adjusted. In the case of defects identified by the District, tagged equipment shall be rendered inoperable and the tag shall not be removed until the District has been notified of the repairs, and/or the District has inspected and authorized the tagged equipment for use. A log containing at least the following shall be maintained: date and type of defect identified and date repaired, replaced or corrected. [District Rules 2520, 9.4.2 and 4622, 5.5], [Federally Enforceable Through Title V]

- 15. Vapor recovery systems and gasoline dispensing equipment shall be maintained leak-free as verified using EPA Test Method 21 and visual inspection. Leak testing shall be performed at least annually and within 60 days of all major modifications. For this condition, a major modification is considered to be replacing, repairing, or upgrading 75% or more of the certified system. A leak is defined as the dripping at a rate of more than three (3) drops per minute of liquid containing VOCs or a reading as methane in excess of 10,000 ppm as determined using EPA Method 21. [District Rules 2520, 9.4.2 and 4622, 3.6, 5.6], [Federally Enforceable Through Title V]
- 16. Each operator shall maintain a leak inspection log containing, at a minimum, the following: inspector's name, location and description of component type where any leak is found; date of leak detection, emission level (ppm) if applicable, and date leak is repaired. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 17. No person shall top off a motor vehicle fuel tank. [District Rule 4622, 5.9], [Federally Enforceable Through Title V]
- 18. No owner or operator shall tamper with, or permit tampering with, the ARB certified vapor recovery system in a manner that would impair the operation or effectiveness of the system. [District Rule 4622, 5.11], [Federally Enforceable Through Title V]
- 19. Operator shall maintain all records of required monitoring data and support information for inspection for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 20. Compliance with permit conditions in the Title V permit shall be deemed compliance with County Rule 108.1 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 21. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4621 except section 5.2.2 (as amended May 20, 1993), 4622 (as amended February 17, 1994), and 4623, section 5.4 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 22. This unit is not equipment used for light crude oil and gas production, natural gas processing, nor organic liquid loading. Therefore, the requirements of County Rules 412.1 (Kern), and 413 (Kern), do not apply to this permit unit. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 23. This unit is not equipment used for light crude oil and gas production, natural gas processing, nor organic liquid loading, and is not an internal or external floating roof tank with capacity of 19,800 gallons or more. Therefore, the requirements of District Rules 4403 (as amended February 16, 1995), 4623, except section 5.4 (as amended December 17, 1992), and 4624 (as amended December 17, 1992) do not apply to this permit unit. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 24. This unit is not associated with loading at a bulk gasoline terminal (as defined in 40CFR 60.501). Therefore, the requirements of 40 CFR 60 Subparts XX do not apply to this permit unit. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-187-7 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

3.27 MW COGEN FACILITY W/ SOLAR CENTAUR MODEL T4700, 43.95 MMBTU/HR GAS FIRED TURBINE ENGINE/GENERATOR SET, W/ INLET AIR EVAPORATIVE COOLER, 33.93 MMBTU/HR GAS FIRED DUCT BURNER, HEAT RECOVERY STEAM GENERATOR, AND KOCH COALESCER

- Units shall be fired exclusively on PUC-quality natural gas which has a sulfur content of less than or equal to 0.017% by weight. [40 CFR 60.333(a) & (b);60.332(a); Rule 404 (Madera), 406 (Fresno) and 407 (6 remaining counties in the San Joaquin Valley)], [Federally Enforceable Through Title V]
- Operator shall not discharge into the atmosphere combustion contaminants (PM) exceeding in concentration at the point of discharge, 0.1 gr/dscf. [District Rule 4201; Rule 402 (Madera) and 404 (all 7 remaining counties in the San Joaquin Valley)], [Federally Enforceable Through Title V]
- 3. Operator shall not exceed a NOx emission rate of: A. (If Rating < 10 MW) 42 ppmvd @ 15% O2, excluding thermal stabilization and reduced load periods; B. (If Rating > 10 MW) (15 X EFF/25)ppmvd @ 15% O2, under load conditions, excluding thermal stabilization and reduced load periods, where EFF (efficiency) is the higher of EFF1 {100%x(3412 Btu/kW-hr)/(Actual Heat Rate at HHV, Btu/kW-hr)} or EFF2 {EFFmfr x (LHV/HHV)} where actual heat rate is a ratio of the heat input to power output taking into account the manufacturer's listed turbine efficiency, HHV is the higher heating value of the fuel, LHV is the lower heating value of the fuel, and EFFmfr is the manufacturer's continuous rated percent efficiency of the gas turbine with air pollution equipment at LHV. An EFF that is less than 25 shall be assigned a value of 25. [40 CFR 60.332(a)(1) & 60.332(a)(2) and District Rule 4703, 5.1.1], [Federally Enforceable Through Title V]
- 4. Operator shall be required to conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081; Rule 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), Rule 110 (Madera), and Rule 108 (Kings)], [Federally Enforceable Through Title VI
- 5. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072-80, D 3031-81, D 4084-82 or D 3246-81. [40 CFR 60.335(d)], [Federally Enforceable Through Title V]
- 6. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(b)(2)], [Federally Enforceable Through Title V]
- 7. HHV and LHV of the fuel shall be determined using ASTM D3588-91, ASTM 1826-88, or ASTM 1945-81. [40 CFR 60.335(b) and District Rule 4703, 6.4.5], [Federally Enforceable Through Title V]
- 8. Nitrogen oxides (NOx) concentrations shall be determined using EPA Method 7E or 20, and oxygen (O2) concentrations shall be determined using EPA Method 3, 3A, or 20. [40 CFR 60.335(b) and District Rule 4703, 6.4], [Federally Enforceable Through Title V]
- 9. The operator shall provide source test information annually regarding the exhaust gas NOx concentration corrected to 15% O2 (dry). [40 CFR 60.332(a), (b) and District Rule 4703, 5.1], [Federally Enforceable Through Title V]
- 10. If the unit has a rating greater than or equal to 10.0 MW, operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703, 5.1.1. [40 CFR 60.332(a),(b) and District Rule 4703, 5.1.1], [Federally Enforceable Through Title V]
- 11. Any gas turbine with an intermittently operated auxiliary burner shall demonstrate compliance with the auxiliary burner on and off. [40 CFR 60.335(b) and District Rule 4703, 6.3.2], [Federally Enforceable Through Title V]
- 12. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. The operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 14. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis, the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(a),(b) and District Rule 4703, 6.2.4], [Federally Enforceable Through Title V]

- 15. The following types of units are not affected units subject to the requirements of the Acid Rain Program: 1) A simple combustion turbine that commenced operation before November 15, 1990, 2) Any unit that, during 1985, did not serve a generator that produced electricity for sale and that did not, as of November 15, 1990, and does not currently, serve a generator that produces electricity for sale, 3) A cogeneration facility which for a unit that commenced construction prior to November 15, 1990, was constructed for the purpose of supplying equal to or less than one-third its potential electrical output capacity or equal to or less than 219,000 Mwe-hrs actual electric output on an annual basis to any utility power distribution system for sale. Therefore, the requirements of 40 CFR 72.6 do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 16. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rule 1081, 4201, 3.1; Rules 406 (Fresno), 407 (Kings, San Joaquin, Stanislaus, Tulare, Merced, and Kern), and 404(Madera); 40 CFR 60.332(c), (d); 60.334 (b), and (c)(2); 60.335(d). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 17. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following subsumed requirements: SJVUAPCD Rule 4703, 6.2.2; Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern and Stanislaus), and 110 (Madera); Rules 402 (Madera) and 404 (Fresno, Kern, Kings, San Joaquin, Merced, Stanislaus, Tulare); 40 CFR 60.332 (a) and (b); 60.333(a) and (b); 60.334 (a), (b), and (c)(1); 60.335 (a), (b), (c), and (e). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 18. Compliance with the permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: SJVUAPCD Rule 4703, sections 5.0, 5.1.1, 6.2.1, 6.2.4, 6.3, 6.4.1, 6.4.3, 6.4.5, 6.4.6. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 19. Permittee shall install, operate and maintain in calibration a predictive emissions monitoring system which continuously measures and records the water-to-fuel ratio and which correlates the water-to-fuel ratio with the NOx concentration in the exhaust by using the method described in 40 CFR 60.335(c). [40 CFR 60.334], [Federally Enforceable Through Title V]
- 20. Permittee shall submit to the APCO the information correlating the control system operating parameters to the associated measured NOx output. [District Rule 4703, 6.2.3], [Federally Enforceable Through Title V]
- 21. Permittee shall install, operate and maintain in calibration a system which continuously measures and records elapsed time of turbine operation. [District Rule 4703, 6.2.1], [Federally Enforceable Through Title V]
- 22. The continuous emissions monitoring system shall meet the performance requirements as specified in 40 CFR Part 60 Appendix B, Spec.2. [40 CFR 60.334 and District Rule 4703, 6.2.1], [Federally Enforceable Through Title V]
- 23. Operator shall submit a semiannual report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(c)(2)], [Federally Enforceable Through Title V]
- 24. Permittee shall submit an excess emissions and monitoring systems performance report (excess emissions are defined in applicable subparts) and/or a summary report form to the APCO semiannually, except when more frequent reporting is specifically required by an applicable subpart. All reports shall be postmarked by the 30th day of each calendar half (or quarter, as appropriate). [40 CFR 60.7(c)], [Federally Enforceable Through Title V]
- 25. Any one-hour period during which the average water-to-fuel ratio, as measured by the predictive monitoring system, falls below the water-to-fuel ratio determined to demonstrate compliance shall be reported to the APCO. Each report shall include the average water-to-fuel ratio, average fuel consumption, ambient conditions, turbine gas load and nitrogen content of the fuel during the period of excess emissions. [40 CFR 60.334(c)], [Federally Enforceable Through Title V]
- 26. Gas turbine engine shall be equipped with water injection system. [District NSR Rule], [Federally Enforceable Through Title V]
- 27. Gas turbine engine shall be equipped with continuously recording water injection rate monitor accurate to within +\- 5%. [District NSR Rule], [Federally Enforceable Through Title V]
- 28. Gas turbine engine/duct burner system shall be equipped with recording fuel gas flowmeter. [District NSR Rule], [Federally Enforceable Through Title V]
- 29. Heat input to gas turbine engine/duct burner system shall not exceed 74.81 MM Btu/hr. [District NSR Rule], [Federally Enforceable Through Title V]
- 30. Duct burner fuel gas supply shall be equipped with an operational injection pressure indicator. [District NSR Rule], [Federally Enforceable Through Title V]
- 31. Gas turbine engine and duct burner shall only be fired on PUC quality or equivalent sulfur content natural gas. [District NSR Rule], [Federally Enforceable Through Title V]
- 32. Gas turbine engine shall not be operated when water injection system is not operating. [District NSR Rule], [Federally Enforceable Through Title V]

- 33. Gas turbine engine and duct burner combined emission rate shall not exceed PM10: 0.81 lb/hr, SOx (as SO2): 0.15 lb/hr, NOx (as NO2): 11.00 lb/hr and 42 ppmvd @15% O2, VOC: 1.85 lb/hr, and CO: 8.00 lb/hr and 200 ppmvd @ 15% O2. [District NSR Rule], [Federally Enforceable Through Title V]
- 34. NOx and CO emissions shall be measured annually pursuant to requirements of Rule 4703 by District witnessed sample collection by independent laboratory. Test results shall be submitted within 60 days. [District Rule 4703 and District NSR Rule], [Federally Enforceable Through Title V]
- 35. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100; CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100. [District NSR Rule and District Rule 4703], [Federally Enforceable Through Title V]
- 36. Compliance source testing shall be conducted under conditions representative of normal operation. [District Rule 1081], [Federally Enforceable Through Title V]
- 37. Sampling facilities for source testing shall be provided in accordance with the provisions of Rule 1081 (Source Sampling). [District Rule 1081], [Federally Enforceable Through Title V]
- 38. Permittee shall keep accurate records of the quantity and heating value (btu/scf) of the fuel gas supplied to the gas turbine engine/duct burner system. Such records shall be maintained for a period of five years and shall be made readily available for District inspection upon request. [District NSR Rule], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-188-6 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

3.27 MW COGEN FACILITY W/ SOLAR CENTAUR MODEL T4700 GAS FIRED TURBINE ENGINE GENERATOR SET W/ INLET AIR EVAPORATIVE COOLER, GAS FIRED DUCT BURNER, HEAT RECOVERY STEAM GENERATOR, AND KOCH COALESCER

- Units shall be fired exclusively on PUC-quality natural gas which has a sulfur content of less than or equal to 0.017% by weight. [40 CFR 60.333(a) & (b);60.332(a); Rule 404 (Madera), 406 (Fresno) and 407 (6 remaining counties in the San Joaquin Valley)], [Federally Enforceable Through Title V]
- Operator shall not discharge into the atmosphere combustion contaminants (PM) exceeding in concentration at the point of discharge, 0.1 gr/dscf. [District Rule 4201; Rule 402 (Madera) and 404 (all 7 remaining counties in the San Joaquin Valley)], [Federally Enforceable Through Title V]
- 3. Operator shall not exceed a NOx emission rate of: A. (If Rating < 10 MW) 42 ppmvd @ 15% O2, excluding thermal stabilization and reduced load periods; B. (If Rating > 10 MW) (15 X EFF/25)ppmvd @ 15% O2, under load conditions, excluding thermal stabilization and reduced load periods, where EFF (efficiency) is the higher of EFF1 {100%x(3412 Btu/kW-hr)/(Actual Heat Rate at HHV, Btu/kW-hr)} or EFF2 {EFFmfr x (LHV/HHV)} where actual heat rate is a ratio of the heat input to power output taking into account the manufacturer's listed turbine efficiency, HHV is the higher heating value of the fuel, LHV is the lower heating value of the fuel, and EFFmfr is the manufacturer's continuous rated percent efficiency of the gas turbine with air pollution equipment at LHV. An EFF that is less than 25 shall be assigned a value of 25. [40 CFR 60.332(a)(1) & 60.332(a)(2) and District Rule 4703, 5.1.1], [Federally Enforceable Through Title V]
- 4. Operator shall be required to conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081; Rule 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), Rule 110 (Madera), and Rule 108 (Kings)], [Federally Enforceable Through Title VI
- 5. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072-80, D 3031-81, D 4084-82 or D 3246-81. [40 CFR 60.335(d)], [Federally Enforceable Through Title V]
- 6. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(b)(2)], [Federally Enforceable Through Title V]
- 7. HHV and LHV of the fuel shall be determined using ASTM D3588-91, ASTM 1826-88, or ASTM 1945-81. [40 CFR 60.335(b) and District Rule 4703, 6.4.5], [Federally Enforceable Through Title V]
- 8. Nitrogen oxides (NOx) concentrations shall be determined using EPA Method 7E or 20, and oxygen (O2) concentrations shall be determined using EPA Method 3, 3A, or 20. [40 CFR 60.335(b) and District Rule 4703, 6.4], [Federally Enforceable Through Title V]
- 9. The operator shall provide source test information annually regarding the exhaust gas NOx concentration corrected to 15% O2 (dry). [40 CFR 60.332(a), (b) and District Rule 4703, 5.1], [Federally Enforceable Through Title V]
- 10. If the unit has a rating greater than or equal to 10.0 MW, operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703, 5.1.1. [40 CFR 60.332(a),(b) and District Rule 4703, 5.1.1], [Federally Enforceable Through Title V]
- 11. Any gas turbine with an intermittently operated auxiliary burner shall demonstrate compliance with the auxiliary burner on and off. [40 CFR 60.335(b) and District Rule 4703, 6.3.2], [Federally Enforceable Through Title V]
- 12. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. The operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 14. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis, the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(a),(b) and District Rule 4703, 6.2.4], [Federally Enforceable Through Title V]

- 15. The following types of units are not affected units subject to the requirements of the Acid Rain Program: 1) A simple combustion turbine that commenced operation before November 15, 1990, 2) Any unit that, during 1985, did not serve a generator that produced electricity for sale and that did not, as of November 15, 1990, and does not currently, serve a generator that produces electricity for sale, 3) A cogeneration facility which for a unit that commenced construction prior to November 15, 1990, was constructed for the purpose of supplying equal to or less than one-third its potential electrical output capacity or equal to or less than 219,000 Mwe-hrs actual electric output on an annual basis to any utility power distribution system for sale. Therefore, the requirements of 40 CFR 72.6 do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 16. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rule 1081, 4201, 3.1; Rules 406 (Fresno), 407 (Kings, San Joaquin, Stanislaus, Tulare, Merced, and Kern), and 404(Madera); 40 CFR 60.332(c), (d); 60.334 (b), and (c)(2); 60.335(d). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 17. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following subsumed requirements: SJVUAPCD Rule 4703, 6.2.2; Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern and Stanislaus), and 110 (Madera); Rules 402 (Madera) and 404 (Fresno, Kern, Kings, San Joaquin, Merced, Stanislaus, Tulare); 40 CFR 60.332 (a) and (b); 60.333(a) and (b); 60.334 (a), (b), and (c)(1); 60.335 (a), (b), (c), and (e). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 18. Compliance with the permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: SJVUAPCD Rule 4703, sections 5.0, 5.1.1, 6.2.1, 6.2.4, 6.3, 6.4.1, 6.4.3, 6.4.5, 6.4.6. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 19. Permittee shall install, operate and maintain in calibration a predictive emissions monitoring system which continuously measures and records the water-to-fuel ratio and which correlates the water-to-fuel ratio with the NOx concentration in the exhaust by using the method described in 40 CFR 60.335(c). [40 CFR 60.334], [Federally Enforceable Through Title V]
- 20. Permittee shall submit to the APCO the information correlating the control system operating parameters to the associated measured NOx output. [District Rule 4703, 6.2.3], [Federally Enforceable Through Title V]
- 21. Permittee shall install, operate and maintain in calibration a system which continuously measures and records elapsed time of turbine operation. [District Rule 4703, 6.2.1], [Federally Enforceable Through Title V]
- 22. The continuous emissions monitoring system shall meet the performance requirements as specified in 40 CFR Part 60 Appendix B, Spec.2. [40 CFR 60.334 and District Rule 4703, 6.2.1], [Federally Enforceable Through Title V]
- 23. Operator shall submit a semiannual report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(c)(2)], [Federally Enforceable Through Title V]
- 24. Permittee shall submit an excess emissions and monitoring systems performance report (excess emissions are defined in applicable subparts) and/or a summary report form to the APCO semiannually, except when more frequent reporting is specifically required by an applicable subpart. All reports shall be postmarked by the 30th day of each calendar half (or quarter, as appropriate). [40 CFR 60.7(c)], [Federally Enforceable Through Title V]
- Any one-hour period during which the average water-to-fuel ratio, as measured by the predictive monitoring system, falls below the water-to-fuel ratio determined to demonstrate compliance shall be reported to the APCO. Each report shall include the average water-to-fuel ratio, average fuel consumption, ambient conditions, turbine gas load and nitrogen content of the fuel during the period of excess emissions. [40 CFR 60.334(c)], [Federally Enforceable Through Title V]
- 26. Gas turbine engine shall be equipped with water injection system. [District NSR Rule], [Federally Enforceable Through Title V]
- 27. Gas turbine engine shall be equipped with continuously recording water injection rate monitor accurate to within +\- 5%. [District NSR Rule], [Federally Enforceable Through Title V]
- 28. Gas turbine engine/duct burner system shall be equipped with recording fuel gas flowmeter. [District NSR Rule], [Federally Enforceable Through Title V]
- 29. Heat input to gas turbine engine/duct burner system shall not exceed 74.81 MM Btu/hr. [District NSR Rule], [Federally Enforceable Through Title V]
- 30. Duct burner fuel gas supply shall be equipped with an operational injection pressure indicator. [District NSR Rule], [Federally Enforceable Through Title V]
- 31. Gas turbine engine and duct burner shall only be fired on PUC quality or equivalent sulfur content natural gas. [District NSR Rule], [Federally Enforceable Through Title V]
- 32. Gas turbine engine shall not be operated when water injection system is not operating. [District NSR Rule], [Federally Enforceable Through Title V]

- 33. Gas turbine engine and duct burner combined emission rate shall not exceed PM10: 0.81 lb/hr, SOx (as SO2): 0.15 lb/hr, NOx (as NO2): 11.00 lb/hr and 42 ppmvd @15% O2, VOC: 1.85 lb/hr, and CO: 8.00 lb/hr and 200 ppmvd @ 15% O2. [District NSR Rule], [Federally Enforceable Through Title V]
- 34. NOx and CO emissions shall be measured annually pursuant to requirements of Rule 4703 by District witnessed sample collection by independent laboratory. Test results shall be submitted within 60 days. [District Rule 4703 and District NSR Rule], [Federally Enforceable Through Title V]
- 35. Source testing to measure oxides of nitrogen (ppmv) shall be conducted using EPA Method 7E, or ARB Method 100. [District NSR Rule and District Rule 4703], [Federally Enforceable Through Title V]
- 36. Source testing to measure carbon monoxide (ppmv) shall be conducted using EPA Method 10, or ARB Method 100. [District NSR Rule and District Rule 4703], [Federally Enforceable Through Title V]
- 37. Source testing to measure stack gas oxygen shall be conducted using EPA Method 3 or 3A, or ARB Method 100. [District NSR Rule and District Rule 4703], [Federally Enforceable Through Title V]
- 38. Compliance source testing shall be conducted under conditions representative of normal operation. [District Rule 1081], [Federally Enforceable Through Title V]
- 39. Sampling facilities for source testing shall be provided in accordance with the provisions of Rule 1081 (Source Sampling). [District Rule 1081], [Federally Enforceable Through Title V]
- 40. Permittee shall keep accurate records of the quantity and heating value (btu/scf) of the fuel gas supplied to the gas turbine engine/duct burner system, and, upon request, shall make such records available for District inspection. [District NSR Rule], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-194-8 EXPIRATION DATE: 05/31/2007

EQUIPMENT DECRIPTION:

4.72 MW COGEN FACILITY INCLUDING 56.27 MM BTU/HR SOLAR TAURUS 60-T73005 GAS FIRED TURBINE ENGINE GENERATOR SET WITH SOLONOX COMBUSTORS, 31 MMBTU/HR GAS FIRED DUCT BURNER, AND HEAT RECOVERY STEAM GENERATOR

- 1. Units shall be fired exclusively on PUC-quality natural gas which has a sulfur content of less than or equal to 0.017% by weight. [40 CFR 60.333(a) & (b);60.332(a); Rule 404 (Madera), 406 (Fresno) and 407 (6 remaining counties in the San Joaquin Valley)], [Federally Enforceable Through Title V]
- Operator shall not discharge into the atmosphere combustion contaminants (PM) exceeding in concentration at the point of discharge, 0.1 gr/dscf. [District Rule 4201; Rule 402 (Madera) and 404 (all 7 remaining counties in the San Joaquin Valley)], [Federally Enforceable Through Title V]
- 3. Operator shall not exceed a NOx emission rate of: A. (If Rating < 10 MW) 42 ppmvd @ 15% O2, excluding thermal stabilization and reduced load periods; B. (If Rating > 10 MW) (15 X EFF/25)ppmvd @ 15% O2, under load conditions, excluding thermal stabilization and reduced load periods, where EFF (efficiency) is the higher of EFF1 {100%x(3412 Btu/kW-hr)/(Actual Heat Rate at HHV, Btu/kW-hr)} or EFF2 {EFFmfr x (LHV/HHV)} where actual heat rate is a ratio of the heat input to power output taking into account the manufacturer's listed turbine efficiency, HHV is the higher heating value of the fuel, LHV is the lower heating value of the fuel, and EFFmfr is the manufacturer's continuous rated percent efficiency of the gas turbine with air pollution equipment at LHV. An EFF that is less than 25 shall be assigned a value of 25. [40 CFR 60.332(a)(1) & 60.332(a)(2) and District Rule 4703, 5.1.1], [Federally Enforceable Through Title V]
- 4. Operator shall be required to conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081; Rule 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), Rule 110 (Madera), and Rule 108 (Kings)], [Federally Enforceable Through Title VI
- 5. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072-80, D 3031-81, D 4084-82 or D 3246-81. [40 CFR 60.335(d)], [Federally Enforceable Through Title V]
- 6. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(b)(2)], [Federally Enforceable Through Title V]
- 7. HHV and LHV of the fuel shall be determined using ASTM D3588-91, ASTM 1826-88, or ASTM 1945-81. [40 CFR 60.335(b) and District Rule 4703, 6.4.5], [Federally Enforceable Through Title V]
- 8. Nitrogen oxides (NOx) concentrations shall be determined using EPA Method 7E or 20, and oxygen (O2) concentrations shall be determined using EPA Method 3, 3A, or 20. [40 CFR 60.335(b) and District Rule 4703, 6.4], [Federally Enforceable Through Title V]
- 9. The operator shall provide source test information annually regarding the exhaust gas NOx concentration corrected to 15% O2 (dry). [40 CFR 60.332(a), (b) and District Rule 4703, 5.1], [Federally Enforceable Through Title V]
- 10. If the unit has a rating greater than or equal to 10.0 MW, operator shall provide source test information annually regarding the demonstrated percent efficiency (EFF) as defined in District Rule 4703, 5.1.1. [40 CFR 60.332(a),(b) and District Rule 4703, 5.1.1], [Federally Enforceable Through Title V]
- 11. Any gas turbine with an intermittently operated auxiliary burner shall demonstrate compliance with the auxiliary burner on and off. [40 CFR 60.335(b) and District Rule 4703, 6.3.2], [Federally Enforceable Through Title V]
- 12. If the turbine is fired on PUC-regulated natural gas, then maintain on file copies of natural gas bills. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. The operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 14. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis, the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(a),(b) and District Rule 4703, 6.2.4], [Federally Enforceable Through Title V]

- 15. The following types of units are not affected units subject to the requirements of the Acid Rain Program: 1) A simple combustion turbine that commenced operation before November 15, 1990, 2) Any unit that, during 1985, did not serve a generator that produced electricity for sale and that did not, as of November 15, 1990, and does not currently, serve a generator that produces electricity for sale, 3) A cogeneration facility which for a unit that commenced construction prior to November 15, 1990, was constructed for the purpose of supplying equal to or less than one-third its potential electrical output capacity or equal to or less than 219,000 Mwe-hrs actual electric output on an annual basis to any utility power distribution system for sale. Therefore, the requirements of 40 CFR 72.6 do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 16. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rule 1081, 4201, 3.1; Rules 406 (Fresno), 407 (Kings, San Joaquin, Stanislaus, Tulare, Merced, and Kern), and 404(Madera); 40 CFR 60.332(c), (d); 60.334 (b), and (c)(2); 60.335(d). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 17. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following subsumed requirements: SJVUAPCD Rule 4703, 6.2.2; Rules 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern and Stanislaus), and 110 (Madera); Rules 402 (Madera) and 404 (Fresno, Kern, Kings, San Joaquin, Merced, Stanislaus, Tulare); 40 CFR 60.332 (a) and (b); 60.333(a) and (b); 60.334 (a), (b), and (c)(1); 60.335 (a), (b), (c), and (e). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 18. Compliance with the permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: SJVUAPCD Rule 4703, sections 5.0, 5.1.1, 6.2.1, 6.2.4, 6.3, 6.4.1, 6.4.3, 6.4.5, 6.4.6. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 19. Permittee shall install, operate and maintain in calibration a predictive emissions monitoring system which continuously measures and records the water-to-fuel ratio and which correlates the water-to-fuel ratio with the NOx concentration in the exhaust by using the method described in 40 CFR 60.335(c). [40 CFR 60.334], [Federally Enforceable Through Title V]
- 20. Permittee shall submit to the APCO the information correlating the control system operating parameters to the associated measured NOx output. [District Rule 4703, 6.2.3], [Federally Enforceable Through Title V]
- 21. Permittee shall install, operate and maintain in calibration a system which continuously measures and records elapsed time of turbine operation. [District Rule 4703, 6.2.1], [Federally Enforceable Through Title V]
- 22. The continuous emissions monitoring system shall meet the performance requirements as specified in 40 CFR Part 60 Appendix B, Spec.2. [40 CFR 60.334 and District Rule 4703, 6.2.1], [Federally Enforceable Through Title V]
- 23. Operator shall submit a semiannual report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(c)(2)], [Federally Enforceable Through Title V]
- 24. Permittee shall submit an excess emissions and monitoring systems performance report (excess emissions are defined in applicable subparts) and/or a summary report form to the APCO semiannually, except when more frequent reporting is specifically required by an applicable subpart. All reports shall be postmarked by the 30th day of each calendar half (or quarter, as appropriate). [40 CFR 60.7(c)], [Federally Enforceable Through Title V]
- 25. Any one-hour period during which the average water-to-fuel ratio, as measured by the predictive monitoring system, falls below the water-to-fuel ratio determined to demonstrate compliance shall be reported to the APCO. Each report shall include the average water-to-fuel ratio, average fuel consumption, ambient conditions, turbine gas load and nitrogen content of the fuel during the period of excess emissions. [40 CFR 60.334(c)], [Federally Enforceable Through Title V]
- 26. Gas turbine engine and duct burner shall each be equipped with continuously recording fuel flow monitors. [District Rule 1070], [Federally Enforceable Through Title V]
- 27. Duct burner fuel gas supply shall be equipped with injection pressure indicator. [District Rule 1070], [Federally Enforceable Through Title V]
- 28. Gas turbine lube oil system atmospheric vent shall be equipped with aerosol/smoke control provisions. [District NSR Rule], [Federally Enforceable Through Title V]
- 29. GTE and duct burner shall be fired on PUC quality or equivalent sulfur content natural gas. [District NSR Rule], [Federally Enforceable Through Title V]
- 30. Gas turbine engine/duct burner system shall be equipped with recording fuel gas flowmeter. [District NSR Rule], [Federally Enforceable Through Title V]
- 31. Heat input to gas turbine engine/duct burner system shall not exceed 1880.16 MMBtu/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 32. GTE and duct burner combined emission rate shall not exceed PM10: 0.72 lb/hr, SOx (as SO2): 0.06 lb/hr, NOx (as NO2): 9.24 lb/hr from the permit unit and 42 ppmvd @15% O2 from the turbine, VOC: 0.38 lb/hr, and CO: 16.70 lb/hr and 200 ppmvd @ 15% O2. [District NSR Rule and District Rule 4703], [Federally Enforceable Through Title V]

- 33. Lube oil vent relief valve emission rate shall not exceed PM10: 0.09 lb/hr, and VOC: 0.09 lb/hr. [District NSR Rule], [Federally Enforceable Through Title V]
- 34. NOx and CO emissions shall be measured pursuant to Rule 4703 annually by District witnessed sample collection by independent laboratory. Compliance source testing shall be conducted under conditions representative of normal operation. Test results shall be submitted within 60 days. [District Rule 4703], [Federally Enforceable Through Title V]
- 35. Sampling facilities for source testing shall be provided in accordance with the provisions of Rule 1081 (Source Sampling). [District Rule 1081], [Federally Enforceable Through Title V]
- 36. Oxides of nitrogen emissions for compliance tests shall be determined by using EPA Method 7E or EPA Method 20. Carbon monoxide emissions for compliance tests shall be determined using EPA Test Methods 10 or 10B. Oxygen content of the exhaust gas shall be determined using EPA Methods 3, 3A, or 20. [District Rule 4703], [Federally Enforceable Through Title V]
- 37. Permittee shall install, operate, and maintain in calibration, equipment approved by the APCO that continuously measures and records the elapsed time of operation. [District Rule 4703], [Federally Enforceable Through Title V]
- 38. Permittee shall maintain a stationary gas turbine system operating log that includes, on a daily basis, the actual local time start-up and stop time, length and reason for reduced load periods, total hours of operation, and quantity of fuel used. [District Rule 4703], [Federally Enforceable Through Title V]
- 39. Permittee shall keep accurate daily records of the quantity and heating value (btu/scf) of the fuel gas supplied to the gas turbine engine/duct burner system, and, upon request, shall make such records available for District inspection. [District NSR Rule], [Federally Enforceable Through Title V]
- 40. All records required by this permit shall be maintained for a period of at least five years and shall be made available for District inspection upon request. [District Rule 4703 and District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-209-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK #010554 AND ONE FREE WATER KNOCKOUT VESSEL (GAMBLE LEASE)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-210-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#010555)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-211-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#006798)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-212-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#10664)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-213-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

68,389 GALLON FIXED ROOF PETROLEUM STORAGE/CLARIFIER TANK

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-214-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

4,200 GALLONS FIXED ROOF PETROLEUM STORAGE TANK (#GD-TK-1)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-215-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK #10695 AND ONE FREE WATER KNOCKOUT VESSEL (MCFEE LEASE)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-216-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#10694)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-217-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#10716)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-218-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#10602) (HOPKINS LEASE)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-219-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

21,195 GALLONS FIXED ROOF PETROLEUM STORAGE TANK (#8472)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-220-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#8707)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-221-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

67,200 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#10602)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-222-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

42,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#6799)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-223-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK #WP-WT-2 AND THREE FREE WATER KNOCKOUT VESSELS (WELLPORT)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-224-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#10635)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-225-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#10646)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-226-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

210,000 GALLON FIXED ROOF PETROLEUM STORAGE/CLARIFIER TANK

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-227-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

68,389 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#TK-1)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-235-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#010766) (HOPKINS LEASE)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-236-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#010767)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-237-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#010765)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-238-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

21,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#MN-ST-1)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-239-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

12,600 GALLON FIXED ROOF PETROLEUM STORAGE TANK

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-240-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

21,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-244-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

179,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#8658)

PERMIT UNIT REQUIREMENTS

1. The true vapor pressure (TVP) of any liquids placed, stored or held in the tank shall not exceed 1.5 psi at storage temperature. [District Rule 4623]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-245-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

8,400 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#OB-WT-1)

PERMIT UNIT REQUIREMENTS

1. The true vapor pressure (TVP) of any liquids placed, stored or held in the tank shall not exceed 1.5 psi at storage temperature. [District Rule 4623]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-246-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK #10357 AND FIVE FREE WATER KNOCKOUT VESSELS (BREMER LEASE)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-247-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#10413)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-248-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#10336)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-249-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#10337)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-250-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#10358)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-251-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#10356)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-252-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#10420)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-253-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#10421)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-254-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

127,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#LBWT-1)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-255-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

569,910 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#LBWT-2)

- 1. True vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and District Rule 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in 40 CFR 60.113 and Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- The requirements of SJVUAPCD Rule 4623 (Amended December 17, 1992), Rule 4801 (Amended December 17, 1992), and 40 CFR Part 60 Subparts K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 6. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit was constructed prior to May 19, 1978 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-256-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#UBFT-1) (HOPKINS LEASE)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-257-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#EBFT-1) (HOPKINS LEASE)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-258-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#LBFT-1)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 3. Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-259-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

21,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#LBST-1)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-260-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

942 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#UBDT-1)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended December 17, 1992), Rule 4801 (Amended December 17, 1992), and 40 CFR Part 60 Subparts K, Ka and Kb do not apply to this source. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 6. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-261-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

942 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#UBDT-2)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-262-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

21,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#EBDT-1)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-263-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#10757)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-264-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

68,389 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#1500WT)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-265-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#10755)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-266-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

21,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#500VR-1)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-267-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

42,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#100WT)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-268-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

42,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#1000WW-T)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-269-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

42,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (SUMP TK.)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-270-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

105,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#5000WTR)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-271-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK #9935 AND ONE FREE WATER KNOCKOUT VESSEL (TUMBADOR LEASE)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-272-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#9934)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-273-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#10370)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-274-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

10,500 GALLON FIXED ROOF PETROLEUM STORAGE TANK WITH SHARED VAPOR CONTROL SYSTEM (SUMP TANK, TUMBADOR LEASE)

- 1. The tank shall be equipped with a vapor loss prevention system (PTO # S-1372-76) consisting of vapor and condensate collection systems capable of reducing VOC emissions by at least 99%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Tank roof appurtenances shall be maintained leak free. [District Rule 4402], [Federally Enforceable Through Title V]
- 3. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 4. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of material diverted into sump tank, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 6. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 7. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-275-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK #9936 AND ONE FREE WATER KNOCKOUT VESSEL (DOME LEASE)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-276-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#9937)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-277-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#9992)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-278-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#10368)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-279-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

173,092 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#6500 WTR)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-280-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

42,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (FUEL TK.)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-281-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

21,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK WITH SHARED VAPOR CONTROL SYSTEM (SUMP TANK, DOME LEASE).

- 1. The tank shall be equipped with a vapor loss prevention system (PTO # S-1372-76) consisting of vapor and condensate collection systems capable of reducing VOC emissions by at least 99%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Tank roof appurtenances shall be maintained leak free. [District Rule 4402], [Federally Enforceable Through Title V]
- 3. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 4. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 6. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 7. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-284-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

68,389 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#9143-WT)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-285-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#10494)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-286-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

42,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#2731)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-287-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

42,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#2732)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-288-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

21,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#MG-WT-1)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-289-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK #6928 WITH TWO FREE WATER KNOCKOUT VESSELS (KEENE LEASE)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-290-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

42,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#9754)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-291-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

42,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#W-T2746)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-292-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#1783)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-293-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#KW-SB-1)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-294-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#KW-C-1)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-295-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,780 GALLON FIXED ROOF PETROLEUM STORAGE TANK (#1783)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-296-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

42,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK (FUEL TK.)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-297-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

99,999 GALLONS FIXED ROOF STORAGE TANK LEASE SOLD 6/8/93 - RS

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. Sulfur compound emissions shall not exceed 2000 ppmv as SO2. [District Rule 4801]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-298-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

99,999 GALLONS FIXED ROOF STORAGE TANK LEASE SOLD - 6/8/93 - RS

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. Sulfur compound emissions shall not exceed 2000 ppmv as SO2. [District Rule 4801]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-299-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

99,999 GALLONS FIXED ROOF STORAGE TANK LEASE SOLD - 6/8/93 - RS

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. Sulfur compound emissions shall not exceed 2000 ppmv as SO2. [District Rule 4801]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-300-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

99,999 GALLONS FIXED ROOF STORAGE TANK LEASE SOLD - 6/8/93 - RS

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. Sulfur compound emissions shall not exceed 2000 ppmv as SO2. [District Rule 4801]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-301-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

5,000 GALLONS FIXED ROOF TANK LEASE SOLD - 6/8/93 - RS

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. Sulfur compound emissions shall not exceed 2000 ppmv as SO2. [District Rule 4801]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-302-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

99,999 GALLONS WASH TANK LEASE SOLD - 6/8/93 - RS

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. Sulfur compound emissions shall not exceed 2000 ppmv as SO2. [District Rule 4801]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-308-4 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

20 UNCONTROLLED CYCLIC OIL WELLS

- 1. Any modification to number of permitted cyclic wells shall require new Authority to Construct. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Periodic (no less than quarterly) sampling of well casing vapor shall be performed to determine H2S concentration, and such records shall be maintained and made readily available for District inspection upon request for a period of five years. [District Rule 1081 and 1070], [Federally Enforceable Through Title V]
- 3. Wells with uncontrolled casing vapor exceeding 2000 ppmv H2S shall be equipped with sulfa-treat systems to reduce sulfur compounds emissions to 2000 ppmv H2S or less. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. All wells authorized by this permit to operate shall be located more than 1000 feet from an existing well vent vapor recovery system operated by the company. [District Rule 4401, 4.5.1], [Federally Enforceable Through Title V]
- 5. Permittee shall maintain a current well roster of all uncontrolled cyclic wells, and such roster shall be made readily available for District inspection upon request. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 6. The crude oil production from wells associated with this permit unit shall not lie within 1000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5], [Federally Enforceable Through Title V]
- 7. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 8. Compliance with permit conditions in the Title V permit shall be deemed in compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 9. The requirements of SJVUAPCD Rule 4407 (Adopted 5/19/94) and SJVUAPCD Rule 4801 (Adopted 12/17/92) do not apply to the well vents. For Rule 4801 applicability, well vent emissions are fugitive emissions not considered to come from a point source. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-312-4 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

TEOR OPERATION INCLUDING 60 STEAM ENHANCED WELLS, WELL VENT VAPOR CONTROL SYSTEM, WELL COLLECTION PIPING, STANDBY FLARE, VAPOR PIPING TO S-1372-17 AND STANDBY FLARE, THREE-PHASE SEPARATORS, HEAT EXCHANGERS, GAS/LIQUID SEPARATORS, STORAGE VESSELS, COMPRESSORS, LUBE OIL TANKS, AND PUMPS (KEENE-WILLIAMS LEASE)

- 1. All equipment shall be constructed, maintained and operated according to the specifications and plans contained in the permit application except as otherwise specified herein. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Permittee shall maintain with the permit a current listing of all steam enhanced wells connected to the casing vent control system and shall make such listing readily available for District inspection upon request. [District Rule 1070], [Federally Enforceable Through Title V]
- 3. Operation shall include standby flare, vapor piping to standby flare, and vapor piping to District approved TEOR steam generator # S-1372-17. [District Rule NSR], [Federally Enforceable Through Title V]
- 4. Operation shall include two slug catchers with mist extractor and one suction, one interstage, and one discharge compressor, and a compressed gas knockout scrubber preceding steam generator S-1372-17 and standby flare. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Operation shall include two heat exchangers, two vapor compressors, one liquid blow-case pump, and one lube oil tank. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Standby flare shall only be used to incinerate TEOR vapors when steam generator permit # S-1372-17 is inoperative. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Casing vapor collection system shall be equipped with vapor flowrate indicator/recorder downstream of condensible recovery system measuring total flowrate. [District NSR Rule and 1070], [Federally Enforceable Through Title V]
- 8. Collected condensate shall be discharged into production pipeline. [District NSR Rule], [Federally Enforceable Through Title V]
- 9. Leaks shall be inspected and repaired as specified in Rule 4401. [District Rule 4401], [Federally Enforceable Through Title V]
- 10. All components of well vent vapor collection and control systems shall be maintained and operated in good working condition at all times. [District NSR Rule], [Federally Enforceable Through Title V]
- 11. Fugitive VOC emissions from vapor collection and control system shall not exceed 2.8 lb/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 12. Emission rates from flare shall not exceed the following: PM10: 13.7 lb/mmscf, SOx (as SO2): 411.4 lb/day, NOx (as NO2): 140 lb/mmscf, VOC: 2.8 lb/mmscf, CO: 11.0 lb/mmscf. [District NSR Rule], [Federally Enforceable Through Title V]
- 13. Oxides of sulfur emissions shall not exceed 1578.08 b/day as SO2 from the following steam generators: S-1372-8, '17, '18, '19, '20 and standby flare S-1372-312.. [District NSR Rule], [Federally Enforceable Through Title V]
- 14. Permittee shall maintain accurate records of well casing vapor H2S concentration (periodic sampling of no less than once per quarter) and daily volume of casing vapor incinerated. [District Rule 1070], [Federally Enforceable Through Title V]
- 15. The following test method shall be used for fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 16. The flare shall be operated according to the manufacturer's specifications, a copy of which shall be maintained on site. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 17. The flare in this permit shall be inspected every two weeks while in operation for visible emissions. If visible emissions are observed, corrective action shall be taken. If visible emissions continue, an EPA method 9 test shall be conducted within 72 hours. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 18. The crude oil production from wells associated with this permit unit shall not lie within 1000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5], [Federally Enforceable Through Title V]

- 19. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1], [Federally Enforceable Through Title V]
- 20. All required source testing shall conform to the compliance testing procedures described in District Rule 1081(as amended December 16, 1993). [District Rule 1081 and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 21. The operator shall maintain monitoring records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1], [Federally Enforceable Through Title V]
- 22. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 23. The uncontrolled VOC emissions from any well vent shall be reduced by at least 99 percent by weight or, if several steam-enhanced crude oil production well vents are connected to a vapor collection and control system, total uncontrolled VOC emissions shall be reduced by at least 99 percent. [District Rule 4401, 5.1 and 5.2 and District NSR Rule], [Federally Enforceable Through Title V]
- 24. For cyclic wells located on properties with less than 10 cyclic wells and owned by a company, the uncontrolled VOC emissions from any well vent or system of well vents connected to a single vapor collection and control device shall be reduced by at least 50 percent.

 Properties shall include contiguous and adjacent oil production properties owned by or under control of the company. [District Rule 4401, 5.4], [Federally Enforceable Through Title V]
- 25. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3], [Federally Enforceable Through Title V]
- 26. Units consisting of more than 500 wells shall not exceed one leak detected for each 20 wells tested with a minimum of 50 wells tested. [District Rule 4401, 5.3], [Federally Enforceable Through Title V]
- 27. Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1], [Federally Enforceable Through Title V]
- 28. Operator shall repair each leak within 15 calendar days of detection. The APCO may grant a 10 calendar day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1], [Federally Enforceable Through Title V]
- 29. Operator shall maintain all components of a well vent vapor collection and control system in good repair. Components of the well vent vapor collection and control system shall include all piping, valves, fittings, pumps, compressors, tanks, etc. used to collect, control, store, or dispose of VOC condensate or non-condensable VOCs and which is prior to any blending of VOC condensate with crude oil or blending of non-condensable VOCs with gases to be used as a fuel. [District Rule 4401, 5.3 and 5.3.2], [Federally Enforceable Through Title V]
- 30. Annual control efficiency compliance tests shall be performed on all vapor collection and control systems used to control emissions from steam-enhanced crude oil production wells. Testing shall be performed by source testers certified by the California Air Resources Board (CARB) during June, July, August or September of each year if the system's control efficiency is dependent upon ambient air temperature. The APCO may waive the annual testing requirements of this condition if the vapor control system does not exhaust to atmosphere or if all uncondensed VOC emissions collected by a vapor collection and control system are incinerated in fuel burning equipment, an internal combustion engine or in a smokeless open flare, and the source's Operating Permit contains adequate periodic monitoring to ensure the source meets 99% control efficiency. [District Rule 4401, 5.1, 5.2 and 6.2.1], [Federally Enforceable Through Title V]
- 31. The control efficiency of the vapor collection and control system used to control VOC emissions from steam enhanced crude oil production well shall be determined by mass balance based on most stringent of a source test, USEPA approved emission factors, or Air Pollution (AP)-42 emission factors for components and number of components; and the efficiency of destruction devices determined by USEPA Method 25, 25a, or 25b as applicable. [District Rule 4401, 6.3.1], [Federally Enforceable Through Title V]
- 32. VOC content shall be determined using the latest revision of ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by CARB Method 432. [District Rule 4401, 6.3.2], [Federally Enforceable Through Title V]
- 33. The source shall perform leak inspections at least annually, using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.4.2 and 4401, 6.3.3], [Federally Enforceable Through Title V]
- 34. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following requirements: County Rule 108.1 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 35. Compliance with permit conditions in the Title V permit shall be deemed in compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 36. The requirements of SJVUAPCD Rule 4407 (Adopted 5/19/94) and SJVUAPCD Rule 4801 (Adopted 12/17/92) do not apply to the well vents. For Rule 4801 applicability, well vent emissions are fugitive emissions not considered to come from a point source. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-313-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

21,000 GALLON PETROLEUM STORAGE TANK (TULARE W-T)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-314-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

21,000 GALLON PETROLEUM STORAGE TANK (UO 10600)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-315-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

21,000 GALLON PETROLEUM STORAGE TANK (UO 10601)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-316-2 EXPIRATION DATE: 05/31/2007

EQUIPMENT DECRIPTION:

TEOR OPERATION SERVING 66 STEAM ENHANCED WELLS, WELL COLLECTION PIPING, FLARE, WELL VENT VAPOR CONTROL SYSTEM VAPOR PIPING TO FLARE, HEAT EXCHANGERS, GAS/LIQUID SEPARATORS, SCRUBBER, COMPRESSORS, AND LUBE OIL TANK (HOPKINS LEASE)

- 1. Casing vapor collection system shall be equipped with vapor flowrate indicator/recorder downstream of condensible recovery system measuring total flowrate. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Steam generator #3, permit # S-1372-1, shall not operate when flare is incinerating TEOR waste gas. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Collected condensate shall be discharged into production pipeline. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Number of leaking components from well vent vapor control system, including condensate handling, shall not exceed the number allowed by Rule 4401, at any one time. [District NSR Rule, 4401], [Federally Enforceable Through Title V]
- 5. Components of well vent vapor collection and control systems shall be maintained and leaks repaired as specified in Rule 4401. [District NSR Rule, 4401], [Federally Enforceable Through Title V]
- 6. Fugitive VOC emissions from vapor collection and control system shall not exceed 4.2 lb/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Emission rates from flare shall not exceed the following: PM10: 13.7 lb/MMscf, SOx (as SO2): 193.5 lb/day, NOx (as NO2): 140 lb/MMscf, VOC: 2.8 lb/MMscf, CO: 11.0 lb/MMscf. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Permittee shall maintain with the permit a current listing of all steam enhanced wells connected to the casing vent control system and shall make such listing readily available for District inspection upon request. [District Rule 1070], [Federally Enforceable Through Title V]
- 9. Permittee shall maintain accurate records of well casing vapor H2S concentration (periodic sampling of no less than once per quarter), daily volume of casing vapor incinerated and resulting daily SO2 emissions. [District Rule 1070], [Federally Enforceable Through Title V]
- 10. The following test method shall be used for fuel gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 11. The flare shall be operated according to the manufacturer's specifications, a copy of which shall be maintained on site. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 12. The flare in this permit shall be inspected every two weeks while in operation for visible emissions. If visible emissions are observed, corrective action shall be taken. If visible emissions continue, an EPA method 9 test shall be conducted within 72 hours. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 13. The crude oil production from wells associated with this permit unit shall not lie within 1000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5], [Federally Enforceable Through Title V]
- 14. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401, 5.0 (as amended January 15, 1998). [District Rule 4401, 4.1], [Federally Enforceable Through Title V]
- 15. All required source testing shall conform to the compliance testing procedures described in District Rule 1081(as amended December 16, 1993). [District Rule 1081 and County Rules 108.1 (Kern)], [Federally Enforceable Through Title V]
- 16. The operator shall maintain monitoring records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1.1], [Federally Enforceable Through Title V]
- 17. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]

- 18. The uncontrolled VOC emissions from any well vent shall be reduced by at least 99 percent by weight or, if several steam-enhanced crude oil production well vents are connected to a vapor collection and control system, total uncontrolled VOC emissions shall be reduced by at least 99 percent. [District NSR Rule and 4401, 5.1 and 5.2], [Federally Enforceable Through Title V]
- 19. For cyclic wells located on properties with less than 10 cyclic wells and owned by a company, the uncontrolled VOC emissions from any well vent or system of well vents connected to a single vapor collection and control device shall be reduced by at least 50 percent.

 Properties shall include contiguous and adjacent oil production properties owned by or under control of the company. [District Rule 4401, 5.4], [Federally Enforceable Through Title V]
- 20. Total number of leaks from the vapor collection and control system, including condensate handling, shall not exceed the number as allowed by Rule 4401 (as amended January 15, 1998) at any one time. [District Rule 4401, 5.3], [Federally Enforceable Through Title V]
- 21. Units consisting of more than 500 wells shall not exceed one leak detected for each 20 wells tested with a minimum of 50 wells tested. [District Rule 4401, 5.3], [Federally Enforceable Through Title V]
- Operator shall affix a readily visible tag bearing the date on which a leak is detected. The tag shall remain in place until the leaking component is repaired. [District Rule 4401, 5.3.1], [Federally Enforceable Through Title V]
- 23. Operator shall repair each leak within 15 calendar days of detection. The APCO may grant a 10 calendar day extension if the operator demonstrates that the necessary and sufficient actions have and are being taken to correct the leak. [District Rule 4401, 5.3.1], [Federally Enforceable Through Title V]
- 24. Operator shall maintain all components of a well vent vapor collection and control system in good repair. Components of the well vent vapor collection and control system shall include all piping, valves, fittings, pumps, compressors, tanks, etc. used to collect, control, store, or dispose of VOC condensate or non-condensable VOCs and which is prior to any blending of VOC condensate with crude oil or blending of non-condensable VOCs with gases to be used as a fuel. [District Rule 4401, 5.3 and 5.3.2], [Federally Enforceable Through Title V]
- 25. Annual control efficiency compliance tests shall be performed on all vapor collection and control systems used to control emissions from steam-enhanced crude oil production wells. Testing shall be performed by source testers certified by the California Air Resources Board (CARB) during June, July, August or September of each year if the system's control efficiency is dependent upon ambient air temperature. The APCO may waive the annual testing requirements of this condition if the vapor control system does not exhaust to atmosphere or if all uncondensed VOC emissions collected by a vapor collection and control system are incinerated in fuel burning equipment, an internal combustion engine or in a smokeless open flare, and the source's Operating Permit contains adequate periodic monitoring to ensure the source meets 99% control efficiency. [District Rule 4401, 5.1, 5.2 and 6.2.1], [Federally Enforceable Through Title V]
- 26. The control efficiency of the vapor collection and control system used to control VOC emissions from steam enhanced crude oil production well shall be determined by mass balance based on most stringent of a source test, USEPA approved emission factors, or Air Pollution (AP)-42 emission factors for components and number of components; and the efficiency of destruction devices determined by USEPA Method 25, 25a, or 25b as applicable. [District Rule 4401, 6.3.1], [Federally Enforceable Through Title V]
- 27. VOC content shall be determined using the latest revision of ASTM Method E168, E169, or E260 as applicable. Halogenated exempt compounds shall be determined by CARB Method 432. [District Rule 4401, 6.3.2], [Federally Enforceable Through Title V]
- 28. The source shall perform leak inspections at least annually, using a portable hydrocarbon detection instrument in accordance with USEPA Method 21. [District Rules 2520, 9.4.2 and 4401, 6.3.3], [Federally Enforceable Through Title V]
- 29. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following requirements: County Rule 108.1 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 30. Compliance with permit conditions in the Title V permit shall be deemed in compliance with SJVUAPCD Rule 4401 (Amended January 15, 1998), excluding sections 5.1 and 5.2 for control systems which have been waived from complying with the requirement of section 6.2.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 31. The requirements of SJVUAPCD Rule 4407 (Adopted 5/19/94) and SJVUAPCD Rule 4801 (Adopted 12/17/92) do not apply to the well vents. For Rule 4801 applicability, well vent emissions are fugitive emissions not considered to come from a point source. A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-317-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

67.5 MMBTU/HR NATURAL/TEOR GAS FIRED STEAM GENERATOR WITH FGR. (MCKITTRICK FRONT LEASE)

- 1. Unit shall be fired only on PUC quality natural gas or TEOR gas. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Burner shall be equipped with operational TEOR gas volume flowmeter. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. All wells producing from strata steamed by this unit shall be connected to a District-approved emissions control system, have District-approved closed casing vents or be District-approved uncontrolled cyclic wells. [District Rule 4401], [Federally Enforceable Through Title V]
- 4. Emission rates shall not exceed any of the following: PM10: 0.014 lb/MMBtu, NOx: 0.036 lb/MM Btu or 30 ppmvd @ 3% O2, VOC: 0.039 lb/MMBtu, or CO: 43.0 ppmvd @ 3% O2. [District NSR Rule & Rule 4305], [Federally Enforceable Through Title V]
- 5. SOx emissions shall not exceed 5.86 lb/hr. SOx emissions limit shall be verified through records of quantity of TEOR fuel gas combusted and fuel gas sulfur concentration. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. This steam generator shall be exclusively fired on PUC quality natural gas when steam generators S-1372-13, 16, and 24 are gas fired and incinerating TEOR vapors. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Source testing to measure NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 8. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 9. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 10. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 11. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 12. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 13. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, and stack gas oxygen EPA Method 3 or 3A or ARB Method 100. [District Rule 1081 & Rule 4305], [Federally Enforceable Through Title V]
- 14. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 15. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 16. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

- 18. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 19. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 20. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 21. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 22. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 23. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annually fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 24. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 25. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072-80, D 3031-81, D 4084-82, D 3246-81 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826-88 or D 1945-81 in conjunction with ASTM D 3588-89 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 27. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and 407 (Kern)], [Federally Enforceable Through Title V]
- 28. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 31. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108.1 (Kern), 424 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 32. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 33. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-318-3 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

67.5 MMBTU/HR NATURAL/TEOR GAS FIRED STEAM GENERATOR WITH FGR. (HOPKINS LEASE)

- 1. Unit shall be fired only on PUC quality natural gas or TEOR gas. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Burner shall be equipped with operational TEOR gas volume flowmeter. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. All wells producing from strata steamed by this unit shall be connected to a District-approved emissions control system, have District-approved closed casing vents or be District-approved uncontrolled cyclic wells. [District Rule 4401], [Federally Enforceable Through Title V]
- 4. Emission rates shall not exceed any of the following: PM10: 0.014 lb/MMBtu, NOx: 0.036 lb/MM Btu or 30 ppmvd @ 3% O2, VOC: 0.039 lb/MMBtu, or CO: 43.0 ppmvd @ 3% O2. [District NSR Rule & Rule 4305], [Federally Enforceable Through Title V]
- 5. SOx emissions shall not exceed 5.86 lb/hr. SOx emissions limit shall be verified through records of quantity of TEOR fuel gas combusted and fuel gas sulfur concentration. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Steam generators S-1372-10, -14, -23, -30, -31, -32, -33, -34, and -318 shall be fired exclusively on PUC quality natural gas when steam generators S-1372-8, 17, 18, 19, 20 are incinerating TEOR vapors. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. Source testing to measure NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 8. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 9. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 10. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 11. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 12. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 13. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, and stack gas oxygen EPA Method 3 or 3A or ARB Method 100. [District Rule 1081 & Rule 4305], [Federally Enforceable Through Title V]
- 14. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 15. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 16. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

- 18. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 19. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 20. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 21. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 22. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 23. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annually fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 24. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 25. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072-80, D 3031-81, D 4084-82, D 3246-81 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826-88 or D 1945-81 in conjunction with ASTM D 3588-89 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 27. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and 407 (Kern)], [Federally Enforceable Through Title V]
- 28. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 31. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108.1 (Kern), 424 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 32. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 33. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-319-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

67.5 MMBTU/HR GAS-FIRED STEAM GENERATOR WITH FGR (MCKITTRICK FRONT)

- 1. Unit shall be fired only on PUC quality natural gas or TEOR gas. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Burner shall be equipped with operational TEOR gas volume flowmeter. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. All wells producing from strata steamed by this unit shall be connected to a District-approved emissions control system, have District-approved closed casing vents or be District-approved uncontrolled cyclic wells. [District Rule 4401], [Federally Enforceable Through Title V]
- 4. Emission rates shall not exceed any of the following: PM10: 0.014 lb/MMBtu, NOx: 0.036 lb/MM Btu or 30 ppmvd @ 3% O2, VOC: 0.039 lb/MMBtu, or CO: 43.0 ppmvd @ 3% O2. [District NSR Rule & Rule 4305], [Federally Enforceable Through Title V]
- 5. SOx emissions shall not exceed 5.86 lb/hr. SOx emissions limit shall be verified through records of quantity of TEOR fuel gas combusted and fuel gas sulfur concentration. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Source testing to measure NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 7. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 8. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 9. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 10. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 11. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 12. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, and stack gas oxygen EPA Method 3 or 3A or ARB Method 100. [District Rule 1081 & Rule 4305], [Federally Enforceable Through Title V]
- 13. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 14. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 15. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 16. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 17. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

- 18. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 19. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 20. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 21. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 22. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annually fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 23. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 24. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072-80, D 3031-81, D 4084-82, D 3246-81 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 25. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826-88 or D 1945-81 in conjunction with ASTM D 3588-89 for gaseous fuels.

 [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 26. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and 407 (Kern)], [Federally Enforceable Through Title V]
- 27. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 28. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 30. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108.1 (Kern), 424 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 31. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 32. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-320-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

1,500 BBL FIXED ROOF STOCK TANK (MORRIS LEASE) TK #1

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-321-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

1,500 BBL FIXED ROOF STOCK TANK (MORRIS LEASE) TK #2

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-322-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

1,350 BBL WASH TANK (MORRIS LEASE)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-325-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

54,306 GALLON FIXED ROOF WASH TANK. CYMRIC

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-326-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

43,974 GALLON FIXED ROOF PETROLEUM STORAGE TANK #3/9775. CYMRIC

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-327-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

42,000 GALLON FIXED ROOF PETROLEUM STORAGE TANK #2/UO98401. CYMRIC

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 3. Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-329-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR WITH FGR AND O2 CONTROLLER

- 1. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 4.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. All wells producing from strata steamed by this unit shall be connected to a District-approved emissions control system, have District-approved closed casing vents or be District-approved uncontrolled cyclic wells. [District Rule 4401], [Federally Enforceable Through Title V]
- 3. Only PUC-regulated quality natural gas shall be burned. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Emission rates shall not exceed any of the following; PM10: 0.008 lb/MMBtu; NOx (as NO2): 30 ppmv @ 3% O2 or 0.036 lb/MMBtu; VOC: 0.0021 lb/MMBtu; SOx: 0.0003 lb/MMBtu; or CO: 31 ppmv @ 3% O2 or 0.029 lb/MMBtu. [District NSR Rule, District Rule 4305], [Federally Enforceable Through Title V]
- The permittee shall use flue gas recirculation (FGR) when the steam generator is in operation. [District Rule 4305], [Federally Enforceable Through Title V]
- 6. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. In-stack O2 monitors are acceptable for O2 measurement. [District Rule 4305], [Federally Enforceable Through Title V]
- 7. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall notify the District and return the NOx and CO concentrations to the allowable emissions rate as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate after one hour, the permittee shall conduct an emissions test within 60 days, utilizing District approved test methods, to determine compliance with the applicable emissions limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 8. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within an acceptable range. These records shall be retained at the facility for a period of no less than five years and shall be made available for District inspection upon request. [District Rules 2520, 9.5.2, and 4305], [Federally Enforceable Through Title V]
- 9. Exhaust stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 1081], [Federally Enforceable Through Title V]
- 10. Source testing to measure NOx and CO emissions shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305], [Federally Enforceable Through Title V]
- 11. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 12. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 13. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081], [Federally Enforceable Through Title V]
- 14. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 15. Compliance source testing shall be conducted under conditions representative of normal operation. [District Rule 1081], [Federally Enforceable Through Title V]
- 16. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, and stack gas oxygen EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4305], [Federally Enforceable Through Title V]

- 17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 18. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 19. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 20. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 21. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 22. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 23. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 24. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 25. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 27. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 28. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 29. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)], [Federally Enforceable Through Title V]
- 30. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 32. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

- 33. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108 (Kings), 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), 110 (Madera), 402 (Madera), 404 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 405 (Madera), 408 (Fresno, Kern, Tulare, Kings, Stanislaus, Merced, and San Joaquin), 407.2 (Kern, Tulare, Kings, Stanislaus, and San Joaquin), and 408.2 (Merced). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 34. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 35. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 36. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2 and 4351, 6.3], [Federally Enforceable Through Title V]
- 37. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 38. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 39. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 40. The number of representative units source tested to demonstrate compliance for NOx limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-330-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

71 CONTROLLED CYCLIC STEAM-ENHANCED CRUDE OIL PRODUCTION WELLS. (WESTERN HEAVY OIL SOURCE)

- 1. Permit unit shall comply with all applicable requirements of Rule 4401. [District Rule 4401]
- 2. All crude oil production wells associated with this permit unit shall be connected to a District-approved emissions control system or have District-approved closed casing vents. [District Rule 4401]
- 3. Total uncontrolled VOC emissions from all well vents shall be reduced by at least 99%. [District Rule 4401]
- 4. All components of well vent vapor collection and control systems shall be maintained in good working condition. [District Rule 4401]
- 5. Leaks shall be inspected and repaired as specified in Rule 4401. [District Rule 4401]
- 6. Crude oil produced from wells with vents shut in to comply with Rule 4401 requirements shall be stored and handled in a manner not allowing the emission of volatile organic compound vapors prevented by shutting in the casing vent. [District Rule 4401]
- 7. Formerly S-1141-426-0 []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-331-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

21,000 GALLON FIXED ROOF CRUDE OIL PRODUCTION TANK #05GF12

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 6. Formerly S-1129-315-0. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-332-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

21,000 GALLON FIXED ROOF CRUDE OIL PRODUCTION TANK #05GF13

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 6. Formerly S-1129-316-0. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-334-3 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

27.5 MMBTU/HR GAS/WASTE GAS STEAM GENERATOR (HSG #577) WITH FLUE GAS RECIRCULATION (FGR)

- 1. This steam generator is approved to operate at the following locations: NW/4 Section 7 and SW/4 Section 6 of T30S R22E. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. If continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 3.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Maximum sulfur content of gas combusted shall not exceed the following: natural gas 0.3 grain/100 scf and 7W vapor recovery gas 10,000 ppmv H2S. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. H2S concentration of 7E vapor recovery gas combusted shall be reduced by 95% prior to combustion and H2S concentration shall not exceed 800 ppm. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. Maximum volume of vapor recovery gas combusted shall not exceed: 7E 225,000 scf/day and 7W 150,000 scf/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 7. 7W vapor recovery gas and natural gas lines to steam generator shall be equipped with operational volumetric flowrate indicators. [District NSR Rule], [Federally Enforceable Through Title V]
- 8. Emissions from the steam generator shall not exceed any of the following: NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, PM10: 0.1135 lb/MMBtu, SOx (as SO2): 0.22 lb/MMBtu, VOC: 0.0067 lb/MMBtu, and CO: 20 ppmv @ 3% O2. [District NSR Rule], [Federally Enforceable Through Title V]
- 9. Total emission rates shall not exceed PM10: 47.9 lb/day, SOx (as SO2): 145.2 lb/day, NOx (as NO2): 23.8 lb/day, VOC: 2.8 lb/day, and CO: 14.1 lb/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 10. The permittee shall maintain records of type and quantity of fuel burned (natural gas, 7W and 7E vapor recovery gas), sulfur content, permitted emission factors and emissions for each unit for each day of operation, in the format approved by the District. [District NSR Rule], [Federally Enforceable Through Title V]
- 11. Records required by this permit shall be retained on site for a period of at least five years and shall be made readily available for District inspection upon request. [District NSR Rule], [Federally Enforceable Through Title V]
- 12. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 13. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of no less than five years and shall be made readily available for District inspection upon request. [District Rules 1070 and 4305], [Federally Enforceable Through Title V]
- 14. If the NOx and/or CO concentrations, as measured by the portable analyzer, exceed the permitted emission limits, the permittee or third party shall notify the District and return the NOx and/or CO concentrations to the permitted emission limits as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the permitted emission limits after (1) hour, the permittee shall conduct a source test within 60 days, of the first exceedance to demonstrate compliance with the permitted emission limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 15. Source testing to measure NOx and CO emissions shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305], [Federally Enforceable Through Title V]

- 16. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 17. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305], [Federally Enforceable Through Title V]
- 18. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 19. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) EPA Method 19, CO (ppmv) EPA Method 10 or ARB Method 100, stack gas oxygen EPA Method 3 or 3A or ARB Method 100, gas sulfur content ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081 and 4305], [Federally Enforceable Through Title V]
- 20. A source test to demonstrate compliance with the indicated emissions limits shall be performed within 60 days of recommencing operation of this unit. [District NSR Rule], [Federally Enforceable Through Title V]
- 21. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 22. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 23. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 24. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 25. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 26. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 27. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 28. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 32. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)], [Federally Enforceable Through Title V]

- 33. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 34. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 35. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 36. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108.1 (Kern), 404 (Kern), 408 (Kern), and 407.2 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 37. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 38. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 39. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2 and 4351, 6.3], [Federally Enforceable Through Title V]
- 40. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 41. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 42. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 43. The number of representative units source tested to demonstrate compliance for NOx limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-335-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

84,000 GALLON FIXED ROOF CRUDE OIL PRODUCTION TANK #2834.

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 6. Formerly S-1129-160-0. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-336-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

42,000 GALLON FIXED ROOF CRUDE OIL PRODUCTION TANK WITH UPSTREAM FIN-FAN COOLER (MCKITTRICK FEE)

- 1. True Vapor Pressure (TVP) of any liquid introduced, placed, or stored shall not exceed 1.5 psi. [District Rule 4623]
- 2. Formerly S-1129-183-2 []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-337-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

250 BARREL (10,500 GALLON) FIXED ROOF PETROLEUM STORAGE (GAUGE) TANK. (MCKITTRICK FEE)

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 6. Formerly S-1129-204-1. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-338-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

10,500 GALLON FIXED ROOF CRUDE OIL PRODUCTION TANK, PROD TANK.

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 6. Formerly S-1129-205-0. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-339-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

42,000 GALLON CRUDE OIL TRANSFER TANK (7 WEST FACILITY) WITH VAPOR CONTROL SYSTEM SHARED WITH S-1372-340

- 1. Vapor control system vapor piping shall discharge only to steam generator S-1372-334 and 7 East flare S-1372-352. [District Rule 2201]
- 2. The tank shall be equipped with a fixed roof with no holes or openings. [District Rule 2201]
- 3. The tank shall be equipped with a vapor recovery system capable of reducing VOC emissions by at least 98%. [District Rule 2201]
- 4. A leak is any emission greater than 10,000 ppm above background measured at a distance of one centimeter from the potential source with a portable hydrocarbon detection instrument calibrated with methane. [District Rule 2201]
- 5. Tank roof appurtenances shall be maintained leak free. [District Rule 2201]
- 6. Tank gauging, sampling devices, relief valves, manholes and etc. shall be equipped with leak free gaskets and shall remain closed at all times except during gauging or sampling. [District Rule 2201]
- 7. Piping, valves, fittings, pumps, compressors, liquid knockouts, condensate pressure vessels, etc. shall be inspected and the total number of leaks for equipment included on S-1372-339 and '340 shall not exceed 4 at any one time. [District Rule 2201]
- 8. Leaks shall be repaired within 15 days. [District Rule 2201]
- 9. True Vapor Pressure (TVP) of any liquid introduced, placed, or stored shall not exceed 1.5 psi. [District Rule 4623]
- 10. Testing for true vapor pressure shall be conducted at least annually. [District Rule 1081]
- 11. Vapor recovery gas shall be incinerated in steam generator S-1372-334 or 7 East flare S-1372-352. [District Rule 2201]
- 12. Vapor recovery gas combusted in 7 East flare S-1372-352 shall be routed to H2S scrubber prior to combustion. [District Rule 2201]
- 13. Permittee shall maintain accurate records of tank throughput, true vapor pressure and temperature of petroleum liquids in the tank, and such records shall be made readily available for District inspection upon request for a period of two years. [District Rule 2201]
- 14. Formerly S-1129-206-2 []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-340-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

10,500 GALLON CRUDE OIL GAUGE TANK (7 WEST FACILITY) WITH VAPOR CONTROL SYSTEM SHARED WITH S-1129-339

- 1. The tank shall be equipped with a fixed roof with no holes or openings. [District Rule 2201]
- 2. The tank shall be equipped with a vapor recovery system capable of reducing VOC emissions by at least 98%. [District Rule 2201]
- 3. A leak is any emission greater than 10,000 ppm above background measured at a distance of one centimeter from the potential source with a portable hydrocarbon detection instrument calibrated with methane. [District Rule 2201]
- 4. Tank roof appurtenances shall be maintained leak free. [District Rule 2201]
- 5. Tank gauging, sampling devices, relief valves, manholes and etc. shall be equipped with leak free gaskets and shall remain closed at all times except during gauging or sampling. [District Rule 2201]
- 6. Piping, valves, fittings, pumps, compressors, liquid knockouts, condensate pressure vessels, etc. shall be inspected and the total number of leaks for equipment included on S-1372-339 and '340 shall not exceed 4 at any one time. [District Rule 2201]
- 7. Leaks shall be repaired within 15 days. [District Rule 2201]
- 8. True Vapor Pressure (TVP) of any liquid introduced, placed, or stored shall not exceed 1.5 psi. [District Rule 4623]
- 9. Testing for true vapor pressure shall be conducted at least annually. [District Rule 1081]
- 10. Permittee shall maintain accurate records of tank throughput, true vapor pressure and temperature of petroleum liquids in the tank, and such records shall be made readily available for District inspection upon request for a period of two years. [District Rule 2201]
- 11. Formerly S-1129-207-2 []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-341-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

10,500 GALLON FIXED ROOF CRUDE OIL PRODUCTION TANK.

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 6. Formerly S-1129-213-1 []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-342-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

31,500 GALLON FIXED ROOF CRUDE OIL PRODUCTION TANK, SALT CREEK UNIT

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 6. Formerly S-1129-214-1 []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-343-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

21,000 GALLON FIXED ROOF CRUDE OIL PRODUCTION TANK #0.5GM1, CENTRAL MCKITTRICK FEE FACILITY (SEC. SW6, T30S, R22E).

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 6. Formerly S-1129-224-1 []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-344-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

42,000 GALLON FIXED ROOF CRUDE OIL PRODUCTION TANK, LACT TANK

- 1. The true vapor pressure of any organic liquid introduced to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 6. Formerly S-1129-297-1 []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-345-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

42,000 GALLON FIXED ROOF CRUDE OIL PRODUCTION TANK, SHIP TANK WITH UPSTREAM FIN-FAN COOLER (MCKITTRICK FEE)

- 1. True Vapor Pressure (TVP) of any liquid introduced, placed, or stored shall not exceed 1.5 psi. [District Rule 4623]
- 2. Formerly S-1129-299-2 []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-346-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

THERMALLY ENHANCED OIL RECOVERY (TEOR) OPERATION WITH TWENTY-EIGHT (28) CLOSED-VENT STEAM DRIVE WELLS.

- 1. Steam enhanced wells shall have closed casing vents. [District Rule 2201]
- 2. Crude oil produced from wells shall be routed via closed system to tanks S-1372-339, and '340. [District Rule 2201]
- 3. VOC emissions shall not exceed 61.6 lb/day. [District Rule 2201]
- 4. Permittee shall maintain with the permit a current listing of all steam enhanced wells included on this permit and shall make such listing readily available for District inspection upon request. [District Rule 4401]
- 5. Formerly S-1129-821-1 []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-347-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

500 BBL FIXED ROOF HEAVY CRUDE STOCK TANK

- 1. The true vapor pressure of any organic liquid introduced, placed or stored to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 6. Formerly S-1129-824-0 []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-348-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

500 BARREL FIXED ROOF HEAVY CRUDE STOCK TANK

- 1. The true vapor pressure of any organic liquid introduced, placed or stored to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 6. Formerly S-1129-825-0 []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-349-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

21,000 GALLON (500 BBL) FIXED ROOF CONDENSATE SEPARATION AND STORAGE TANK WITH PRODUCTION SEPARATOR, FIN FAN HEAT EXCHANGER AND VAPOR RECOVERY SYSTEM SHARED WITH S-1372-351 (7 EAST FACILITY, STAR FEE).

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- Vapor recovery system shall include liquid knockout, 15 hp gas compressor, and piping to 7 East flare S-1372-352 and steam generator S-1372-334. [District Rule 2201]
- 3. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule]
- 4. Tank roof appurtenances shall be maintained leak free (as defined in Rule 4623). [District Rule 2201]
- 5. Tank gauging, sampling devices, relief valves, manholes and etc. shall be equipped with gas-tight (as defined in Rule 4623) gaskets and shall remain closed at all times except during gauging or sampling. [District Rule 2201]
- 6. Tank seams, welds, joints, piping, valves and fittings shall be inspected and maintained gas-tight (as defined in Rule 4623). [District Rule 2201]
- 7. The tank shall be equipped with a vapor recovery system capable of reducing VOC emissions by at least 99%. [District Rule 2201]
- 8. VOC emissions shall not exceed 6.44 lb/day. [District Rule 2201]
- 9. Vapor recovery gas shall be routed to H2S scrubber included on S-1372-352 prior to incineration in 7 East flare S-1372-352 or steam generator S-1372-334. [District Rule 2201]
- 10. Vapor recovery gas volume shall not exceed 225,000 scf/day. [District Rule 2201]
- 11. Sampling facilities for source testing shall be provided in accordance with the provisions of Rule 1081 (Source Sampling). [District Rule 1081]
- 12. District witnessed sample collection to demonstrate compliance with VOC emission limit shall be conducted within 60 days of initial start-up and on an annual basis thereafter. [District Rule 1081]
- 13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081]
- 14. Permittee shall maintain accurate records of vapor recovery gas flow rate and VOC content. [District Rule 1070]
- 15. All records shall be retained for a minimum of 2 years, and shall be made available for District inspection upon request. [District Rule 1070]
- 16. Formerly S-1129-827-1 []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-350-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

21,000 GALLON (500 BBL) FIXED ROOF CONDENSATE SEPARATION AND STORAGE TANK WITH PRODUCTION SEPARATOR, FIN FAN HEAT EXCHANGER AND VAPOR RECOVERY SYSTEM (6 NORTH FACILITY, MCKITTRICK FEE LEASE).

- 1. Vapor recovery system shall include liquid knockout, two 15 hp gas compressors, and gas piping to 6 North flare S-1372-353. [District Rule 2201]
- 2. The tank shall be equipped with a fixed roof with no holes or openings. [District Rule 2201]
- 3. Tank roof appurtenances shall be maintained leak free (as defined in Rule 4623). [District Rule 2201]
- 4. Tank gauging, sampling devices, relief valves, manholes and etc. shall be equipped with gas-tight (as defined in Rule 4623) gaskets and shall remain closed at all times except during gauging or sampling. [District Rule 2201]
- 5. Tank seams, welds, joints, piping, valves and fittings shall be inspected and maintained gas-tight (as defined in Rule 4623). [District Rule 2201]
- 6. The tank shall be equipped with a vapor recovery system capable of reducing VOC emissions by at least 99%. [District Rule 2201]
- 7. VOC emissions shall not exceed 3.54 lb/day. [District Rule 2201]
- 8. Vapor recovery gas shall be routed to H2S scrubber prior to incineration in 6 North flare S-1372-353. [District Rule 2201]
- 9. Vapor recovery gas volume shall not exceed 120,000 scf/day. [District Rule 2201]
- 10. Sampling facilities for source testing shall be provided in accordance with the provisions of Rule 1081 (Source Sampling). [District Rule 1081]
- 11. District witnessed sample collection to demonstrate compliance with VOC emission limit shall be conducted within 60 days of initial start-up and on an annual basis thereafter. [District Rule 1081]
- 12. The results of each sample analysis shall be submitted to the District within 60 days thereafter. [District Rule 1081]
- 13. Permittee shall maintain accurate records of vapor recovery gas flow rate and VOC content. [District Rule 1070]
- 14. All records shall be retained for a minimum of 2 years, and shall be made available for District inspection upon request. [District Rule 1070]
- 15. Formerly S-1129-829-1 []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-351-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

4200 GALLON (100 BBL) GAUGE TANK WITH VAPOR RECOVERY SYSTEM SHARED WITH S-1372-349.(7 EAST FACILITY, STAR FEE).

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. The tank shall be equipped with a fixed roof with no holes or openings. [District NSR Rule]
- 3. Tank roof appurtenances shall be maintained leak free (as defined in Rule 4623). [District Rule 2201]
- 4. Tank gauging, sampling devices, relief valves, manholes and etc. shall be equipped with gas-tight (as defined in Rule 4623) gaskets and shall remain closed at all times except during gauging or sampling. [District Rule 2201]
- 5. Tank seams, welds, joints, piping, valves and fittings shall be inspected and maintained gas-tight (as defined in Rule 4623). [District Rule 2201]
- 6. The tank shall be equipped with a vapor recovery system capable of reducing VOC emissions by at least 99%. [District Rule 2201]
- 7. Formerly S-1129-830-0 []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-352-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

83.3 MMBTU/HR FLARE SERVING 7 EAST PRODUCTION FACILITY, STAR FEE.

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. Flare shall include, propane pilot, automatic re-ignition provisions, and 5 ft diameter by 18 ft tall H2S scrubber vessel with mist scrubber. [District Rule 2201]
- 3. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1/4 or 5% opacity. [District Rule 2201]
- 4. Vapor recovery gas and natural gas lines to flare shall be equipped with volumetric flowrate indicators. [District Rule 2201]
- 5. Maximum volumes of gas incinerated in this flare shall not exceed the following: 7 East vapor recovery gas 225,000 scf/day, 7 West vapor recovery gas 150,000 scf/day, and natural gas 6,000 scf/day. [District Rule 2201]
- 6. Supplemental fuel shall be natural gas only. [District Rule 2201]
- 7. 7 West vapor recovery gas shall be combusted in flare only when steam generator S-1372-334 is not operating. [District Rule 2201]
- 8. H2S scrubber shall operate with a removal efficiency of at least 95% and H2S concentration of scrubbed vapor recovery gas shall not exceed 800 ppm. [District Rule 2201]
- 9. H2S concentration in vapor recovery gas before and after the scrubber shall be tested to determine H2S removal efficiency daily or at an alternate frequency approved in writing by the District. [District Rule 1081]
- 10. When H2S scrubber is being recharged, unscrubbed gas shall not vent to incineration device or to atmosphere. [District Rule 2201]
- 11. Emission rates shall not exceed any of the following in lb/MMBtu: PM10 0.014, NOx 0.14, VOC 0.003 or CO 0.035. [District Rule 2201]
- 12. Sampling facilities for source testing shall be provided in accordance with the provisions of Rule 1081 (Source Sampling). [District Rule 1081]
- 13. District witnessed sample collection to demonstrate compliance with H2S removal efficiency shall be conducted within 60 days of initial start-up and on an annual basis thereafter. [District Rule 1081]
- 14. The results of each sample analysis shall be submitted to the District within 60 days thereafter. [District Rule 1081]
- 15. Permittee shall maintain accurate daily records of type and volume of gas flared (natural gas, 7E and 7W vapor recovery gas), H2S concentration, and scrubber removal efficiency. [District Rule 1070]
- 16. All records shall be retained for a minimum of 2 years, and shall be made available for District inspection upon request. [District Rule 1070]
- 17. Formerly S-1129-831-0 []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-353-0 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

83.3 MMBTU/HR FLARE SERVING 6 NORTH FACILITY, STAR FEE.

- 1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
- 2. Flare shall be equipped with propane pilot, automatic re-ignition provisions and 5 ft diameter by 18 ft tall H2S scrubber vessel with mist scrubber. [District Rule 2201]
- 3. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1/4 or 5% opacity. [District Rule 2201]
- 4. Vapor recovery gas and natural gas lines to flare shall be equipped with volumetric flowrate indicator. [District Rule 2201]
- 5. Maximum volumes of gas incinerated in this flare shall not exceed the following: 6 North vapor recovery gas 120,000 scf/day and natural gas 3,500 scf/day. [District Rule 2201]
- 6. Supplemental fuel shall be natural gas only. [District Rule 2201]
- 7. H2S scrubber shall operate with a removal efficiency of at least 95% and H2S concentration of scrubbed vapor recovery gas shall not exceed 800 ppm. [District Rule 2201]
- 8. H2S concentration in vapor recovery gas before and after the scrubber shall be tested to determine H2S removal efficiency daily or at an alternate frequency approved in writing by the District. [District Rule 1081]
- 9. When H2S scrubber is being recharged, unscrubbed gas shall not vent to incineration device or to atmosphere. [District Rule 2201]
- 10. Emission rates shall not exceed any of the following in lb/MMBtu: PM10 0.014, NOx 0.14, VOC 0.003 or CO 0.035. [District Rule 2201]
- 11. Sampling facilities for source testing shall be provided in accordance with the provisions of Rule 1081 (Source Sampling). [District Rule 1081]
- 12. District witnessed sample collection to demonstrate compliance with H2S removal efficiency shall be conducted within 60 days of initial startup and on an annual basis thereafter. [District Rule 1081]
- 13. The results of each sample analysis shall be submitted to the District within 60 days thereafter. [District Rule 1081]
- 14. Permittee shall maintain accurate daily records of type and volume of gas flared (natural gas and 6N vapor recovery gas), H2S concentration, and scrubber removal efficiency. [District Rule 1070]
- 15. All records shall be retained for a minimum of 2 years, and shall be made available for District inspection upon request. [District Rule 1070]
- 16. Formerly S-1129-832-0 []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-355-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR #52 DIS# 22457-79 WITH FGR

- 1. No less than 0.5 miles of roadway shall be paved and maintained in good repair. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Only natural gas shall be used as fuel. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Emissions from this unit shall not exceed any of the following: PM10: 0.005 lb/MMBtu, SOx (as SO2): 0.003 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 30 ppmv @3% O2; or CO: 25.8 ppmv @3% O2. [District NSR Rule and 4305], [Federally Enforceable Through Title V]
- 4. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months thereafter, except as provided below. [District Rules 4305 and 4351], [Federally Enforceable Through Title V]
- 5. Compliance with NOx and CO emission limits shall be demonstrated not less than once every 36 months, if compliance is demonstrated on two consecutive annual compliance tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 6. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 7. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 8. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 9. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District-approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 10. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations (corrected to 3% O2), and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 11. If the NOx and/or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 12. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, CO (ppmv) EPA Method 10 or ARB Method 100, PM10 (ppmv) EPA Method 201 or ARB Method 5 and stack gas oxygen EPA Method 3 or 3A or ARB Method 100. [District Rules 1081 and 4305], [Federally Enforceable Through Title V]
- 13. Permittee shall maintain records required by this permit for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 1070, 4305], [Federally Enforceable Through Title V]
- 14. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 15. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 16. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 17. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]

- 18. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 19. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annually fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 20. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 21. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072-80, D 3031-81, D 4084-82, D 3246-81 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 22. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826-88 or D 1945-81 in conjunction with ASTM D 3588-89 for gaseous fuels.

 [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 23. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and 407 (Kern)], [Federally Enforceable Through Title V]
- 24. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 25. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 27. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108.1 (Kern), 424 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 28. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 29. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-356-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR DIS #22468-79 WITH FGR AND O2 CONTROLLER

- 1. No less than 0.5 miles of roadway shall be paved and maintained in good repair. [District NSR Rule], [Federally Enforceable Through Title V]
- 2. Only PUC-quality natural gas shall be used as fuel. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Emissions from this unit shall not exceed any of the following: PM10: 0.005 lb/MMBtu, SOx (as SO2): 0.003 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 30 ppmv @3% O2; or CO: 25.8 ppmv @3% O2. [District NSR Rule and Rule 4305], [Federally Enforceable Through Title V]
- 4. The steam generator shall be equipped with an FGR valve positioning indicator. [District Rule 4305], [Federally Enforceable Through Title V]
- Except during periods of steam generator startup/shutdown, steam generator shall not be operated unless flue gas recirculation system is operating. [District Rule 4305], [Federally Enforceable Through Title V]
- 6. Steam generator may be equipped with a programmable logic controller (PLC). [District Rule 4305], [Federally Enforceable Through Title V]
- 7. The acceptable range of flue gas recirculation (FGR) valve settings shall be established by testing emissions from this or other representative unit(s) as approved by the District. The acceptable maximum and minimum FGR valve settings shall be the settings with which compliance with applicable NOx and CO emission rates have been demonstrated through District approved source testing. [District Rule 4305], [Federally Enforceable Through Title V]
- 8. The acceptable range of FGR valve position shall be documented for each steam generator in a District approved plan. Permittee shall maintain a copy of the current plan with the steam generator permit. [District Rule 4305], [Federally Enforceable Through Title V]
- 9. If the flue gas recirculation valve setting deviates from the acceptable range, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the flue gas recirculation valve settings are not corrected promptly, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emissions limits at the observed flue gas recirculation valve setting. [District Rule 4305], [Federally Enforceable Through Title V]
- 10. Permittee shall record the FGR valve position and date and time when the FGR valve position was checked, on a weekly basis. Permittee shall record any corrective action taken to maintain the FGR setting within the acceptable range. Permittee shall maintain records of date and duration of each startup and each shut down. [District Rule 1070], [Federally Enforceable Through Title V]
- 11. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the District, will satisfy the NOx and CO source testing requirement. [District Rule 4305], [Federally Enforceable Through Title V]
- 12. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District-approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 13. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations (corrected to 3% O2), and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 14. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 15. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months thereafter, except as provided below. [District Rules 4305 and 4351], [Federally Enforceable Through Title V]
- 16. Compliance with NOx and CO emission limits shall be demonstrated not less than once every 36 months, if compliance is demonstrated on two consecutive annual compliance tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 17. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]

- 18. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081], [Federally Enforceable Through Title V]
- 19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 20. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, CO (ppmv) EPA Method 10 or ARB Method 100, PM10 (ppmv) EPA Method 201 or ARB Method 5 and stack gas oxygen EPA Method 3 or 3A or ARB Method 100. [District Rules 1081 and 4305], [Federally Enforceable Through Title V]
- 21. Permittee shall maintain records required by this permit for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 1070, 4305], [Federally Enforceable Through Title V]
- 22. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 23. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 24. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 25. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 27. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 28. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072-80, D 3031-81, D 4084-82, D 3246-81 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 31. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826-88 or D 1945-81 in conjunction with ASTM D 3588-89 for gaseous fuels.

 [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 32. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rule 407 (Kern)], [Federally Enforceable Through Title
- 33. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 34. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]

- 35. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 36. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108.1 (Kern), 404 (Kern), 408 (Kern), and 407.2 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 37. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 38. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 39. Annual test results submitted to the District from unit(s) representing a group of units may be used to demonstrate compliance with NOx limits of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 4305, 6.3.2 and 4351, 6.3], [Federally Enforceable Through Title V]
- 40. The following conditions must be met for representative unit(s) to be used to demonstrate compliance for NOx limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 41. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 42. All units in a group for which representative units are source tested to demonstrate compliance for NOx limits of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.4.2 and 4305, 6.3.2], [Federally Enforceable Through Title V]
- 43. The number of representative units source tested to demonstrate compliance for NOx limits shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-357-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR DIS #22469-79 WITH O2 CONTROLLER

- 1. Emissions from this unit shall not exceed any of the following: PM10: 0.008 lb/MMBtu, SOx (as SO2): 0.003 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 30 ppmv @3% O2; or CO: 25.8 ppmv @3% O2. [District NSR Rule, and 4305], [Federally Enforceable Through Title V]
- 2. Steam generator shall be equipped with O2 controller. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. When continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 3.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. No less than 0.5 miles of roadway shall be paved and maintained in good repair. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Only PUC-quality natural gas shall be used as fuel. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District-approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 7. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations (corrected to 3% O2), and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 8. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 9. Source testing to measure NOx and CO emissions shall be conducted within 60 days of startup, and not less than once every 12 months thereafter, except as provided below. [District Rules 4305], [Federally Enforceable Through Title V]
- 10. NOx and CO emissions shall be measured not less than once every 36 months, if compliance is demonstrated on two consecutive annual compliance tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 11. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 12. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 13. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, CO (ppmv) EPA Method 10 or ARB Method 100 and stack gas oxygen EPA Method 3 or 3A or ARB Method 100. [District Rules 1081 and 4305], [Federally Enforceable Through Title V]
- 14. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 15. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 16. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 17. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 18. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]

- 19. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 20. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 21. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 22. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 23. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072-80, D 3031-81, D 4084-82, D 3246-81 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 24. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826-88 or D 1945-81 in conjunction with ASTM D 3588-89 for gaseous fuels.

 [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 25. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rule 407 (Kern)], [Federally Enforceable Through Title V]
- 26. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 27. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 29. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108.1 (Kern), 404 (Kern), 408 (Kern), and 407.2 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 30. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 31. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-358-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR DIS #22470-79 WITH O2 CONTROLLER AND FGR

- 1. Emissions from this unit shall not exceed any of the following: PM10: 0.008 lb/MMBtu, SOx (as SO2): 0.003 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 30 ppmv @3% O2; or CO: 25.8 ppmv @3% O2. [District NSR Rule, and 4305], [Federally Enforceable Through Title V]
- 2. Steam generator shall be equipped with O2 controller. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. When continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 3.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. No less than 0.5 miles of roadway shall be paved and maintained in good repair. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. Only PUC-quality natural gas shall be used as fuel. [District NSR Rule], [Federally Enforceable Through Title V]
- 6. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District-approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 7. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations (corrected to 3% O2), and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 8. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 9. Compliance source testing shall be conducted under conditions representative of normal operation. [District Rule 1081], [Federally Enforceable Through Title V]
- 10. Source testing to measure NOx and CO emissions shall be conducted within 60 days of startup, and not less than once every 12 months thereafter, except as provided below. [District Rules 4305], [Federally Enforceable Through Title V]
- 11. NOx and CO emissions shall be measured not less than once every 36 months, if compliance is demonstrated on two consecutive annual compliance tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 12. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 13. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 14. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, CO (ppmv) EPA Method 10 or ARB Method 100 and stack gas oxygen EPA Method 3 or 3A or ARB Method 100. [District Rules 1081 and 4305], [Federally Enforceable Through Title V]
- 15. Permittee shall maintain records required by this permit for a period of five years and shall make such records readily available for District inspection upon request. [District Rules 1070, 4305], [Federally Enforceable Through Title V]
- 16. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 17. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 18. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]

- 19. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 20. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]
- 21. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 22. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 23. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 24. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 25. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072-80, D 3031-81, D 4084-82, D 3246-81 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 26. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826-88 or D 1945-81 in conjunction with ASTM D 3588-89 for gaseous fuels. [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 27. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rule 407 (Kern)], [Federally Enforceable Through Title V]
- 28. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 29. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 30. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 31. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108.1 (Kern), 404 (Kern), 408 (Kern), and 407.2 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 32. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 33. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-359-2 EXPIRATION DATE: 05/31/2007

EQUIPMENT DECRIPTION:

62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR DIS #22632-80 WITH O2 CONTROLLER AND FGR

- 1. Emissions from this unit shall not exceed any of the following: PM10: 0.005 lb/MMBtu, SOx (as SO2): 0.003 lb/MMBtu, VOC: 0.003 lb/MMBtu, NOx (as NO2): 30 ppmv @3% O2; or CO: 25.8 ppmv @3% O2. [District NSR Rule, and 4305], [Federally Enforceable Through Title V]
- 2. Steam generator shall be equipped with O2 controller. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. When continuous operation oxygen analyzer/controller is utilized, excess O2 shall be maintained between 0.5 and 3.0%. If not utilized, excess air shall be maintained at no less than 15%. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Only PUC-quality natural gas shall be used as fuel. [District NSR Rule], [Federally Enforceable Through Title V]
- 5. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District-approved portable analyzers. [District Rule 4305], [Federally Enforceable Through Title V]
- 6. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations (corrected to 3% O2), and the O2 concentration. The records must also include a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4305], [Federally Enforceable Through Title V]
- 7. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the allowable emissions rate, the permittee shall take corrective action within one hour after detection. If the portable analyzer readings continue to exceed the allowable emissions rate, the permittee shall notify the District immediately and conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable limits. [District Rule 4305], [Federally Enforceable Through Title V]
- 8. Compliance source testing shall be conducted under conditions representative of normal operation. [District Rule 1081], [Federally Enforceable Through Title V]
- 9. Source testing to measure NOx and CO emissions shall be conducted within 60 days of startup, and not less than once every 12 months thereafter, except as provided below. [District Rules 4305], [Federally Enforceable Through Title V]
- 10. NOx and CO emissions shall be measured not less than once every 36 months, if compliance is demonstrated on two consecutive annual compliance tests. [District Rule 4305], [Federally Enforceable Through Title V]
- 11. If permittee fails any compliance demonstration for NOx or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305], [Federally Enforceable Through Title V]
- 12. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081], [Federally Enforceable Through Title V]
- 13. The following test methods shall be used: NOx (ppmv) EPA Method 7E or ARB Method 100, CO (ppmv) EPA Method 10 or ARB Method 100 and stack gas oxygen EPA Method 3 or 3A or ARB Method 100. [District Rules 1081 and 4305], [Federally Enforceable Through Title V]
- 14. The portable analyzer shall be calibrated prior to each use with a two-point calibration method (zero and span). Calibration shall be performed with certified calibration gases. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 15. During the source test, emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 16. All required source testing shall conform to the compliance testing procedures described in District Rule 1081 (Last Amended December 16, 1993). [District Rule 1081 and County Rule 108.1 (Kern)], [Federally Enforceable Through Title V]
- 17. Copies of all fuel invoices, gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 18. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.5.2], [Federally Enforceable Through Title V]

- 19. Particulate matter emissions shall not exceed 0.1 grain/dscf, calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3], [Federally Enforceable Through Title V]
- 20. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.4.2 and District Rule 4301, 5.2.1], [Federally Enforceable Through Title V]
- 21. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 22. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6B; or Method 8; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months; however, annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 23. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072-80, D 3031-81, D 4084-82, D 3246-81 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 24. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826-88 or D 1945-81 in conjunction with ASTM D 3588-89 for gaseous fuels.

 [District Rule 2520, 9.4.2; 4305, 6.2.1; and 4351, 6.2.1], [Federally Enforceable Through Title V]
- 25. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.4.2 and County Rule 407 (Kern)], [Federally Enforceable Through Title V]
- 26. Sulfur compound emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. [Kern County Rule 424 and District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 27. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.4.2], [Federally Enforceable Through Title V]
- 28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Amended December 17, 1992), and 4301 (Amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 29. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: 108.1 (Kern), 404 (Kern), 408 (Kern), and 407.2 (Kern). A permit shield is granted from these requirements. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 30. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 31. This unit is located west of interstate 5 in Kern county. Therefore, the requirements of District Rule 4351(Amended October 19, 1995) do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-360-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

22,008 GALLON FIXED ROOF CRUDE OIL STORAGE TANK

- 1. The true vapor pressure of any organic liquid introduced, placed or stored to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 6. Formerly permit number S-3505-1-0. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-361-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

32,970 GALLON FIXED ROOF CRUDE OIL STORAGE TANK

- 1. The true vapor pressure of any organic liquid introduced, placed or stored to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 6. Formerly permit number S-3505-2-0. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-362-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

42,000 GALLON FIXED ROOF CRUDE OIL STORAGE TANK

- 1. The true vapor pressure of any organic liquid introduced, placed or stored to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 6. Formerly permit number S-3505-3-0. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-363-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

11,004 GALLON FIXED ROOF STORAGE TANK

- 1. The true vapor pressure of any organic liquid introduced, placed or stored to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 6. Formerly permit number S-3505-5-0. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-364-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

21,714 GALLON FIXED ROOF STORAGE TANK

- 1. The true vapor pressure of any organic liquid introduced, placed or stored to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 6. Formerly permit number S-3505-6-0. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-365-1 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

11,004 GALLON FIXED ROOF STORAGE TANK

- 1. The true vapor pressure of any organic liquid introduced, placed or stored to the tank shall not exceed 1.5 psia at liquid temperature. [District Rule 4623, 2.0 and 2010], [Federally Enforceable Through Title V]
- 2. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 5. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]
- 6. Formerly permit number S-3505-9-0. []

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-366-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

63,000 GALLON (1,500 BBL) FIXED-ROOF CONSTANT LEVEL CRUDE OIL WASH TANK

- 1. True vapor pressure of any liquid introduced in this tank shall not exceed 0.5 psia at storage temperature. [District NSR Rule and 4623, 2.0], [Federally Enforceable Through Title V]
- 2. Tank shall be operated at constant level. [District NSR Rule], [Federally Enforceable Through Title V]
- 3. VOC emissions from tank shall not exceed 0.9 lb/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, and true vapor pressure of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally Enforceable Through Title V]
- 6. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 7. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-367-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

42,000 GALLON (1,000 BBL) FIXED ROOF CRUDE OIL STOCK TANK

- 1. True vapor pressure of any liquid introduced in this tank shall not exceed 0.5 psia at storage temperature. [District NSR Rule and 4623, 2.0], [Federally Enforceable Through Title V]
- 2. Throughput shall not exceed 500 bbl/day (monthly average). [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Emissions from tank shall not exceed 1.9 lb/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, throughput, and true vapor pressure
 of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally
 Enforceable Through Title V]
- 6. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 7. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1372-368-2 **EXPIRATION DATE:** 05/31/2007

EQUIPMENT DECRIPTION:

42,000 GALLON (1,000 BBL) FIXED ROOF CRUDE OIL STOCK TANK

- 1. True vapor pressure of any liquid introduced in this tank shall not exceed 0.5 psia at storage temperature. [District NSR Rule and 4623, 2.0], [Federally Enforceable Through Title V]
- 2. Throughput shall not exceed 500 bbl/day (monthly average). [District NSR Rule], [Federally Enforceable Through Title V]
- 3. Emissions from tank shall not exceed 1.9 lb/day. [District NSR Rule], [Federally Enforceable Through Title V]
- 4. Operator shall determine the true vapor pressure of the petroleum liquid stored in the tank at least once per year in accordance with methods described in Section 6.2 of District Rule 4623 (Amended 12/17/92). Determinations shall be made annually during summer and whenever there is a change in the source or type of petroleum entering the tank. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- Operator shall keep accurate records of types of liquids stored in each container, storage temperature, throughput, and true vapor pressure
 of liquids stored to verify continued exemption from District Rule 4623 (as amended December 17, 1992). [District Rule 2520, 9.1], [Federally
 Enforceable Through Title V]
- 6. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.4.2], [Federally Enforceable Through Title V]
- 7. The requirements of SJVUAPCD Rule 4623 (Amended 12/17/92) do not apply to this source. Also, this unit has a storage capacity less than 420,000 gallons and is used for petroleum or condensate stored, processed and/or treated at a drilling and production facility prior to custody transfer. Tank emissions are fugitive emissions not considered to come from a point source. Therefore, the requirements of Rule 4801 (Amended 12/17/92) and 40 CFR Part 60 Subparts K, Ka, and Kb do not apply to this source. A permit shield is granted from these requirements [District Rule 2520, 13.2], [Federally Enforceable Through Title V]